

**Permit #:** 28.0701 -PSD

**Effective Date:** Draft



**SOUTH DAKOTA DEPARTMENT OF  
ENVIRONMENT AND NATURAL RESOURCES  
PREVENTION OF SIGNIFICANT DETERIORATION  
AIR QUALITY PRECONSTRUCTION PERMIT**

**Steven M Pirner, Secretary  
Department of Environment and Natural Resources**

**Under the South Dakota Air Pollution  
Control Regulations**

Pursuant to Chapter 34A-1-21 of the South Dakota Codified Laws and the Air Pollution Control Regulations of the State of South Dakota and in reliance on statements made by the owner designated below, a permit to construct and operate is hereby issued by the Secretary of the Department of Environment and Natural Resources. This permit authorizes such owner to construct and operate the permitted units at the location designated below and under the listed conditions:

**A. Owner**

**1. Company name and address**

Hyperion Energy Center – Hyperion Refining LLC  
1350 Premier Place, 5910 N. Central Expressway  
Dallas, Texas 75206

**2. Actual Source Location and Mailing Address if Different from Above**

316<sup>th</sup> Street and 474<sup>th</sup> Avenue  
Union County, South Dakota

**3. Permit Contact**

Colin Campbell, Project Manager  
(919) 845-1422

**4. Facility Contact**

**5. Responsible Official**

Preston Phillips, Vice President  
(214) 750-4336

**B. Type of Operation**

A 400,000 barrel per day greenfield petroleum refinery and an integrated gasification combined cycle electric utility plant.

# TABLE OF CONTENTS

---

	Page
<b>1.0 STANDARD CONDITIONS .....</b>	<b>1</b>
1.1 Construction and operation of source.....	1
1.2 Duty to comply. ....	18
1.3 Property rights or exclusive privileges.....	18
1.4 Penalty for violating a permit condition. ....	18
1.5 Inspection and entry. ....	19
1.6 Severability.....	19
1.7 Credible evidence.....	19
<b>2.0 CONSTRUCTION AND OPERATING PERMIT DEADLINES .....</b>	<b>19</b>
2.1 Commence construction.....	19
2.2 Submit operating permit application.....	19
<b>3.0 RECORDKEEPING AND REPORTING REQUIREMENTS.....</b>	<b>20</b>
3.1 Recordkeeping and reporting.....	20
3.2 Signatory Requirements.....	20
3.3 Certification statement.....	20
3.4 Construction date notification.....	21
3.5 Initial startup notification.....	21
3.6 Daily log.....	21
3.7 Startup, shutdown, and malfunction plan recordkeeping .....	21
3.8 Quarterly reports.....	22
<b>4.0 BEST AVAILABLE CONTROL TECHNOLOGY (BACT) LIMITS...23</b>	
4.1 BACT limits for particulate matter.....	23
4.2 BACT limits for sulfur dioxide.....	29
4.3 BACT limits for nitrogen oxide.....	35
4.4 BACT limits for volatile organic compounds as carbon.....	41
4.5 BACT limits for carbon monoxide.....	44
4.6 BACT limit for sulfuric acid mist.....	47
4.7 BACT limit for hydrogen sulfide.....	49
4.8 Compliance with BACT limits during startup, shutdown, and malfunction.....	50
<b>5.0 Operational Limits.....</b>	<b>50</b>
5.1 Refinery crude oil.....	50
5.2 IGCC system.....	50
5.3 Cooling tower.....	50
5.4 Paved roads and parking lots.....	51
5.5 Sulfur recovery plant.....	51
5.6 Combined cycle combustion turbines.....	51
5.7 Gasifier startup burner.....	51
5.8 Diesel generators and fire pumps.....	51
<b>6.0 New Source Performance Standards .....</b>	<b>53</b>

# TABLE OF CONTENTS

---

	Page
6.1	New source performance standard – Subpart A.....53
6.2	New source performance standard – Subpart Da.....53
6.3	New source performance standard – Subpart J.....54
6.4	New source performance standard – Subpart Ja.....54
6.5	New source performance standard – Subpart Kb. ....54
6.6	New source performance standard – Subpart Y.....54
6.7	New source performance standard – Subpart UU.....54
6.8	New source performance standard – Subpart NNN.....54
6.9	New source performance standard – Subpart OOO. ....54
6.10	New source performance standard – Subpart RRR.....55
6.11	New source performance standard – Subpart IIII. ....55
6.12	New source performance standard – Subpart KKKK. ....55
7.0	National Emission Standards for Hazardous Air Pollutants .....55
7.1	National emission standards for hazardous air pollutants – Subpart A. ....55
7.2	National emission standards for hazardous air pollutants – Subpart FF. ....55
8.0	Maximum Achievable Control Technology Standard .....55
8.1	Maximum Achievable Control Technology Standard – Subpart A.....56
8.2	Maximum Achievable Control Technology Standard – Subpart B. ....56
8.3	Maximum Achievable Control Technology Standard – Subpart H.....57
8.4	Maximum Achievable Control Technology Standard – Subpart Q.....57
8.5	Maximum Achievable Control Technology Standard – Subpart CC.....58
8.6	Maximum Achievable Control Technology Standard – Subpart UUU. ....58
9.0	Other Applicable Limits .....58
9.1	State opacity limit. ....58
10.0	PERFORMANCE TESTS .....58
10.1	Performance test may be required. ....58
10.2	Test methods and procedures. ....59
10.3	Representative performance test. ....59
10.4	Submittal of test plan.....59
10.5	Notification of test. ....59
10.6	Performance test report. ....59
10.7	Initial particulate performance tests.....59
10.8	Initial sulfur dioxide performance tests.....61
10.9	Initial nitrogen oxide performance tests.....62
10.10	Initial volatile organic compound performance tests .....62
10.11	Initial carbon monoxide performance tests.....64
10.12	Initial hydrogen sulfide performance tests.....64
10.13	Initial hydrogen chloride performance tests .....64
10.14	Initial certification of continuous emission monitoring system.....65
11.0	CONTINUOUS EMISSION MONITORING SYSTEMS.....65

# TABLE OF CONTENTS

---

	Page
11.1 Sulfur dioxide continuous emission monitoring systems. ....	65
11.2 Nitrogen oxide continuous emission monitoring systems.....	67
11.3 Carbon monoxide continuous emission monitoring systems. ....	68
<b>12.0 REFINERY FLARE WORK PRACTICE STANDARDS .....</b>	<b>70</b>
12.1 Refinery flare operations.....	70
12.2 Refinery flare design.....	70
12.3 Refinery flare minimization plan. ....	70
12.4 Refinery flare recordkeeping and reporting. ....	72
12.5 Root cause analysis, recordkeeping and reporting. ....	72
<b>13.0 IGCC FLARE WORK PRACTICE STANDARDS .....</b>	<b>73</b>
13.1 IGCC flare operations. ....	73
13.2 IGCC flare design. ....	73
13.3 IGCC flare minimization plan.....	73
13.4 IGCC flare recordkeeping and reporting.....	75
<b>14.0 LDAR PROGRAM .....</b>	<b>75</b>
14.1 Periodic monitoring of pumps in light liquid service. ....	75
14.2 Periodic monitoring of compressors. ....	76
14.3 Periodic monitoring of pressure relief devices in gas/vapor service. ....	77
14.4 Periodic monitoring of sampling connection systems.....	77
14.5 Periodic monitoring of open-ended valves and lines. ....	78
14.6 Periodic monitoring of valves in gas/vapor service and light liquid service. .	78
14.7 Periodic monitoring of other pumps, valves, connectors, etc. ....	79
14.8 Periodic monitoring of surge control vessels and bottom receivers.....	79
14.9 Periodic monitoring of closed vent systems and control devices.....	80
14.10 Periodic monitoring of agitators in gas/vapor service and in light liquid service.....	81
14.11 Periodic monitoring of connectors in gas/vapor service and in light liquid service.....	82
14.12 Repair delay.....	83
14.13 Cooling tower heat exchanger.....	84
<b>15.0 WASTEWATER TREATMENT FACILITY STANDARDS .....</b>	<b>84</b>
15.1 Wastewater collection system. ....	84
15.2 Wastewater stripper. ....	84
15.3 Equalization tank. ....	85
15.4 Oil/Water Separator and DAF Units. ....	85
<b>16.0 FUGITIVE DUST CONTROLS .....</b>	<b>85</b>
16.1 Fugitive dust plan.....	85
16.2 Unpaved road controls. ....	85
16.3 Paved roads and parking area controls. ....	85
16.4 Track out area controls. ....	86

# TABLE OF CONTENTS

---

	Page
<b>16.5</b> Open storage pile control. ....	<b>86</b>
<b>16.6</b> Waste pit controls. ....	<b>86</b>
<b>16.8</b> Opacity limit for fugitive sources. ....	<b>87</b>
<b>16.9</b> Coke moisture content. ....	<b>87</b>
<b>16.10</b> Material unloading. ....	<b>87</b>
<b>16.11</b> Coke pit. ....	<b>87</b>
<b>16.12</b> Opacity limit for storage building. ....	<b>87</b>
<b>17.0</b> RECOMMENDATION.....	<b>87</b>

## 1.0 STANDARD CONDITIONS

**1.1 Construction and operation of source.** In accordance with Administrative Rules of South Dakota (ARSD) 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall construct and operate the units, controls, and processes as described in Table 1-1 in accordance with the statements, representations, and supporting data contained in the complete permit application submitted and dated December 20, 2007, unless modified by the conditions of this permit. The application consists of the application forms, updates, supporting data, and supplementary correspondence. If the owner or operator becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in an application, such information shall be promptly submitted. The control equipment shall be operated in a manner that achieves compliance with the conditions of this permit at all times.

*Table 1-1 – Description of Permitted Units, Operations, and Processes*

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
<b>#1</b>	Atmospheric crude charge heater #1. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	530 million Btus per hour heat input	Selective catalytic reduction
<b>#2</b>	Atmospheric crude charge heater #2. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	530 million Btus per hour heat input	Selective catalytic reduction
<b>#3</b>	Vacuum charge heater #1. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	215 million Btus per hour heat input	Selective catalytic reduction
<b>#4</b>	Vacuum charge heater #2. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	215 million Btus per hour heat input	Selective catalytic reduction
<b>#5</b>	Naphtha hydrotreater charge heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	200 million Btus per hour heat input	Selective catalytic reduction
<b>#6</b>	Naphtha hydrotreater stripper reboiler heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	169 million Btus per hour heat input	Selective catalytic reduction
<b>#7</b>	Naphtha splitter reboiler heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	247 million Btus per hour heat input	Selective catalytic reduction
<b>#8</b>	Distillate hydrotreater feed heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	141 million Btus per hour heat input	Selective catalytic reduction

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
<b>#9</b>	Delayed coker #1A heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	243 million Btus per hour heat input	Selective catalytic reduction
<b>#10</b>	Delayed coker #1B heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	243 million Btus per hour heat input	Selective catalytic reduction
<b>#11</b>	Delayed coker #2A heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	243 million Btus per hour heat input	Selective catalytic reduction
<b>#12</b>	Delayed coker #2B heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	243 million Btus per hour heat input	Selective catalytic reduction
<b>#13</b>	Number one platformer charge and interheater #1. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	825 million Btus per hour heat input	Selective catalytic reduction
<b>#14</b>	Number one platformer interheater #2 and #3. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	493 million Btus per hour heat input	Selective catalytic reduction
<b>#15</b>	Number two platformer charge and interheater #1. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	825 million Btus per hour heat input	Selective catalytic reduction
<b>#16</b>	Number two platformer interheater #2 and #3. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	493 million Btus per hour heat input	Selective catalytic reduction
<b>#17</b>	Oleflex heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	604 million Btus per hour heat input	Selective catalytic reduction
<b>#18</b>	Reformate splitter reboiler. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	138 million Btus per hour heat input	Selective catalytic reduction
<b>#19</b>	Number one hydrocracker fractionator feed heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	676 million Btus per hour heat input	Selective catalytic reduction
<b>#20</b>	Number two hydrocracker fractionator feed heater. The unit is fired on refinery fuel gas and is equipped with Low-NOx burners.	676 million Btus per hour heat input	Selective catalytic reduction

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
#21	Number one hydrocracker heater #1A. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	67 million Btus per hour heat input	Not applicable
#22	Number one hydrocracker heater #1B. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	67 million Btus per hour heat input	Not applicable
#23	Number one hydrocracker heater #1C. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	67 million Btus per hour heat input	Not applicable
#24	Number one hydrocracker heater #2A. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	65 million Btus per hour heat input	Not applicable
#25	Number one hydrocracker heater #2B. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	65 million Btus per hour heat input	Not applicable
#26	Number two hydrocracker heater #1A. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	67 million Btus per hour heat input	Not applicable
#27	Number two hydrocracker heater #1B. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	67 million Btus per hour heat input	Not applicable
#28	Number two hydrocracker heater #1C. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	67 million Btus per hour heat input	Not applicable
#29	Number two hydrocracker heater #2A. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	65 million Btus per hour heat input	Not applicable
#30	Number two hydrocracker heater #2B. The unit is fired on refinery fuel gas and is equipped with Ultra Low-NOx burners.	65 million Btus per hour heat input	Not applicable
#31	Number one platformer catalyst regenerator.	79,500 barrels per day	Caustic scrubber
#32	Number two platformer catalyst	79,500 barrels per day	Caustic scrubber

Unit	Description	Operating Rate <sup>1</sup>	Control Device
	regenerator.		
#33	Oleflex catalyst regenerator.	18,000 barrels per day	Caustic scrubber
#34a	Coke drum #1 – Steam vent A	60,000 barrels per day	Not applicable
#34b	Coke drum #1 – Steam vent B		Not applicable
#34c	Coke drum #1 – Steam vent C		Not applicable
#34d	Coke drum #1 – Steam vent D		Not applicable
#35a	Coke drum #2 – Steam vent A	60,000 barrels per day	Not applicable
#35b	Coke drum #2 – Steam vent B		Not applicable
#35c	Coke drum #2 – Steam vent C		Not applicable
#35d	Coke drum #2 – Steam vent D		Not applicable
#36	Refinery flare #1. The unit is fired on natural gas and the exhaust gases from the refinery during emergency conditions.	1 million Btus per hour heat input <sup>2</sup>	Not applicable
#37	Refinery flare #2. The unit is fired on natural gas and the exhaust gases from the refinery during emergency conditions.	1 million Btus per hour heat input <sup>2</sup>	Not applicable
#38	Refinery flare #3. The unit is fired on natural gas and the exhaust gases from the refinery during emergency conditions.	1 million Btus per hour heat input <sup>2</sup>	Not applicable
#39	Refinery flare #4. The unit is fired on natural gas and the exhaust gases from the refinery during emergency conditions.	1 million Btus per hour heat input <sup>2</sup>	Not applicable
#40	Refinery flare #5. The unit is fired on natural gas and the exhaust gases from the refinery during emergency conditions.	1 million Btus per hour heat input <sup>2</sup>	Not applicable
#41	Fan air cooler and wet cooling tower. The unit has 13 cells.	130,000 gallons per minute	High efficiency drift eliminators
	Sulfur recovery plant. The sulfur recovery plant consists of six lines; each includes a Claus Reactor and tail gas treater.	2,040 long tons per day; or 1,884 long tons per day <sup>3</sup>	Six thermal oxidizers
#42a	Thermal oxidizer #1. The thermal oxidizer is fired on refinery fuel gas and natural gas and equipped with Low-NOx burners.	101 million Btus per hour heat input	
#42b	Thermal oxidizer #2. The thermal oxidizer is fired on refinery fuel gas and natural gas and equipped with Low-NOx burners.	101 million Btus per hour heat input	

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
#42c	Thermal oxidizer #3. The thermal oxidizer is fired on refinery fuel gas and natural gas and equipped with Low-NOx burners.	101 million Btus per hour heat input	
#42d	Thermal oxidizer #4. The thermal oxidizer is fired on refinery fuel gas and natural gas and equipped with Low-NOx burners.	101 million Btus per hour heat input	
#42e	Thermal oxidizer #5. The thermal oxidizer is fired on refinery fuel gas and natural gas and equipped with Low-NOx burners.	101 million Btus per hour heat input	
#42f	Thermal oxidizer #6. The thermal oxidizer is fired on refinery fuel gas and natural gas and equipped with Low-NOx burners.	101 million Btus per hour heat input	
#43	Railcar loading rack.	16,000 barrels per day	Vacuum-regenerated, carbon adsorption-based vapor recovery system
#44	Truck loading rack.	16,000 barrels per day	Vacuum-regenerated, carbon adsorption-based vapor recovery system
#45a	Wastewater treatment plant. The wastewater treatment plant will consist of a wastewater stripper and equipped with closed vents on the oil/water separators and primary dissolved air flotation systems.	Not available	Catalytic oxidizer and selective catalytic reduction
	Catalytic oxidizer. The catalytic oxidizer is fired on refinery fuel gas and natural gas.	1 million Btus per hour heat input	
#45b	Wastewater treatment drains with a vent.	Not applicable	Closed vent system and dual carbon canisters
#45c	Two aeration tanks.	Not applicable	Internal floating roof
#46a #46b #46c #46d	Petroleum coke storage building.	1,000 tons per hour	Four baghouses
	Baghouse #1.		
	Baghouse #2.		
	Baghouse #3.		
#46d	Baghouse #4.		
#47	Coal/Coke unloading building.	1,000 tons per hour	Baghouse
#48	Flux unloading building.	100 tons per hour	Baghouse
#49	Slag loading building.	100 tons per hour	Baghouse

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
<b>#50</b>	Gasification system. Oxygen blown, slagging gasifiers with shift conversion reactors.	10,564 million Btus per hour heat input	Flare
	Flare. The unit is fired on natural gas and the exhaust gases from the startup, shutdown, and malfunctions of the gasification system.	787 million Btus per hour heat input	
<b>#51</b>	Gasifier startup burner #1. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#52</b>	Gasifier startup burner #2. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#53</b>	Gasifier startup burner #3. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#54</b>	Gasifier startup burner #4. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#55</b>	Gasifier startup burner #5. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#56</b>	Gasifier startup burner #6. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#57</b>	Gasifier startup burner #7. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#58</b>	Gasifier startup burner #8. The unit is fired on natural gas and equipped with Low-NOx burners.	18 million Btus per hour heat input	Not applicable
<b>#59</b>	Power island acid gas removal system. Rectisol ® wash	544 million standard cubic feet of syngas per day	Not applicable
<b>#60</b>	Combined cycle gas turbine #1.	1,677 million Btus per hour heat input	Catalytic reactor system and selective catalytic reduction
	Option #1 – The unit is fired on syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and diluent injection.		

Unit	Description	Operating Rate <sup>1</sup>	Control Device
	Option #2 – The unit is fired on pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and dry Low-NOx combustion burners.		
<b>#61</b>	<p>Combined cycle gas turbine #2.</p> <p>Option #1 – The unit is fired on syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and diluent injection.</p> <p>Option #2 – The unit is fired on pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and dry Low-NOx combustion burners.</p>	1,677 million Btus per hour heat input	Catalytic reactor system and selective catalytic reduction
<b>#62</b>	<p>Combined cycle gas turbine #3.</p> <p>Option #1 – The unit is fired on syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and diluent injection.</p> <p>Option #2 – The unit is fired on pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and dry Low-NOx combustion burners.</p>	1,677 million Btus per hour heat input	Catalytic reactor system and selective catalytic reduction
<b>#63</b>	<p>Combined cycle gas turbine #4.</p> <p>Option #1 – The unit is fired on syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and diluent injection.</p>	1,677 million Btus per hour heat input	Catalytic reactor system and selective catalytic reduction

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
	Option #2 – The unit is fired on pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and dry Low-NOx combustion burners.		
<b>#64</b>	Combined cycle gas turbine #5. Option #1 – The unit is fired on syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and diluent injection.	1,677 million Btus per hour heat input	Catalytic reactor system and selective catalytic reduction
	Option #2 – The unit is fired on pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil and equipped with Low-NOx duct burners and dry Low-NOx combustion burners.		
<b>#65</b>	Emergency generator #1. The unit is fired on ultra low sulfur distillate oil.	600 kilowatts	Not applicable
<b>#66</b>	Emergency generator #2. The unit is fired on ultra low sulfur distillate oil.	600 kilowatts	Not applicable
<b>#67</b>	Emergency generator #3. The unit is fired on ultra low sulfur distillate oil.	600 kilowatts	Not applicable
<b>#68</b>	Emergency generator #4. The unit is fired on ultra low sulfur distillate oil.	600 kilowatts	Not applicable
<b>#69</b>	Fire water pump #1. The unit is fired on ultra low sulfur distillate oil.	2,250 kilowatts	Not applicable
<b>#70</b>	Fire water pump #2. The unit is fired on ultra low sulfur distillate oil.	2,250 kilowatts	Not applicable
<b>#71</b>	Aboveground storage tank #RF1-1. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#72</b>	Aboveground storage tank #RF1-2. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
<b>#73</b>	Aboveground storage tank #RF1-3. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#74</b>	Aboveground storage tank #RF1-4. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#75</b>	Aboveground storage tank #RF1-5. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#76</b>	Aboveground storage tank #RF1-6. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#77</b>	Aboveground storage tank #RF1-7. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#78</b>	Aboveground storage tank #RF1-8. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#79</b>	Aboveground storage tank #RF1-9. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#80</b>	Aboveground storage tank #RF1-10. The tank will store crude oil or other petroleum liquids.	21,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#81</b>	Aboveground storage tank #RP4-1. The tank will store conventional regular gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#82</b>	Aboveground storage tank #RP4-2. The tank will store conventional regular gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#83</b>	Aboveground storage tank #RP5-1. The tank will store conventional premium gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#84</b>	Aboveground storage tank #RP6-1. The tank will store conventional regular subgrade gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#85</b>	Aboveground storage tank #RP6-2. The tank will store conventional regular subgrade gasoline or other	8,400,000 gallons	Internal floating roof and Unit #175 or #176

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
	petroleum liquids.		
<b>#86</b>	Aboveground storage tank #RP6-3. The tank will store conventional regular subgrade gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#87</b>	Aboveground storage tank #RP6-4. The tank will store conventional regular subgrade gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#88</b>	Aboveground storage tank #RP6-5. The tank will store conventional regular subgrade gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#89</b>	Aboveground storage tank #RP6-6. The tank will store conventional regular subgrade gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#90</b>	Aboveground storage tank #RP6-7. The tank will store conventional regular subgrade gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#91</b>	Aboveground storage tank #RP7-1. The tank will store conventional premium subgrade gasoline or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#92</b>	Aboveground storage tank #RP8-1. The tank will store reformulated regular gasoline blendstock for oxygen blending or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#93</b>	Aboveground storage tank #RP8-2. The tank will store reformulated regular gasoline blendstock for oxygen blending or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#94</b>	Aboveground storage tank #RP8-3. The tank will store reformulated regular gasoline blendstock for oxygen blending or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#95</b>	Aboveground storage tank #RP8-4. The tank will store reformulated regular gasoline blendstock for oxygen blending or other petroleum	8,400,000 gallons	Internal floating roof and Unit #175 or #176

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
	liquids.		
<b>#96</b>	Aboveground storage tank #RP9-1. The tank will store reformulated premium gasoline blendstock for oxygen blending or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#97</b>	Aboveground storage tank #RP10-1. The tank will store jet fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#98</b>	Aboveground storage tank #RP10-2. The tank will store jet fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#99</b>	Aboveground storage tank #RP10-3. The tank will store jet fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#100</b>	Aboveground storage tank #RP11-1. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#101</b>	Aboveground storage tank #RP11-2. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#102</b>	Aboveground storage tank #RP11-3. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#103</b>	Aboveground storage tank #RP11-4. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#104</b>	Aboveground storage tank #RP11-5. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#105</b>	Aboveground storage tank #RP11-6. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#106</b>	Aboveground storage tank #RP11-7. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
<b>#107</b>	Aboveground storage tank #RP11-8. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#108</b>	Aboveground storage tank #RP11-9. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#109</b>	Aboveground storage tank #RP11-10. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#110</b>	Aboveground storage tank #RP11-11. The tank will store ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#111</b>	Aboveground storage tank #IP3-1. The tank will store light straight run from the crude unit or other petroleum liquids.	10,500,000 gallons	Internal floating roof and Unit #175 or #176
<b>#112</b>	Aboveground storage tank #IP3-2. The tank will store light straight run from the crude unit or other petroleum liquids.	10,500,000 gallons	Internal floating roof and Unit #175 or #176
<b>#113</b>	Aboveground storage tank #IP4-1. The tank will store coker naphtha or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#114</b>	Aboveground storage tank #IP5-1. The tank will store hydrotreated light naphtha or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#115</b>	Aboveground storage tank #IP5-2. The tank will store hydrotreated light naphtha or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#116</b>	Aboveground storage tank #IP6-1. The tank will store hydrotreated heavy naphtha or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#117</b>	Aboveground storage tank #IP6-2. The tank will store hydrotreated heavy naphtha or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
<b>#118</b>	Aboveground storage tank #IP7-1. The tank will store heavy hydrocracker naphtha or other petroleum liquids.	14,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#119</b>	Aboveground storage tank #IP7-2. The tank will store heavy hydrocracker naphtha or other petroleum liquids.	14,000,000 gallons	Internal floating roof and Unit #175 or #176
<b>#120</b>	Aboveground storage tank #IP8-1. The tank will store light hydrocracker naphtha or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#121</b>	Aboveground storage tank #IP8-2. The tank will store light hydrocracker naphtha or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#122</b>	Aboveground storage tank #IP9-1. The tank will store light reformate or other petroleum liquids.	4,200,000 gallons	Internal floating roof and Unit #175 or #176
<b>#123</b>	Aboveground storage tank #IP10-1. The tank will store saturated light hydrocracker naphtha or other petroleum liquids.	2,100,000 gallons	Internal floating roof and Unit #175 or #176
<b>#124</b>	Aboveground storage tank #IP10-2. The tank will store saturated light hydrocracker naphtha or other petroleum liquids.	2,100,000 gallons	Internal floating roof and Unit #175 or #176
<b>#125</b>	Aboveground storage tank #IP11-1. The tank will store reformate or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#126</b>	Aboveground storage tank #IP11-2. The tank will store reformate or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#127</b>	Aboveground storage tank #IP11-3. The tank will store reformate or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#128</b>	Aboveground storage tank #IP11-4. The tank will store reformate or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#129</b>	Aboveground storage tank #IP12-1. The tank will store heavy reformate or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
<b>#130</b>	Aboveground storage tank #IP13-1. The tank will store isomerate or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#131</b>	Aboveground storage tank #IP13-2. The tank will store isomerate or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#132</b>	Aboveground storage tank #IP14-1. The tank will store indirect alkylation process alkylate or other petroleum liquids.	2,500,000 gallons	Internal floating roof and Unit #175 or #176
<b>#133</b>	Aboveground storage tank #IP14-2. The tank will store indirect alkylation process alkylate or other petroleum liquids.	2,500,000 gallons	Internal floating roof and Unit #175 or #176
<b>#134</b>	Aboveground storage tank #IP15-1. The tank will store indirect alkylation process C12+ stream or other petroleum liquids.	450,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#135</b>	Aboveground storage tank #IP16-1. The tank will store straight run kerosene or other petroleum liquids.	4,200,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#136</b>	Aboveground storage tank #IP16-2. The tank will store straight run kerosene or other petroleum liquids.	4,200,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#137</b>	Aboveground storage tank #IP17-1. The tank will store straight run diesel or other petroleum liquids.	4,200,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#138</b>	Aboveground storage tank #IP17-2. The tank will store straight run diesel or other petroleum liquids.	4,200,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#139</b>	Aboveground storage tank #IP17-3. The tank will store straight run diesel or other petroleum liquids.	4,200,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#140</b>	Aboveground storage tank #IP18-1. The tank will store atmospheric gas oil or other petroleum liquids.	4,200,000 gallons	Fixed roof and Unit #175 or #176
<b>#141</b>	Aboveground storage tank #IP19-1. The tank will store light coker gas oil or other petroleum liquids.	4,200,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#142</b>	Aboveground storage tank #IP19-2. The tank will store light coker gas	4,200,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
	oil or other petroleum liquids.		
<b>#143</b>	Aboveground storage tank #IP20-1. The tank will store distillate hydrotreater desulfurization ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#144</b>	Aboveground storage tank #IP20-2. The tank will store distillate hydrotreater desulfurization ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#145</b>	Aboveground storage tank #IP20-3. The tank will store distillate hydrotreater desulfurization ultra low sulfur diesel fuel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#146</b>	Aboveground storage tank #IP21-1. The tank will store distillate hydrotreater desulfurization Naphtha or other petroleum liquids.	2,100,000 gallons	Internal floating roof and Unit #175 or #176
<b>#147</b>	Aboveground storage tank #IP22-1. The tank will store hydrocracker diesel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#148</b>	Aboveground storage tank #IP22-2. The tank will store hydrocracker diesel or other petroleum liquids.	8,400,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#149</b>	Aboveground storage tank #IP23-1. The tank will store vacuum gas oil or other petroleum liquids.	14,000,000 gallons	Fixed roof and Unit #175 or #176
<b>#150</b>	Aboveground storage tank #IP23-2. The tank will store vacuum gas oil or other petroleum liquids.	14,000,000 gallons	Fixed roof and Unit #175 or #176
<b>#151</b>	Aboveground storage tank #IP23-3. The tank will store vacuum gas oil or other petroleum liquids.	14,000,000 gallons	Fixed roof and Unit #175 or #176
<b>#152</b>	Aboveground storage tank #IP24-1. The tank will store heavy coker gas oil or other petroleum liquids.	4,200,000 gallons	Fixed roof and Unit #175 or #176
<b>#153</b>	Aboveground storage tank #IP24-2. The tank will store heavy coker gas oil or other petroleum liquids.	4,200,000 gallons	Fixed roof and Unit #175 or #176
<b>#154</b>	Aboveground storage tank #IP25-1.	21,000,000 gallons	Fixed roof and Unit #175

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
	The tank will store vacuum residuum or other petroleum liquids.		or #176
<b>#155</b>	Aboveground storage tank #IP25-2. The tank will store vacuum residuum or other petroleum liquids.	21,000,000 gallons	Fixed roof and Unit #175 or #176
<b>#156</b>	Aboveground storage tank #IP26-1. The tank will store ethanol or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176
<b>#157</b>	Aboveground storage tank #IP26-2. The tank will store ethanol or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176
<b>#158</b>	Aboveground storage tank #SS1-1. The tank will store slop or other petroleum liquids.	3,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#159</b>	Aboveground storage tank #SS1-2. The tank will store slop or other petroleum liquids.	3,400,000 gallons	Internal floating roof and Unit #175 or #176
<b>#160</b>	Aboveground storage tank #SS2-1. The tank will store coker, crude, and/or vacuum sour water or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#161</b>	Aboveground storage tank #SS3-1. The tank will store hydrocracker and distillate hydrotreater desulfurization sour water or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#162</b>	Aboveground storage tank #SS4-1. The tank will store swing sour water or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176
<b>#163</b>	Aboveground storage tank #SS8-1. The tank will store amine (lean) or other petroleum liquids.	6,300,000 gallons	Fixed roof and Unit #175 or #176 <sup>4</sup>
<b>#164</b>	Aboveground storage tank #SS9-1. The tank will store amine (rich) or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#165</b>	Aboveground storage tank #SS10-1. The tank will store swing sour or sweet amine or other petroleum liquids.	6,300,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#166</b>	Aboveground storage tank #SS14-1. The tank will store gasoline with additives or other petroleum	150,000 gallons	Internal floating roof and Unit #175 or #176

<b>Unit</b>	<b>Description</b>	<b>Operating Rate <sup>1</sup></b>	<b>Control Device</b>
	liquids.		
<b>#167</b>	Aboveground storage tank #SS15-1. The tank will store gasoline with additives or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176
<b>#168</b>	Aboveground storage tank #SS16-1. The tank will store gasoline with additives or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176
<b>#169</b>	Aboveground storage tank #SS17-1. The tank will store gasoline with additives or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176
<b>#170</b>	Aboveground storage tank #SS18-1. The tank will store gasoline with additives or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176
<b>#171</b>	Aboveground storage tank #SS19-1. The tank will store gasoline with additives or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176
<b>#172</b>	Aboveground storage tank #SS20-1. The tank will store kerosene with additives or other petroleum liquids.	150,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#173</b>	Aboveground storage tank #SS21-1. The tank will store diesel with additives or other petroleum liquids.	140,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#174</b>	Aboveground storage tank #SS22-1. The tank will store methanol or other petroleum liquids.	31,000 gallons	Internal floating roof and Unit #175 or #176 <sup>4</sup>
<b>#175</b>	Tank farm thermal oxidizer. The thermal oxidizer may be fired on refinery gas, natural gas, and the vapors generated from the operation of the storage tanks. The thermal oxidizer will be equipped with Low-NOx burners.	Not applicable	Not applicable

Unit	Description	Operating Rate <sup>1</sup>	Control Device
#176	Tank farm thermal oxidizer. The thermal oxidizer may be fired on refinery gas, natural gas, and the vapors generated from the operation of the storage tanks. The thermal oxidizer will be equipped with Low-NOx burners.	Not applicable	Not applicable

<sup>1</sup> – The operating rate is the nominal or manufacturer listed operating rate noted in the PSD application and are descriptive only;

<sup>2</sup> – Represents maximum design operating rate of the pilot gas flow rate; and

<sup>3</sup> – The amount of sulfur produced per day is based on which fuel Option for the combined cycle combustion turbines. Option #1 consists of firing the combined cycle gas turbines with syngas, pressure swing adsorption tail gas; and distillate oil. Option #2 consists of firing the combined cycle gas turbines with pressure swing adsorption tail gas, natural gas, and distillate oil.

<sup>4</sup> – The thermal oxidizer may or may not be required depending on permit condition 5.11

**1.2 Duty to comply.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(12), the owner or operator shall comply with the conditions of this permit. An owner or operator who knowingly makes a false statement in any record or report or who falsifies, tampers with, or renders inaccurate, any monitoring device or method is in violation of this permit. A violation of any condition in this permit is grounds for enforcement, reopening this permit, permit termination, or denial of a permit renewal application. The owner or operator, in an enforcement action, cannot use the defense that it would have been necessary to cease or reduce the permitted activity to maintain compliance. The owner or operator shall provide any information requested by the Secretary to determine compliance or whether cause exists for reopening or terminating this permit.

**1.3 Property rights or exclusive privileges.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(12), the State’s issuance of this permit, adoption of design criteria, and approval of plans and specifications does not convey any property rights of any sort, any exclusive privileges, any authorization to damage, injure or use any private property, any authority to invade personal rights, any authority to violate federal, state or local laws or regulations, or any taking, condemnation or use of eminent domain against any property owned by third parties. The State does not warrant that the owner’s or operator’s compliance with this permit, design criteria, approved plans and specifications, and operation under this permit, will not cause damage, injury or use of private property, an invasion of personal rights, or violation of federal, state or local laws or regulations. The owner or operator is solely and severally liable for all damage, injury or use of private property, invasion of personal rights, infringement of federal, state or local laws and regulations, or taking or condemnation of property owned by third parties, which may result from actions taken under the permit.

**1.4 Penalty for violating a permit condition.** In accordance with South Dakota Codified

Law (SDCL) 34A-1, a violation of a permit condition may subject the owner or operator to civil or criminal prosecution, a state penalty of not more than \$10,000 per day per violation, injunctive action, administrative permit action, and other remedies as provided by law.

**1.5 Inspection and entry.** In accordance with SDCL 34A-1-41, the owner or operator shall allow the Secretary to:

1. Enter the premises where a regulated activity is located or where pertinent records are stored;
2. Have access to and copy any records that are required under this permit;
3. Inspect operations regulated under this permit; and/or
4. Sample or monitor any substances or parameters for the purpose of assuring compliance.

**1.6 Severability.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(11), any portion of this permit that is void or challenged shall not affect the validity of the remaining permit requirements.

**1.7 Credible evidence.** In accordance with ARSD 74:36:13:07, credible evidence may be used for the purpose of establishing whether the owner or operator has violated or is violation of this permit. Credible evidence is as follows:

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has occurred at the source:
  - a. A monitoring method approved for the source pursuant to 40 Code of Federal Regulations (CFR) §70.6(a)(3) and incorporated in this permit; or
  - b. Compliance methods specified in an applicable plan;
2. The following testing, monitoring, or information gathering methods are presumptively credible testing, monitoring, or information-gathering methods:
  - a. Any monitoring or testing methods approved in this permit, including those in 40 CFR Parts 51, 60, 61 and 75; or
  - b. Other testing, monitoring, or information-gathering methods that produce information comparable to that produced by any method in section (1) or (2)(a).

## **2.0 CONSTRUCTION AND OPERATING PERMIT DEADLINES**

**2.1 Commence construction.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(r)(2), the owner or operator shall commence construction within 18 months of the effective date of this permit. If construction is delayed or interrupted for a period of 18 months or more this permit becomes invalid. The owner or operator may apply, before the end of the 18-month period, to the Secretary for an extension. The Secretary may grant an extension after the owner or operator satisfactorily demonstrates that an extension is justified.

**2.2 Submit operating permit application.** In accordance with ARSD 74:36:05:03.01, the owner or operator shall submit a complete permit application for a Title V air quality permit within 12 months after the initial startup of the petroleum refinery. For the purpose of this condition, commencing operation means the initial startup of the petroleum refinery, which is the first date that the petroleum refinery receives crude oil for processing. A complete permit application shall include all of the requirements specified in ARSD 74:36:05:12, including

periodic monitoring and compliance assurance monitoring activities necessary to assure compliance.

### **3.0 RECORDKEEPING AND REPORTING REQUIREMENTS**

**3.1 Recordkeeping and reporting.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(9), the owner or operator shall maintain all monitoring data, records, reports, and pertinent information specified by this permit for five years from the date of sample, measurement, report, or application. The records shall be maintained on-site for the first two years and may be maintained off-site for the last three years. All records must be made available to the Secretary for inspection. All notifications and reports shall be submitted to the following address:

South Dakota Department of Environment and Natural Resources  
PMB 2020, Air Quality Program  
523 E. Capitol, Joe Foss Building  
Pierre, SD 57501-3181

**3.2 Signatory Requirements.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:12(17), all applications submitted to the Secretary shall be signed and certified by a responsible official. A responsible official for a corporation is a responsible corporate officer and for a partnership or sole proprietorship is a general partner or the proprietor, respectively. All reports or other information submitted to the Secretary shall be signed and certified by a responsible official or a duly authorized representative. A person is a duly authorized representative only if:

1. The authorization is made in writing by a person described above and submitted to the Secretary; and
2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters.

The responsible official shall notify the Secretary if an authorization is no longer accurate. The new duly authorized representative must be designated prior to or together with any reports or information to be signed by a duly authorized representative.

**3.3 Certification statement.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(14)(a), all documents required by this permit, including reports, must be certified by a responsible official or a duly authorized representative. The certification shall include the following statement:

“I certify that based on information and belief formed after reasonable inquiry the statements and information in this document and all attachments are true, accurate, and complete.”

**3.4 Construction date notification.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(9), the owner or operator shall notify the Secretary of the date construction commenced on the permanent structures for the petroleum refinery. The notification shall be postmarked within 15 days after the date construction commenced.

**3.5 Initial startup notification.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(9), the owner or operator shall notify the Secretary of the initial startup date of the petroleum refinery. The notification shall be postmarked within 15 days after the date of initial startup. Initial startup of the petroleum refinery is the date the first gallon of crude oil is received by the facility to be refined.

**3.6 Daily log.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(9), the owner or operator must maintain a daily log. The daily log shall contain the following information:

1. Maintenance schedule for the air pollution control equipment specified in Table 1-1. At a minimum, the maintenance schedule shall meet the manufacturer's recommended schedule for maintenance. The following information shall be recorded for any maintenance performed:
  - a. Identify the unit;
  - b. The date and time maintenance was performed;
  - c. Description of the type of maintenance;
  - d. Reason for performing maintenance; and
  - e. Signature of person performing maintenance;
2. The amount of crude oil processed, in barrels, through the petroleum refinery each day and a 365-daily average;
3. The time each sulfur recovery plant line and associated thermal oxidizer (Unit #42a through #42f), combined cycle combustion turbines (Unit #60 through #64), and gasifier startup burners (Unit #51 through #58) operated during the day;
4. The time each combined cycle combustion turbine (Unit #60 through #64) burned ultra low distillate oil during the day;
5. The number of hours each emergency generator and fire pump (Unit #65 through #70) operated, excluding operations during an emergency; and
6. An hourly sample of the wastewater that enters the oil/water separators shall be collected and analyzed to determine the benzene concentration, in parts per million by weight, in the wastewater. The flow-weighted average of the benzene concentration, in parts per million by weight, shall be calculated on a 24-hour basis for each day and a 365-daily average.

**3.7 Startup, shutdown, and malfunction plan recordkeeping.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall maintain a copy of the current Startup, Shutdown, and Malfunction plan at the site and must make the plan available upon request for inspection and copying by the Secretary. In addition, if the Startup, Shutdown, and Malfunction plan is subsequently revised, the owner or operator must maintain at the site each previous (i.e., superseded) version of the Startup, Shutdown, and Malfunction plan, and must make each previous version available for inspection and copying by the Secretary for a period of five years after revision of the plan. If at any time after adoption of a Startup,

Shutdown, and Malfunction plan the owner or operator ceases operation or is otherwise no longer subject to this permit condition, the owner or operator must retain a copy of the most recent plan for five years from the date the owner or operator ceases operation or is no longer subject to this permit condition and must make the plan available upon request for inspection and copying by the Secretary. The owner or operator must maintain the following records during a startup, shutdown, or malfunction occurrence:

1. The occurrence and duration of each startup or shutdown;
2. The occurrence and duration of each malfunction of operation (e.g. process equipment), the required air pollution control, or the monitoring equipment;
3. Actions taken during periods of startup or shutdown when the actions taken are different from the procedures specified in the Startup, Shutdown, and Malfunction plan;
4. Actions taken during periods of a malfunction when the actions taken are different from the procedures specified in the Startup, Shutdown, and Malfunction plan; and
5. All information necessary, including actions taken, to demonstrate conformance with the Startup, Shutdown, and Malfunction plan.

**3.8 Quarterly reports.** In accordance with ARSD 74:36:05:16.01(9), the owner or operator shall submit a quarterly report. The report shall contain the following information:

1. Name of the facility, permit number, reference to this permit condition, and identify the submittal as a quarterly report;
2. Calendar dates covered in the quarterly report;
3. A summary of the excess emissions as determined by the continuous emission monitoring systems:
  - a. The magnitude of the emissions that were greater than identified emission limit;
  - b. The date and duration of the excess emissions;
  - c. The causes of the excess emissions (startup/shutdown, control equipment problems, process problems, other known causes, or unknown causes); and
  - d. The percentage of time the excess emissions occurred during operation of the permitted unit;
4. The amount of time a continuous emission monitoring system was down due to monitoring equipment malfunction, non-monitoring malfunction, quality assurance calibrations, other known causes, or unknown causes;
5. The percentage of time a monitoring system was down while the permitted unit was in operation;
6. A summary of the amount of crude oil processed, in barrels, each day and the 365-day rolling average for each day in the reporting period;
7. A summary of any periods in which more than four of the six sulfur recovery lines and associated thermal oxidizers operated at one time during the reporting period, the reason that it occurred, and the procedures that will be taken to ensure only four of the sulfur recovery lines and associated thermal oxidizers are operated at one time in the future. If only four of the sulfur recovery lines and associated thermal oxidizers are operated at one time during the reporting period, a statement stating this fact shall be submitted;
8. A summary of any periods in which more than four of the five combined cycle combustion turbines operated at one time during the reporting period, the reason that it occurred, and the procedures that will be taken to ensure only four of the combined cycle combustion turbines

are operated at one time in the future. If only four of the combined cycle combustion turbines are operated at one time during the reporting period, a statement stating this fact shall be submitted;

9. A summary of any periods in which more than six of the eight gasifier startup burners operated at one time during the reporting period, the reason that it occurred, and the procedures that will be taken to ensure only six of the gasifier startup burners are operated at one time in the future. If only six of the gasifier startup burners are operated at one time during the reporting period, a statement stating this fact shall be submitted;
10. A summary of the number of hours the combined cycle combustion turbines operated while burning ultra low distillate oil during the month and the 12-month rolling total for each month in the reporting period;
11. A summary of the number of hours each generator and fire pump operated during the month and the 12-month rolling total for each month in the reporting period;
12. The 365-day average of the flow-weighted average benzene concentration, in parts per million by weight, for each day in the reporting period; and
13. A statement that the owner or operator followed the procedures specified in the Startup, Shutdown, and Malfunction plan during a startup, shutdown or malfunction during the reporting period. If an action taken by the owner or operator during a startup, shutdown, or malfunction (including an action taken to correct a malfunction) is not consistent with the procedures specified in the Startup, Shutdown, and Malfunction plan, the following information shall be included in the quarterly report:
  - a. An explanation of the circumstances of the event;
  - b. The reasons for not following the Startup, Shutdown, and Malfunction plan;
  - c. A description of all excess emissions and/or parameter monitoring exceedances which are believed to have occurred or could have occurred in the case of malfunctions; and
  - d. Actions taken to minimize emissions.

The first quarterly report shall be submitted at the end of the calendar quarter that the initial startup of the petroleum refinery occurred. All other quarterly reports shall be postmarked no later than the 30th day following the end of each calendar quarter (i.e. January 30<sup>th</sup>, April 30<sup>th</sup>, July 30<sup>th</sup>, and October 30<sup>th</sup>).

#### **4.0 BEST AVAILABLE CONTROL TECHNOLOGY (BACT) LIMITS**

**4.1 BACT limits for particulate matter.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall not allow the emissions of particulate matter 10 microns in diameter or less (PM10) in excess of the emission limits specified in Table 4-1 for the appropriate permitted unit, operation, and process.

*Table 4-1 – PM10 BACT Emission Limits*

Unit	Description	PM10 Emission Limit <sup>1</sup>
------	-------------	----------------------------------

<b>Unit</b>	<b>Description</b>	<b>PM10 Emission Limit <sup>1</sup></b>
<b>#1</b>	Atmospheric crude charge heater #1	0.0075 pounds per million Btus (filterable and condensable); and 4.0 pounds per hour (filterable and condensable)
<b>#2</b>	Atmospheric crude charge heater #2	0.0075 pounds per million Btus (filterable and condensable); and 4.0 pounds per hour (filterable and condensable)
<b>#3</b>	Vacuum charge heater #1	0.0075 pounds per million Btus (filterable and condensable); and 1.6 pounds per hour (filterable and condensable)
<b>#4</b>	Vacuum charge heater #2	0.0075 pounds per million Btus (filterable and condensable); and 1.6 pounds per hour (filterable and condensable)
<b>#5</b>	Naphtha hydrotreater charge heater	0.0075 pounds per million Btus (filterable and condensable); and 1.5 pounds per hour (filterable and condensable)
<b>#6</b>	Naphtha hydrotreater stripper reboiler heater	0.0075 pounds per million Btus (filterable and condensable); and 1.3 pounds per hour (filterable and condensable)
<b>#7</b>	Naphtha splitter reboiler heater	0.0075 pounds per million Btus (filterable and condensable); and 1.9 pounds per hour (filterable and condensable)
<b>#8</b>	Distillate hydrotreater feed heater	0.0075 pounds per million Btus (filterable and condensable); and 1.1 pounds per hour (filterable and condensable)
<b>#9</b>	Delayed coker #1A heater	0.0075 pounds per million Btus (filterable and condensable); and 1.8 pounds per hour (filterable and condensable)
<b>#10</b>	Delayed coker #1B heater	0.0075 pounds per million Btus (filterable and condensable); and 1.8 pounds per hour (filterable and condensable)
<b>#11</b>	Delayed coker #2A heater	0.0075 pounds per million Btus (filterable and condensable); and 1.8 pounds per hour (filterable and condensable)
<b>#12</b>	Delayed coker #2B heater	0.0075 pounds per million Btus (filterable and condensable); and 1.8 pounds per hour (filterable and condensable)
<b>#13</b>	Number one platformer charge and interheater #1	0.0075 pounds per million Btus (filterable and condensable); and 6.2 pounds per hour (filterable and condensable)
<b>#14</b>	Number one platformer interheater #2 and #3	0.0075 pounds per million Btus (filterable and condensable); and 3.7 pounds per hour (filterable and condensable)
<b>#15</b>	Number two platformer charge	0.0075 pounds per million Btus (filterable and

<b>Unit</b>	<b>Description</b>	<b>PM10 Emission Limit <sup>1</sup></b>
	and interheater #1	condensable); and 6.2 pounds per hour (filterable and condensable)
<b>#16</b>	Number two platformer interheater #2 and #3	0.0075 pounds per million Btus (filterable and condensable); and 3.7 pounds per hour (filterable and condensable)
<b>#17</b>	Oleflex heater	0.0075 pounds per million Btus (filterable and condensable); and 4.5 pounds per hour (filterable and condensable)
<b>#18</b>	Reformate splitter reboiler	0.0075 pounds per million Btus (filterable and condensable); and 1.0 pounds per hour (filterable and condensable)
<b>#19</b>	Number one hydrocracker fractionator feed heater	0.0075 pounds per million Btus (filterable and condensable); and 5.1 pounds per hour (filterable and condensable)
<b>#20</b>	Number two hydrocracker fractionator feed heater	0.0075 pounds per million Btus (filterable and condensable); and 5.1 pounds per hour (filterable and condensable)
<b>#21</b>	Number one hydrocracker heater #1A	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#22</b>	Number one hydrocracker heater #1B	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#23</b>	Number one hydrocracker heater #1C	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#24</b>	Number one hydrocracker heater #2A	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#25</b>	Number one hydrocracker heater #2B	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#26</b>	Number two hydrocracker heater #1A	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#27</b>	Number two hydrocracker heater #1B	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#28</b>	Number two hydrocracker heater #1C	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
<b>#29</b>	Number two hydrocracker heater	0.0075 pounds per million Btus (filterable and

<b>Unit</b>	<b>Description</b>	<b>PM10 Emission Limit <sup>1</sup></b>
	#2A	condensable); and 0.5 pounds per hour (filterable and condensable)
#30	Number two hydrocracker heater #2B	0.0075 pounds per million Btus (filterable and condensable); and 0.5 pounds per hour (filterable and condensable)
#31	Number one platformer catalyst regenerator	0.01 pounds per hour (filterable and condensable)
#32	Number two platformer catalyst regenerator	0.01 pounds per hour (filterable and condensable)
#33	Oleflex catalyst regenerator	0.002 pounds per hour (filterable and condensable)
#34	Coke drum #1 – Four steam vents	See Permit Condition 6.4
#35	Coke drum #2 – Four steam vents	See Permit Condition 6.4
#36	Refinery flare #1	See Chapter 12.0
#37	Refinery flare #2	See Chapter 12.0
#38	Refinery flare #3	See Chapter 12.0
#39	Refinery flare #4	See Chapter 12.0
#40	Refinery flare #5	See Chapter 12.0
#41	Cooling tower	See Permit Condition 5.3
#42a	Sulfur recovery plant thermal oxidizer #1	11.2 pounds per hour (filterable and condensable) and 0.0055 pounds per long ton sulfur loaded to the system <sup>2</sup>
#42b	Sulfur recovery plant thermal oxidizer #2	11.2 pounds per hour (filterable and condensable) and 0.0055 pounds per long ton sulfur loaded to the system <sup>2</sup>
#42c	Sulfur recovery plant thermal oxidizer #3	11.2 pounds per hour (filterable and condensable) and 0.0055 pounds per long ton sulfur loaded to the system <sup>2</sup>
#42d	Sulfur recovery plant thermal oxidizer #4	11.2 pounds per hour (filterable and condensable) and 0.0055 pounds per long ton sulfur loaded to the system <sup>2</sup>
#42e	Sulfur recovery plant thermal oxidizer #5	11.2 pounds per hour (filterable and condensable) and 0.0055 pounds per long ton sulfur loaded to the system <sup>2</sup>
#42f	Sulfur recovery plant thermal oxidizer #6	11.2 pounds per hour (filterable and condensable) and 0.0055 pounds per long ton sulfur loaded to the system <sup>2</sup>
#45a	Wastewater treatment plant thermal oxidizer	0.0075 pounds per million Btus (filterable and condensable); and 0.01 pounds per hour (filterable and condensable)
#46a	Petroleum coke storage building baghouse #1	0.005 grains per dry standard cubic foot (filterable); and 2.4 pounds per hour (filterable)
#46b	Petroleum coke storage building baghouse #2	0.005 grains per dry standard cubic foot (filterable); and 2.4 pounds per hour (filterable)

<b>Unit</b>	<b>Description</b>	<b>PM10 Emission Limit <sup>1</sup></b>
#46c	Petroleum coke storage building baghouse #3	0.005 grains per dry standard cubic foot (filterable); and 2.4 pounds per hour (filterable)
#46d	Petroleum coke storage building baghouse #4	0.005 grains per dry standard cubic foot (filterable); and 2.4 pounds per hour (filterable)
#47	Coal/Coke unloading building	0.005 grains per dry standard cubic foot (filterable); and 2.4 pounds per hour (filterable)
#48	Flux unloading building	0.005 grains per dry standard cubic foot (filterable); and 2.4 pounds per hour (filterable)
#49	Slag loading building	0.005 grains per dry standard cubic foot (filterable); and 2.4 pounds per hour (filterable)
#50	Gasification flare #1	See Chapter 13.0
#51	Gasifier startup burner #1	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#52	Gasifier startup burner #2	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#53	Gasifier startup burner #3	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#54	Gasifier startup burner #4	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#55	Gasifier startup burner #5	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#56	Gasifier startup burner #6	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#57	Gasifier startup burner #7	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#58	Gasifier startup burner #8	0.006 pounds per million Btus (filterable and condensable); and 0.1 pounds per hour (filterable and condensable)
#60	Combined cycle gas turbine #1	Burning a combination of syngas and pressure swing adsorption tail gas: 0.009 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)
		Burning a combination of pressure swing adsorption tail gas and natural gas: 0.006 pounds

Unit	Description	PM10 Emission Limit <sup>1</sup>
		<p>per million Btus (filterable); 0.011 pounds per million Btus (filterable and condensable); and 18.4 pounds per hour (filterable and condensable)</p> <p>Burning a distillate oil: 0.015 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)</p>
#61	Combined cycle gas turbine #2	<p>Burning a combination of syngas and pressure swing adsorption tail gas: 0.009 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)</p> <p>Burning a combination of pressure swing adsorption tail gas and natural gas: 0.006 pounds per million Btus (filterable); 0.011 pounds per million Btus (filterable and condensable); and 18.4 pounds per hour (filterable and condensable)</p>
		<p>Burning a distillate oil: 0.015 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)</p>
#62	Combined cycle gas turbine #3	<p>Burning a combination of syngas and pressure swing adsorption tail gas: 0.009 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)</p> <p>Burning a combination of pressure swing adsorption tail gas and natural gas: 0.006 pounds per million Btus (filterable); 0.011 pounds per million Btus (filterable and condensable); and 18.4 pounds per hour (filterable and condensable)</p> <p>Burning a distillate oil: 0.015 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)</p>
#63	Combined cycle gas turbine #4	<p>Burning a combination of syngas and pressure swing adsorption tail gas: 0.009 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)</p> <p>Burning a combination of pressure swing adsorption tail gas and natural gas: 0.006 pounds</p>

Unit	Description	PM10 Emission Limit <sup>1</sup>
		per million Btus (filterable); 0.011 pounds per million Btus (filterable and condensable); and 18.4 pounds per hour (filterable and condensable)
		Burning a distillate oil: 0.015 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)
#64	Combined cycle gas turbine #5	Burning a combination of syngas and pressure swing adsorption tail gas: 0.009 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)
		Burning a combination of pressure swing adsorption tail gas and natural gas: 0.006 pounds per million Btus (filterable); 0.011 pounds per million Btus (filterable and condensable); and 18.4 pounds per hour (filterable and condensable)
		Burning a distillate oil: 0.015 pounds per million Btus (filterable); 0.022 pounds per million Btus (filterable and condensable); and 36.9 pounds per hour (filterable and condensable)
#65	Emergency generator #1	See Permit Condition 6.11
#66	Emergency generator #2	See Permit Condition 6.11
#67	Emergency generator #3	See Permit Condition 6.11
#68	Emergency generator #4	See Permit Condition 6.11
#69	Fire water pump #1	See Permit Condition 6.11
#70	Fire water pump #2	See Permit Condition 6.11
#175	Tank farm thermal oxidizer	0.0075 pounds per million Btus (filterable and condensable)
#176	Tank farm thermal oxidizer	0.0075 pounds per million Btus (filterable and condensable)

<sup>1</sup> – Unless otherwise specified compliance with the emission limits is based on the average of three test runs based on the performance test procedures and requirements in Chapter 10.0; and

<sup>2</sup> – The pounds per hour limit for the thermal oxidizer is a combined limit for the sulfur recovery plant (e.g. all thermal oxidizer in operation at one given time). The pounds per long ton sulfur loaded limit for the thermal oxidizer is a unit specific limit for the thermal oxidizer and not a combined limit.

**4.2 BACT limits for sulfur dioxide.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall not allow the emissions of sulfur dioxide in excess of the emission limits specified in Table 4-2 for the appropriate permitted unit, operation, and process

**Table 4-2 – Sulfur Dioxide BACT Emission Limits**

Unit	Description	Sulfur Dioxide Emission Limit <sup>1</sup>
#1	Atmospheric crude charge	25 parts per million total sulfur by volume determined as

<b>Unit</b>	<b>Description</b>	<b>Sulfur Dioxide Emission Limit <sup>1</sup></b>
	heater #1	hydrogen sulfide in the refinery gas; and 1.8 pounds of sulfur dioxide per hour in the exhaust stream
<b>#2</b>	Atmospheric crude charge heater #2	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 1.8 pounds of sulfur dioxide per hour in the exhaust stream
<b>#3</b>	Vacuum charge heater #1	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.7 pounds of sulfur dioxide per hour in the exhaust stream
<b>#4</b>	Vacuum charge heater #2	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.7 pounds of sulfur dioxide per hour in the exhaust stream
<b>#5</b>	Naphtha hydrotreater charge heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.7 pounds of sulfur dioxide per hour in the exhaust stream
<b>#6</b>	Naphtha hydrotreater stripper reboiler heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.6 pounds of sulfur dioxide per hour in the exhaust stream
<b>#7</b>	Naphtha splitter reboiler heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.8 pounds of sulfur dioxide per hour in the exhaust stream
<b>#8</b>	Distillate hydrotreater feed heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.5 pounds of sulfur dioxide per hour in the exhaust stream
<b>#9</b>	Delayed coker #1A heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.8 pounds of sulfur dioxide per hour in the exhaust stream
<b>#10</b>	Delayed coker #1B heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.8 pounds of sulfur dioxide per hour in the exhaust stream
<b>#11</b>	Delayed coker #2A heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.8 pounds of sulfur dioxide per hour in the exhaust stream
<b>#12</b>	Delayed coker #2B heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.8 pounds of sulfur dioxide per hour in the exhaust stream
<b>#13</b>	Number one platformer charge and interheater #1	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 2.7 pounds of sulfur dioxide per hour in the exhaust stream
<b>#14</b>	Number one platformer interheater #2 and #3	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 1.6 pounds of sulfur dioxide per hour in the exhaust stream
<b>#15</b>	Number two platformer charge and interheater #1	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 2.7 pounds of sulfur dioxide per hour in the exhaust stream

<b>Unit</b>	<b>Description</b>	<b>Sulfur Dioxide Emission Limit <sup>1</sup></b>
		dioxide per hour in the exhaust stream
<b>#16</b>	Number two platformer interheater #2 and #3	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 1.6 pounds of sulfur dioxide per hour in the exhaust stream
<b>#17</b>	Oleflex heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 2.0 pounds of sulfur dioxide per hour in the exhaust stream
<b>#18</b>	Reformate splitter reboiler	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.5 pounds of sulfur dioxide per hour in the exhaust stream
<b>#19</b>	Number one hydrocracker fractionator feed heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 2.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#20</b>	Number two hydrocracker fractionator feed heater	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 2.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#21</b>	Number one hydrocracker heater #1A	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#22</b>	Number one hydrocracker heater #1B	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#23</b>	Number one hydrocracker heater #1C	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#24</b>	Number one hydrocracker heater #2A	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#25</b>	Number one hydrocracker heater #2B	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#26</b>	Number two hydrocracker heater #1A	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#27</b>	Number two hydrocracker heater #1B	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#28</b>	Number two hydrocracker heater #1C	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
<b>#29</b>	Number two hydrocracker heater #2A	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream

Unit	Description	Sulfur Dioxide Emission Limit <sup>1</sup>
		dioxide per hour in the exhaust stream
#30	Number two hydrocracker heater #2B	25 parts per million total sulfur by volume determined as hydrogen sulfide in the refinery gas; and 0.2 pounds of sulfur dioxide per hour in the exhaust stream
#31	Number one platformer catalyst regenerator.	0.2 pounds per hour <sup>2</sup>
#32	Number two platformer catalyst regenerator.	0.2 pounds per hour <sup>2</sup>
#33	Oleflex catalyst regenerator.	0.03 pounds per hour <sup>2</sup>
#36	Refinery flare #1	See Chapter 12.0
#37	Refinery flare #2	See Chapter 12.0
#38	Refinery flare #3	See Chapter 12.0
#39	Refinery flare #4	See Chapter 12.0
#40	Refinery flare #5	See Chapter 12.0
#42a	Sulfur recovery plant thermal oxidizer #1	114.2 pounds per hour <sup>7,8</sup> and 0.056 pounds per long ton sulfur loaded to the system <sup>7,8</sup>
#42b	Sulfur recovery plant thermal oxidizer #2	114.2 pounds per hour <sup>7,8</sup> and 0.056 pounds per long ton sulfur loaded to the system <sup>7,8</sup>
#42c	Sulfur recovery plant thermal oxidizer #3	114.2 pounds per hour <sup>7,8</sup> and 0.056 pounds per long ton sulfur loaded to the system <sup>7,8</sup>
#42d	Sulfur recovery plant thermal oxidizer #4	114.2 pounds per hour <sup>7,8</sup> and 0.056 pounds per long ton sulfur loaded to the system <sup>7,8</sup>
#42e	Sulfur recovery plant thermal oxidizer #5	114.2 pounds per hour <sup>7,8</sup> and 0.056 pounds per long ton sulfur loaded to the system <sup>7,8</sup>
#42f	Sulfur recovery plant thermal oxidizer #6	114.2 pounds per hour <sup>7,8</sup> and 0.056 pounds per long ton sulfur loaded to the system <sup>7,8</sup>
#45a	Wastewater treatment plant thermal oxidizer	25 parts per million by volume determined as hydrogen sulfide in the refinery gas
#50	Gasification flare #1	See Chapter 13.0
#51	Gasifier startup burner #1	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#52	Gasifier startup burner #2	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#53	Gasifier startup burner #3	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#54	Gasifier startup burner #4	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#55	Gasifier startup burner #5	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#56	Gasifier startup burner #6	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#57	Gasifier startup burner #7	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#58	Gasifier startup burner #8	0.006 pounds per million Btus <sup>6</sup> ; and 0.1 pounds per hour <sup>6</sup>
#60	Combined cycle gas turbine #1	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 1.0 part per million by volume sulfur in the syngas; 0.5 parts per million by volume

Unit	Description	Sulfur Dioxide Emission Limit <sup>1</sup>
		<p>sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds of sulfur dioxide per hour in the exhaust stream (all fuels)</p> <p>Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 9.0 part per million by volume sulfur in the natural gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds per hour in the exhaust stream (all fuels)</p>
#61	Combined cycle gas turbine #2	<p>Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 1.0 part per million by volume sulfur in the syngas; 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds of sulfur dioxide per hour in the exhaust stream (all fuels)</p>
		<p>Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 9.0 part per million by volume sulfur in the natural gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds per hour in the exhaust stream (all fuels)</p>
#62	Combined cycle gas turbine #3	<p>Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 1.0 part per million by volume sulfur in the syngas; 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds of sulfur dioxide per hour in the exhaust stream (all fuels)</p> <p>Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure</p>

Unit	Description	Sulfur Dioxide Emission Limit <sup>1</sup>
		swing adsorption tail gas; 9.0 part per million by volume sulfur in the natural gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds per hour in the exhaust stream (all fuels)
#63	Combined cycle gas turbine #4	<p>Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 1.0 part per million by volume sulfur in the syngas; 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds of sulfur dioxide per hour in the exhaust stream (all fuels)</p> <p>Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 9.0 part per million by volume sulfur in the natural gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds per hour in the exhaust stream (all fuels)</p>
#64	Combined cycle gas turbine #5	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 1.0 part per million by volume sulfur in the syngas; 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds of sulfur dioxide per hour in the exhaust stream (all fuels)
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 0.5 parts per million by volume sulfur <sup>3</sup> in the pressure swing adsorption tail gas; 1.0 part per million by volume sulfur <sup>4</sup> in the pressure swing adsorption tail gas; 9.0 part per million by volume sulfur in the natural gas; 15.0 parts per million by weight sulfur <sup>5</sup> in the ultra low sulfur distillate oil; and 2.3 pounds per hour in the exhaust stream (all fuels)
#65	Emergency generator #1	See Permit Condition 6.11
#66	Emergency generator #2	See Permit Condition 6.11
#67	Emergency generator #3	See Permit Condition 6.11
#68	Emergency generator #4	See Permit Condition 6.11
#69	Fire water pump #1	See Permit Condition 6.11
#70	Fire water pump #2	See Permit Condition 6.11
#175	Tank farm thermal oxidizer	25 parts per million total sulfur as hydrogen sulfide in the refinery gas

Unit	Description	Sulfur Dioxide Emission Limit <sup>1</sup>
#176	Tank farm thermal oxidizer	25 parts per million total sulfur as hydrogen sulfide in the refinery gas

<sup>1</sup> – Unless otherwise noted, compliance with the emission limit is based on a 24-hour rolling average, excluding periods of startup, shutdown, and malfunctions, and based on a 365-day rolling average, including periods of startup, shutdown, and malfunctions using a continuous emission monitoring system that meets the procedures and requirements specified in permit condition 11.1;

<sup>2</sup> – Compliance with the emission limit is based on an average of three test runs based on the performance test procedures and requirements in Chapter 10.0;

<sup>3</sup> – Compliance with the emission limit is based on a 24-hour rolling average, excluding periods of startup, shutdown, and malfunctions using a continuous emission monitoring system that meets the procedures and requirements specified in permit condition 11.1;

<sup>4</sup> – Compliance with the emission limit is based on a 365-day rolling average, including periods of startup, shutdown, and malfunctions using a continuous emission monitoring system that meets the procedures and requirements specified in permit condition 11.1;

<sup>5</sup> – Maximum sulfur content;

<sup>6</sup> – Compliance is achieved by burning pipeline-quality natural gas;

<sup>7</sup> – Compliance with the emission limit is based on a 3-hour rolling average, excluding periods of startup, shutdown, and malfunctions, and based on a 365-day rolling average, including periods of startup, shutdown, and malfunctions using a continuous emission monitoring system that meets the procedures and requirements specified in permit condition 11.1; and

<sup>8</sup> – The pounds per hour limit for the thermal oxidizer is a combined limit for the sulfur recovery plant (e.g. all thermal oxidizer in operation at one given time). The pounds per long ton sulfur loaded limit for the thermal oxidizer is a unit specific limit for the thermal oxidizer and not a combined limit.

**4.3 BACT limits for nitrogen oxide.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall not allow the emissions of nitrogen oxide in excess of the emission limits specified in Table 4-3 for the appropriate permitted unit, operation, and process.

**Table 4-3 – Nitrogen Oxide BACT Emission Limits**

Unit	Description	Nitrogen Oxide Emission Limit <sup>1</sup>
#1	Atmospheric crude charge heater #1	0.006 pounds per million Btus; and 3.2 pounds per hour
#2	Atmospheric crude charge heater #2	0.006 pounds per million Btus; and 3.2 pounds per hour
#3	Vacuum charge heater #1	0.006 pounds per million Btus; and 1.3 pounds per hour
#4	Vacuum charge heater #2	0.006 pounds per million Btus; and 1.3 pounds per hour
#5	Naphtha hydrotreater charge heater	0.006 pounds per million Btus; and 1.2 pounds per hour
#6	Naphtha hydrotreater stripper reboiler heater	0.006 pounds per million Btus; and 1.0 pounds per hour
#7	Naphtha splitter reboiler heater	0.006 pounds per million Btus; and 1.5 pounds per hour
#8	Distillate hydrotreater feed heater	0.006 pounds per million Btus; and 0.8 pounds per hour
#9	Delayed coker #1A heater	0.006 pounds per million Btus; and 1.5 pounds per hour
#10	Delayed coker #1B heater	0.006 pounds per million Btus; and 1.5 pounds per hour

<b>Unit</b>	<b>Description</b>	<b>Nitrogen Oxide Emission Limit <sup>1</sup></b>
#11	Delayed coker #2A heater	0.006 pounds per million Btus; and 1.5 pounds per hour
#12	Delayed coker #2B heater	0.006 pounds per million Btus; and 1.5 pounds per hour
#13	Number one platformer charge and interheater #1	0.006 pounds per million Btus; and 5.0 pounds per hour
#14	Number one platformer interheater #2 and #3	0.006 pounds per million Btus; and 3.0 pounds per hour
#15	Number two platformer charge and interheater #1	0.006 pounds per million Btus; and 5.0 pounds per hour
#16	Number two platformer interheater #2 and #3	0.006 pounds per million Btus; and 3.0 pounds per hour
#17	Oleflex heater	0.006 pounds per million Btus; and 3.6 pounds per hour
#18	Reformate splitter reboiler	0.006 pounds per million Btus; and 0.8 pounds per hour
#19	Number one hydrocracker fractionator feed heater	0.006 pounds per million Btus; and 4.1 pounds per hour
#20	Number two hydrocracker fractionator feed heater	0.006 pounds per million Btus; and 4.1 pounds per hour
#21	Number one hydrocracker heater #1A	0.025 pounds per million Btus; and 1.7 pounds per hour
#22	Number one hydrocracker heater #1B	0.025 pounds per million Btus; and 1.7 pounds per hour
#23	Number one hydrocracker heater #1C	0.025 pounds per million Btus; and 1.7 pounds per hour
#24	Number one hydrocracker heater #2A	0.025 pounds per million Btus; and 1.6 pounds per hour
#25	Number one hydrocracker heater #2B	0.025 pounds per million Btus; and 1.6 pounds per hour
#26	Number two hydrocracker heater #1A	0.025 pounds per million Btus; and 1.7 pounds per hour
#27	Number two hydrocracker heater #1B	0.025 pounds per million Btus; and 1.7 pounds per hour
#28	Number two hydrocracker heater #1C	0.025 pounds per million Btus; and 1.7 pounds per hour
#29	Number two hydrocracker heater #2A	0.025 pounds per million Btus; and 1.6 pounds per hour
#30	Number two hydrocracker heater #2B	0.025 pounds per million Btus; and 1.6 pounds per hour
#31	Number one platformer catalyst regenerator.	0.1 pounds per hour <sup>2</sup>
#32	Number two platformer catalyst regenerator	0.1 pounds per hour <sup>2</sup>
#33	Oleflex catalyst regenerator.	0.02 pounds per hour <sup>2</sup>
#36	Refinery flare #1.	See Chapter 12.0
#37	Refinery flare #2.	See Chapter 12.0
#38	Refinery flare #3.	See Chapter 12.0

Unit	Description	Nitrogen Oxide Emission Limit <sup>1</sup>
#39	Refinery flare #4.	See Chapter 12.0
#40	Refinery flare #5.	See Chapter 12.0
#42a	Sulfur recovery plant thermal oxidizer #1.	0.06 pounds per million Btus; and 6.1 pounds per hour
#42b	Sulfur recovery plant thermal oxidizer #2.	0.06 pounds per million Btus; and 6.1 pounds per hour
#42c	Sulfur recovery plant thermal oxidizer #3.	0.06 pounds per million Btus; and 6.1 pounds per hour
#42d	Sulfur recovery plant thermal oxidizer #4.	0.06 pounds per million Btus; and 6.1 pounds per hour
#42e	Sulfur recovery plant thermal oxidizer #5.	0.06 pounds per million Btus; and 6.1 pounds per hour
#42f	Sulfur recovery plant thermal oxidizer #6.	0.06 pounds per million Btus; and 6.1 pounds per hour
#45a	Wastewater treatment plant thermal oxidizer.	5.0 pounds per hour
#50	Gasification flare #1.	See Chapter 13.0
#51	Gasifier startup burner #1.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#52	Gasifier startup burner #2.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#53	Gasifier startup burner #3.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#54	Gasifier startup burner #4.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#55	Gasifier startup burner #5.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#56	Gasifier startup burner #6.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#57	Gasifier startup burner #7.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#58	Gasifier startup burner #8.	0.07 pounds per million Btus <sup>2</sup> ; and 1.2 pounds hour <sup>2</sup>
#60	Combined cycle gas turbine #1.	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas and/or pressure swing adsorption tail gas <sup>3</sup> ; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil <sup>3</sup> ; 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure swing adsorption tail gas and/or ultra low sulfur distillate oil <sup>4</sup> ; and 10.5 pounds per hour (all fuels)
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning pressure swing adsorption tail gas and/or

Unit	Description	Nitrogen Oxide Emission Limit <sup>1</sup>
		natural gas <sup>3</sup> ; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil <sup>3</sup> ; 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure adsorption tail gas, and/or ultra low sulfur distillate oil <sup>4</sup> ; and 10.5 pounds per hour (all fuels)
<b>#61</b>	Combined cycle gas turbine #2.	<p>Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas and/or pressure swing adsorption tail gas<sup>3</sup>; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil<sup>3</sup>; 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure swing adsorption tail gas and/or ultra low sulfur distillate oil<sup>4</sup>; and 10.5 pounds per hour (all fuels)</p> <p>Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning pressure swing adsorption tail gas and/or natural gas<sup>3</sup>; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil<sup>3</sup>; 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure adsorption tail gas, and/or ultra low sulfur distillate oil<sup>4</sup>; and 10.5 pounds per hour (all fuels)</p>
<b>#62</b>	Combined cycle gas turbine #3.	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas and/or pressure swing adsorption tail gas <sup>3</sup> ; 6.0 parts per million by volume nitrogen oxide,

Unit	Description	Nitrogen Oxide Emission Limit <sup>1</sup>
		corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil <sup>3</sup> ; 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure swing adsorption tail gas and/or ultra low sulfur distillate oil <sup>4</sup> ; and 10.5 pounds per hour (all fuels)
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning pressure swing adsorption tail gas and/or natural gas <sup>3</sup> ; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil <sup>3</sup> ; 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure adsorption tail gas, and/or ultra low sulfur distillate oil <sup>4</sup> ; and 10.5 pounds per hour (all fuels)
#63	Combined cycle gas turbine #4.	<p>Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas and/or pressure swing adsorption tail gas<sup>3</sup>; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil<sup>3</sup>; 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure swing adsorption tail gas and/or ultra low sulfur distillate oil<sup>4</sup>; and 10.5 pounds per hour (all fuels)</p> <p>Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning pressure swing adsorption tail gas and/or natural gas<sup>3</sup>; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream</p>

Unit	Description	Nitrogen Oxide Emission Limit <sup>1</sup>
		when burning ultra low sulfur distillate oil <sup>3</sup> ; 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure adsorption tail gas, and/or ultra low sulfur distillate oil <sup>4</sup> ; and 10.5 pounds per hour (all fuels)
#64	Combined cycle gas turbine #5.	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas and/or pressure swing adsorption tail gas <sup>3</sup> ; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil <sup>3</sup> ; 3.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure swing adsorption tail gas and/or ultra low sulfur distillate oil <sup>4</sup> ; and 10.5 pounds per hour (all fuels)
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning pressure swing adsorption tail gas and/or natural gas <sup>3</sup> ; 6.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning ultra low sulfur distillate oil <sup>3</sup> ; 2.0 parts per million by volume nitrogen oxide, corrected to 15% oxygen, in the exhaust stream when burning syngas, pressure adsorption tail gas, and/or ultra low sulfur distillate oil <sup>4</sup> ; and 10.5 pounds per hour (all fuels)
#65	Emergency generator #1.	See Permit Condition 6.11
#66	Emergency generator #2.	See Permit Condition 6.11
#67	Emergency generator #3.	See Permit Condition 6.11
#68	Emergency generator #4.	See Permit Condition 6.11
#69	Fire water pump #1.	See Permit Condition 6.11
#70	Fire water pump #2.	See Permit Condition 6.11
#175	Tank farm thermal oxidizer.	0.04 pounds per million Btus <sup>2</sup>
#176	Tank farm thermal oxidizer.	0.04 pounds per million Btus <sup>2</sup>

<sup>1</sup> – Unless otherwise noted, compliance with the emission limit is based on a 3-hour rolling average, excluding periods of startup, shutdown, and malfunctions, and based on a 365-day rolling average, including periods of startup, shutdown, and malfunctions using a continuous emission monitoring system that meets procedures and requirements specified in permit condition 11.1;

<sup>2</sup> – Compliance with the emission limit is based on an average of three test runs based on the performance test procedures and requirements in Chapter 10.0;

<sup>3</sup> – Compliance with the emission limit is based on a 3-hour rolling average, excluding periods of

startup, shutdown, and malfunctions, based on the continuous emission monitoring system procedures and requirements specified in permit condition 11.1; and

<sup>4</sup> – Compliance with the emission limit is based on a 365-day rolling average, including periods of startup, shutdown, and malfunctions based on the continuous emission monitoring system procedures and requirements specified in permit condition 11.1.

**4.4 BACT limits for volatile organic compounds as carbon.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall not allow the emissions of volatile organic compounds (VOCs) as carbon in excess of the emission limits specified in Table 4-4 for the appropriate permitted unit, operation, and process

**Table 4-4 – Volatile Organic Compound as Carbon BACT Emission Limits**

<b>Unit</b>	<b>Description</b>	<b>VOC as Carbon Emission Limit <sup>1</sup></b>
#1	Atmospheric crude charge heater #1	0.0015 pounds per million Btus
#2	Atmospheric crude charge heater #2	0.0015 pounds per million Btus
#3	Vacuum charge heater #1	0.0015 pounds per million Btus
#4	Vacuum charge heater #2	0.0015 pounds per million Btus
#5	Naphtha hydrotreater charge heater	0.0015 pounds per million Btus
#6	Naphtha hydrotreater stripper reboiler heater	0.0015 pounds per million Btus
#7	Naphtha splitter reboiler heater	0.0015 pounds per million Btus
#8	Distillate hydrotreater feed heater	0.0015 pounds per million Btus
#9	Delayed coker #1A heater	0.0015 pounds per million Btus
#10	Delayed coker #1B heater	0.0015 pounds per million Btus
#11	Delayed coker #2A heater	0.0015 pounds per million Btus
#12	Delayed coker #2B heater	0.0015 pounds per million Btus
#13	Number one platformer charge and interheater #1	0.0015 pounds per million Btus
#14	Number one platformer interheater #2 and #3	0.0015 pounds per million Btus
#15	Number two platformer charge and interheater #1	0.0015 pounds per million Btus
#16	Number two platformer interheater #2 and #3	0.0015 pounds per million Btus
#17	Oleflex heater	0.0015 pounds per million Btus
#18	Reformate splitter reboiler	0.0015 pounds per million Btus
#19	Number one hydrocracker fractionator feed heater	0.0015 pounds per million Btus
#20	Number two hydrocracker fractionator feed heater	0.0015 pounds per million Btus
#21	Number one hydrocracker heater #1A	0.0015 pounds per million Btus

<b>Unit</b>	<b>Description</b>	<b>VOC as Carbon Emission Limit <sup>1</sup></b>
#22	Number one hydrocracker heater #1B	0.0015 pounds per million Btus
#23	Number one hydrocracker heater #1C	0.0015 pounds per million Btus
#24	Number one hydrocracker heater #2A	0.0015 pounds per million Btus
#25	Number one hydrocracker heater #2B	0.0015 pounds per million Btus
#26	Number two hydrocracker heater #1A	0.0015 pounds per million Btus
#27	Number two hydrocracker heater #1B	0.0015 pounds per million Btus
#28	Number two hydrocracker heater #1C	0.0015 pounds per million Btus
#29	Number two hydrocracker heater #2A	0.0015 pounds per million Btus
#30	Number two hydrocracker heater #2B	0.0015 pounds per million Btus
#34	Coke drum #1 – Four steam vents	See Permit Condition 6.4
#35	Coke drum #2 – Four steam vents	See Permit Condition 6.4
#36	Refinery flare #1	See Chapter 12.0
#37	Refinery flare #2	See Chapter 12.0
#38	Refinery flare #3	See Chapter 12.0
#39	Refinery flare #4	See Chapter 12.0
#40	Refinery flare #5	See Chapter 12.0
#41	Cooling tower	See Permit Condition 14.13
#42a	Sulfur recovery plant thermal oxidizer #1	0.005 pounds per million Btus
#42b	Sulfur recovery plant thermal oxidizer #2	0.005 pounds per million Btus
#42c	Sulfur recovery plant thermal oxidizer #3	0.005 pounds per million Btus
#42d	Sulfur recovery plant thermal oxidizer #4	0.005 pounds per million Btus
#42e	Sulfur recovery plant thermal oxidizer #5	0.005 pounds per million Btus
#42f	Sulfur recovery plant thermal oxidizer #6	0.005 pounds per million Btus
#43	Railcar loading rack	1.25 pounds per million gallons of product loaded
#44	Truck loading rack	1.25 pounds per million gallons of product loaded
#45a	Wastewater treatment plant	See Permit Condition 15.4; and the least stringent between 98% destruction efficiency; or 20 parts per million by

Unit	Description	VOC as Carbon Emission Limit <sup>1</sup>
		weight
#50	Gasification flare #1	See Chapter 13.0
#51	Gasifier startup burner #1	0.14 pounds per million Btus
#52	Gasifier startup burner #2	0.14 pounds per million Btus
#53	Gasifier startup burner #3	0.14 pounds per million Btus
#54	Gasifier startup burner #4	0.14 pounds per million Btus
#55	Gasifier startup burner #5	0.14 pounds per million Btus
#56	Gasifier startup burner #6	0.14 pounds per million Btus
#57	Gasifier startup burner #7	0.14 pounds per million Btus
#58	Gasifier startup burner #8	0.14 pounds per million Btus
#60	Combined cycle gas turbine #1	0.0017 pounds of volatile organic compounds, reported as propane, per million Btus, heat input, high heating value <sup>1</sup> ; and 3.0 parts per million by volume carbon monoxide, corrected to 15% oxygen <sup>2</sup>
#61	Combined cycle gas turbine #2	0.0017 pounds of volatile organic compounds, reported as propane, per million Btus, heat input, high heating value <sup>1</sup> ; and 3.0 parts per million by volume carbon monoxide, corrected to 15% oxygen <sup>2</sup>
#62	Combined cycle gas turbine #3	0.0017 pounds of volatile organic compounds, reported as propane, per million Btus, heat input, high heating value <sup>1</sup> ; and 3.0 parts per million by volume carbon monoxide, corrected to 15% oxygen <sup>2</sup>
#63	Combined cycle gas turbine #4	0.0017 pounds of volatile organic compounds, reported as propane, per million Btus, heat input, high heating value <sup>1</sup> ; and 3.0 parts per million by volume carbon monoxide, corrected to 15% oxygen <sup>2</sup>
#64	Combined cycle gas turbine #5	0.0017 pounds of volatile organic compounds, reported as propane, per million Btus, heat input, high heating value <sup>1</sup> ; and 3.0 parts per million by volume carbon monoxide, corrected to 15% oxygen <sup>2</sup>
#65	Emergency generator #1	See Permit Condition 6.11
#66	Emergency generator #2	See Permit Condition 6.11
#67	Emergency generator #3	See Permit Condition 6.11
#68	Emergency generator #4	See Permit Condition 6.11
#69	Fire water pump #1	See Permit Condition 6.11
#70	Fire water pump #2	See Permit Condition 6.11
#175	Tank farm thermal oxidizer	The least stringent between 98% destruction efficiency; or 20 parts per million by weight
#176	Tank farm thermal oxidizer	The least stringent between 98% destruction efficiency; or 20 parts per million by weight

<sup>1</sup> – Unless otherwise specified, compliance with the emission limits is based on the average of three test runs based on the performance test procedures and requirements in Chapter 10.0; and

<sup>2</sup> – Compliance is based on a 365-day rolling average, including periods of startup, shutdown, or malfunctions using a continuous emission monitoring system that meets the procedures and

requirements specified in Chapter 11.0.

**4.5 BACT limits for carbon monoxide.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall not allow the emissions of carbon monoxide in excess of the emission limits specified in Table 4-5 for the appropriate permitted unit, operation, and process

**Table 4-5 – Carbon Monoxide BACT Emission Limits**

<b>Unit</b>	<b>Description</b>	<b>Carbon Monoxide Emission Limit <sup>1</sup></b>
#1	Atmospheric crude charge heater #1	0.007 pounds per million Btus; and 21.2 pounds per hour
#2	Atmospheric crude charge heater #2	0.007 pounds per million Btus; and 21.2 pounds per hour
#3	Vacuum charge heater #1	0.007 pounds per million Btus; and 8.6 pounds per hour
#4	Vacuum charge heater #2	0.007 pounds per million Btus; and 8.6 pounds per hour
#5	Naphtha hydrotreater charge heater	0.007 pounds per million Btus; and 8.0 pounds per hour
#6	Naphtha hydrotreater stripper reboiler heater	0.007 pounds per million Btus; and 6.8 pounds per hour
#7	Naphtha splitter reboiler heater	0.007 pounds per million Btus; and 9.9 pounds per hour
#8	Distillate hydrotreater feed heater	0.007 pounds per million Btus; and 5.6 pounds per hour
#9	Delayed coker #1A heater	0.007 pounds per million Btus; and 9.7 pounds per hour
#10	Delayed coker #1B heater	0.007 pounds per million Btus; and 9.7 pounds per hour
#11	Delayed coker #2A heater	0.007 pounds per million Btus; and 9.7 pounds per hour
#12	Delayed coker #2B heater	0.007 pounds per million Btus; and 9.7 pounds per hour
#13	Number one platformer charge and interheater #1	0.007 pounds per million Btus; and 33.0 pounds per hour
#14	Number one platformer interheater #2 and #3	0.007 pounds per million Btus; and 19.7 pounds per hour
#15	Number two platformer charge and interheater #1	0.007 pounds per million Btus; and 33.0 pounds per hour
#16	Number two platformer interheater #2 and #3	0.007 pounds per million Btus; and 19.7 pounds per hour
#17	Oleflex heater	0.007 pounds per million Btus; and 24.2 pounds per hour
#18	Reformate splitter reboiler	0.007 pounds per million Btus; and 5.5 pounds per hour
#19	Number one hydrocracker fractionator feed heater	0.007 pounds per million Btus; and 27.0 pounds per hour
#20	Number two hydrocracker fractionator feed heater	0.007 pounds per million Btus; and 27.0 pounds per hour
#21	Number one hydrocracker heater #1A	0.007 pounds per million Btus; and 2.7 pounds per hour
#22	Number one hydrocracker heater #1B	0.007 pounds per million Btus; and 2.7 pounds per hour

<b>Unit</b>	<b>Description</b>	<b>Carbon Monoxide Emission Limit <sup>1</sup></b>
<b>#23</b>	Number one hydrocracker heater #1C	0.007 pounds per million Btus; and 2.7 pounds per hour
<b>#24</b>	Number one hydrocracker heater #2A	0.007 pounds per million Btus; and 2.7 pounds per hour
<b>#25</b>	Number one hydrocracker heater #2B	0.007 pounds per million Btus; and 2.7 pounds per hour
<b>#26</b>	Number two hydrocracker heater #1A	0.007 pounds per million Btus; and 2.6 pounds per hour
<b>#27</b>	Number two hydrocracker heater #1B	0.007 pounds per million Btus; and 2.6 pounds per hour
<b>#28</b>	Number two hydrocracker heater #1C	0.007 pounds per million Btus; and 2.6 pounds per hour
<b>#29</b>	Number two hydrocracker heater #2A	0.007 pounds per million Btus; and 2.6 pounds per hour
<b>#30</b>	Number two hydrocracker heater #2B	0.007 pounds per million Btus; and 2.6 pounds per hour
<b>#31</b>	Number One Platformer Catalyst Regenerator	0.5 pounds per hour <sup>2</sup>
<b>#32</b>	Number Two Platformer Catalyst Regenerator	0.5 pounds per hour <sup>2</sup>
<b>#33</b>	Oleflex Catalyst Regenerator	0.1 pounds per hour <sup>2</sup>
<b>#34</b>	Coke Drum #1 – Four Steam Vents	See Permit Condition 6.4
<b>#35</b>	Coke Drum #2 – Four Steam Vents	See Permit Condition 6.4
<b>#36</b>	Refinery Flare #1	See Chapter 12.0
<b>#37</b>	Refinery Flare #2	See Chapter 12.0
<b>#38</b>	Refinery Flare #3	See Chapter 12.0
<b>#39</b>	Refinery Flare #4	See Chapter 12.0
<b>#40</b>	Refinery Flare #5	See Chapter 12.0
<b>#42a</b>	Sulfur Recovery Plant Thermal Oxidizer #1	0.08 pounds per million Btus; and 8.1 pounds per hour <sup>3</sup>
<b>#42b</b>	Sulfur Recovery Plant Thermal Oxidizer #2	0.08 pounds per million Btus; and 8.1 pounds per hour <sup>3</sup>
<b>#42c</b>	Sulfur Recovery Plant Thermal Oxidizer #3	0.08 pounds per million Btus; and 8.1 pounds per hour <sup>3</sup>
<b>#42d</b>	Sulfur Recovery Plant Thermal Oxidizer #4	0.08 pounds per million Btus; and 8.1 pounds per hour <sup>3</sup>
<b>#42e</b>	Sulfur Recovery Plant Thermal Oxidizer #5	0.08 pounds per million Btus; and 8.1 pounds per hour <sup>3</sup>
<b>#42f</b>	Sulfur Recovery Plant Thermal Oxidizer #6	0.08 pounds per million Btus; and 8.1 pounds per hour <sup>3</sup>

Unit	Description	Carbon Monoxide Emission Limit <sup>1</sup>
#45	Wastewater Treatment Plant Thermal Oxidizer	0.08 pounds per million Btus <sup>2</sup> ; and 0.08 pounds per hour <sup>2</sup>
#50	Gasification Flare #1	See Chapter 13.0
#51	Gasifier startup burner #1	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#52	Gasifier startup burner #2	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#53	Gasifier startup burner #3	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#54	Gasifier startup burner #4	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#55	Gasifier startup burner #5	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#56	Gasifier startup burner #6	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#57	Gasifier startup burner #7	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#58	Gasifier startup burner #8	0.37 pounds per million Btus <sup>2</sup> ; and 6.7 pounds per hour <sup>2</sup>
#59	Power Island Acid Gas Removal System	20 parts per million by volume; and 25.1 pounds per hour
#60	Combined Cycle Gas Turbine #1	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
#61	Combined Cycle Gas Turbine #2	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
#62	Combined Cycle Gas Turbine #3	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
#63	Combined Cycle Gas Turbine #4	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen;

Unit	Description	Carbon Monoxide Emission Limit <sup>1</sup>
		and 11.1 pounds per hour <sup>3</sup>
#64	Combined Cycle Gas Turbine #5	Burning a combination of syngas, pressure swing adsorption tail gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
		Burning a combination of pressure swing adsorption tail gas, natural gas, and ultra low sulfur distillate oil: 3.0 parts per million by volume in the exhaust gas corrected to 15% oxygen; and 11.1 pounds per hour <sup>3</sup>
#65	Emergency Generator #1	See Permit Condition 6.11
#66	Emergency Generator #2	See Permit Condition 6.11
#67	Emergency Generator #3	See Permit Condition 6.11
#68	Emergency Generator #4	See Permit Condition 6.11
#69	Fire Water Pump #1	See Permit Condition 6.11
#70	Fire Water Pump #2	See Permit Condition 6.11
#175	Tank Farm Thermal Oxidizer	0.08 pounds per million Btus <sup>2</sup>
#176	Tank Farm Thermal Oxidizer	0.08 pounds per million Btus <sup>2</sup>

<sup>1</sup> – Unless otherwise noted, compliance with the emission limit is based on a 24-hour rolling average, excluding periods of startup, shutdown, and malfunctions, and based on a 365-day rolling average, including periods of startup, shutdown, and malfunctions using a continuous emission monitoring system that meets the procedures and requirements specified in permit condition 11.3;

<sup>2</sup> – Compliance with the emission limit is based on an average of three test runs based on the performance test procedures and requirements in Chapter 10.0; and

<sup>3</sup> – Unless otherwise noted, compliance with the emission limit is based on a 3-hour rolling average, excluding periods of startup, shutdown, and malfunctions, and based on a 365-day rolling average, including periods of startup, shutdown, and malfunctions using a continuous emission monitoring system that meets the procedures and requirements specified in permit condition 11.3;

**4.6 BACT limit for sulfuric acid mist.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall not allow the emissions of sulfuric acid mist in excess of the emission limits specified in Table 4-6 for the appropriate permitted unit, operation, and process.

**Table 4-6 – Sulfuric Acid Mist BACT Emission Limit**

Unit	Description	Sulfuric Acid Mist Emission Limit
#1	Atmospheric Crude Charge Heater #1	See Permit Condition 4.2
#2	Atmospheric Crude Charge Heater #2	See Permit Condition 4.2
#3	Vacuum Charge Heater #1	See Permit Condition 4.2
#4	Vacuum Charge Heater #2	See Permit Condition 4.2
#5	Naphtha Hydrotreater Charge Heater	See Permit Condition 4.2
#6	Naphtha Hydrotreater Stripper Reboiler Heater	See Permit Condition 4.2

<b>Unit</b>	<b>Description</b>	<b>Sulfuric Acid Mist Emission Limit</b>
#7	Naphtha Splitter Reboiler Heater	See Permit Condition 4.2
#8	Distillate Hydrotreater Feed Heater	See Permit Condition 4.2
#9	Delayed Coker #1A Heater	See Permit Condition 4.2
#10	Delayed Coker #1B Heater	See Permit Condition 4.2
#11	Delayed Coker #2A Heater	See Permit Condition 4.2
#12	Delayed Coker #2B Heater	See Permit Condition 4.2
#13	Number One Platformer Charge and Interheater #1	See Permit Condition 4.2
#14	Number One Platformer Interheater #2 and Interheater #3	See Permit Condition 4.2
#15	Number Two Platformer Charge and Interheater #1	See Permit Condition 4.2
#16	Number Two Platformer Interheater #2 and Interheater #3	See Permit Condition 4.2
#17	Oleflex Heater	See Permit Condition 4.2
#18	Reformate Splitter Reboiler	See Permit Condition 4.2
#19	Number One Hydrocracker Fractionator Feed Heater	See Permit Condition 4.2
#20	Number Two Hydrocracker Fractionator Feed Heater	See Permit Condition 4.2
#21	Number One Hydrocracker Heater #1A	See Permit Condition 4.2
#22	Number One Hydrocracker Heater #1B	See Permit Condition 4.2
#23	Number One Hydrocracker Heater #1C	See Permit Condition 4.2
#24	Number One Hydrocracker Heater #2A	See Permit Condition 4.2
#25	Number One Hydrocracker Heater #2B	See Permit Condition 4.2
#26	Number Two Hydrocracker Heater #1A	See Permit Condition 4.2
#27	Number Two Hydrocracker Heater #1B	See Permit Condition 4.2
#28	Number Two Hydrocracker Heater #1C	See Permit Condition 4.2
#29	Number Two Hydrocracker Heater #2A	See Permit Condition 4.2
#30	Number Two Hydrocracker Heater #2B	See Permit Condition 4.2
#36	Refinery Flare #1	See Chapter 12.0
#37	Refinery Flare #2	See Chapter 12.0
#38	Refinery Flare #3	See Chapter 12.0
#39	Refinery Flare #4	See Chapter 12.0
#40	Refinery Flare #5	See Chapter 12.0
#42a	Sulfur Recovery Plant Thermal Oxidizer #1	See Permit Condition 4.2
#42b	Sulfur Recovery Plant Thermal Oxidizer #2	See Permit Condition 4.2
#42c	Sulfur Recovery Plant Thermal Oxidizer #3	See Permit Condition 4.2
#42d	Sulfur Recovery Plant Thermal Oxidizer #4	See Permit Condition 4.2
#42e	Sulfur Recovery Plant Thermal Oxidizer #5	See Permit Condition 4.2
#42f	Sulfur Recovery Plant Thermal Oxidizer #6	See Permit Condition 4.2
#50	Gasification Flare #1.	See Chapter 13.0
#51	Gasifier startup burner #1	See Permit Condition 4.2

<b>Unit</b>	<b>Description</b>	<b>Sulfuric Acid Mist Emission Limit</b>
#52	Gasifier startup burner #2	See Permit Condition 4.2
#53	Gasifier startup burner #3	See Permit Condition 4.2
#54	Gasifier startup burner #4	See Permit Condition 4.2
#55	Gasifier startup burner #5	See Permit Condition 4.2
#56	Gasifier startup burner #6	See Permit Condition 4.2
#57	Gasifier startup burner #7	See Permit Condition 4.2
#58	Gasifier startup burner #8	See Permit Condition 4.2
#60	Combined Cycle Gas Turbine #1	See Permit Condition 4.2
#61	Combined Cycle Gas Turbine #2	See Permit Condition 4.2
#62	Combined Cycle Gas Turbine #3	See Permit Condition 4.2
#63	Combined Cycle Gas Turbine #4	See Permit Condition 4.2
#64	Combined Cycle Gas Turbine #5	See Permit Condition 4.2

**4.7 BACT limit for hydrogen sulfide.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall not allow the emissions of hydrogen sulfide in excess of the emission limits specified in Table 4-7 for the appropriate permitted unit, operation, and process.

**Table 4-7 – Hydrogen Sulfide BACT Emission Limit**

<b>Unit</b>	<b>Description</b>	<b>Hydrogen Sulfide Emission Limit</b>
#36	Refinery Flare #1.	See Chapter 12.0
#37	Refinery Flare #2.	See Chapter 12.0
#38	Refinery Flare #3.	See Chapter 12.0
#39	Refinery Flare #4.	See Chapter 12.0
#40	Refinery Flare #5.	See Chapter 12.0
#42a	Sulfur Recovery Plant Thermal Oxidizer #1	0.3 pounds per hour and 0.00015 pounds per long ton sulfur loaded to the system <sup>1,2</sup>
#42b	Sulfur Recovery Plant Thermal Oxidizer #2	0.3 pounds per hour and 0.00015 pounds per long ton sulfur loaded to the system <sup>1,2</sup>
#42c	Sulfur Recovery Plant Thermal Oxidizer #3	0.3 pounds per hour and 0.00015 pounds per long ton sulfur loaded to the system <sup>1,2</sup>
#42d	Sulfur Recovery Plant Thermal Oxidizer #4	0.3 pounds per hour and 0.00015 pounds per long ton sulfur loaded to the system <sup>1,2</sup>
#42e	Sulfur Recovery Plant Thermal Oxidizer #5	0.3 pounds per hour and 0.00015 pounds per long ton sulfur loaded to the system <sup>1,2</sup>

<b>Unit</b>	<b>Description</b>	<b>Hydrogen Sulfide Emission Limit</b>
<b>#42f</b>	Sulfur Recovery Plant Thermal Oxidizer #6	0.3 pounds per hour and 0.00015 pounds per long ton sulfur loaded to the system <sup>1,2</sup>
<b>#50</b>	Gasification Flare #1.	See Chapter 13.0
<b>#59</b>	Power island acid gas removal system	3.0 parts per million by volume; and 4.2 pounds per hour <sup>3</sup>

<sup>1</sup> – Compliance with the emission limit is based on an average of three test runs based on the performance test procedures and requirements in Chapter 10.0;

<sup>2</sup> – The pounds per hour limit for the thermal oxidizer is a combined limit for the sulfur recovery plant (e.g. all thermal oxidizer in operation at one given time). The pounds per long ton sulfur loaded limit for the thermal oxidizer is unit specific limit for the thermal oxidizer and not a combined limit; and

<sup>3</sup> – Compliance with the emission limit is based on a 24-hour rolling average, excluding periods of startup, shutdown, and malfunctions using a continuous emission monitoring system meeting the procedures and requirements specified in permit condition 11.1.

**4.8 Compliance with BACT limits during startup, shutdown, and malfunction.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall utilize good work and maintenance practices and manufacturers’ recommendations to minimize emissions during, and the frequency and duration of, startup, shutdown, and malfunction events for those units and pollutants that are not using a continuous emission monitoring system to demonstrate compliance. The owner or operator shall develop and implement a startup, shutdown, and malfunction plan for those units and pollutants that are not using a continuous emission monitoring system to demonstrate compliance. The startup, shutdown, and malfunction plan shall describe, in detail, procedures for operating and maintaining those units and pollutants that are not using a continuous emission monitoring system to demonstrate compliance during periods of startup, shutdown, and malfunction; a program of corrective action for malfunctions; and recordkeeping requirements identifying that the procedures and corrective actions were completed. The startup, shutdown, and malfunction plan shall be submitted to and approved by the Secretary at least 90 days prior to the initial startup of the petroleum refinery.

## **5.0 Operational Limits**

**5.1 Refinery crude oil.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not refine more than 400,000 barrels of crude oil per day. Compliance shall be based on a 365-day rolling average.

**5.2 IGCC system.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall produce the hydrogen, electricity, and/or steam from the IGCC system for on-site use. The owner or operator shall not sell the hydrogen, electricity, and/or steam to an outside entity.

**5.3 Cooling tower.** In accordance with ARSD 74:36:09:02, as referenced to ARSD

74:36:05:16.01(8), the owner or operator shall install, operate, and maintain a 0.0005 percent efficient drift eliminators on Unit #41.

**5.4 Paved roads and parking lots.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall pave all haul roads and parking lots within the Hyperion Energy Center's property boundaries at this location. The roads shall be paved within one year after initial startup of the petroleum refinery.

**5.5 Sulfur recovery plant.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not operate more than four of the six sulfur recovery plant lines and associated thermal oxidizers (Unit #42a through #42f) at any given time. The owner or operator is allowed to overlap the operations of the sulfur recovery plant lines and associated thermal oxidizers during startup and shutdown of the units.

**5.6 Combined cycle combustion turbines.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not operate more than four of the five combined cycle combustion turbine system (Unit #60 through #64) at any given time. The owner or operator is allowed to overlap the operations of the combined cycle combustion turbines during startup and shutdown of the units. The owner or operator shall not operate the five combined cycle combustion turbine system (Unit #60 through #64) greater than 500 hours per 12-month rolling period on ultra low sulfur distillate oil.

**5.7 Gasifier startup burner.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not operate more than six of the eight gasifier startup burners (Unit #51 through #58) at any given time. The owner or operator is allowed to overlap the operations of the gasifier startup burners during startup and shutdown of the units.

**5.8 Diesel generators and fire pumps.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall purchase a 2008 model or newer generator and fire pump. The owner or operator shall limit the operations of each generator and fire pump to less than 300 hours per 12-month rolling period. Operations during an emergency do not count against the hour per 12-month rolling period.

**5.9 Operation, maintenance, and monitoring plan.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall develop, maintain, and implement a written Operation, Maintenance, and Monitoring plan. The Operation, Maintenance, and Monitoring plan shall be submitted to the Secretary within 60 days prior to initial startup of the petroleum refinery. Any subsequent changes to the plan must be submitted to the Secretary for review and approval. Pending approval by the Secretary of an initial or amended plan, the owner or operator must comply with the provisions of the submitted plan. Each plan must contain the following information:

1. Process and control device parameters to be monitored to determine compliance, along with established operating limits or ranges, as applicable, for each emission unit;
2. A monitoring schedule for each emission unit;
3. Procedures for the proper operation and maintenance of each emission unit and each air

pollution control device used to meet the applicable emission limits and operating limits in this permit;

4. Procedures for the proper installation, operation, and maintenance of monitoring devices or systems used to determine compliance include:
  - a. Calibration and certification of accuracy of each monitoring device;
  - b. Performance and equipment specifications for the sample interface, parametric signal analyzer, and the data collection and reduction systems; and
  - c. Ongoing operation and maintenance procedures in accordance with the following requirements:
    - i. Maintain and operate each continuous monitoring system in a manner consistent with good air pollution control practices;
    - ii. Maintain and operate each continuous monitoring system as specified in this permit;
    - iii. Maintain the necessary parts for routine repairs of each continuous monitoring system;
    - iv. Install, operate, and the data verified prior to or in conjunction with conducting performance tests. The verification shall, at a minimum, include completion of the manufacturer's written specifications or recommendations for installation, operation, and calibration of the system; and
    - v. Except for system breakdowns, out-of-control periods, repairs, maintenance periods, calibration checks, and zero (low-level) and high-level calibration drift adjustments, all continuous monitoring systems shall be in continuous operation.
5. Procedures for monitoring process and control device parameters.
6. Corrective actions to be taken when process or operating parameters or add-on control device parameters deviate from the operating limits specified in this permit, including:
  - a. Procedures to determine and record the cause of a deviation or excursion, and the time the deviation or excursion began and ended; and
  - b. Procedures for recording the corrective action taken, the time corrective action was initiated, and the time and date the corrective action was completed; and
7. A maintenance schedule for each emission unit and control device that is consistent with the manufacturer's instructions and recommendations for routine and long-term maintenance.

**5.10 Startup, shutdown, and malfunction plan.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall develop a written Startup, Shutdown, and Malfunction plan that describes in detail the procedures for operating and maintaining the units identified in Table 1-1 during periods of startup, shutdown, and malfunctions. In addition, the plan shall identify a program of corrective action for a malfunction of the process, air pollution control, and monitoring equipment used to comply with the relevant standard. The Startup, Shutdown, and Malfunction plan does not need to address any scenario that would not cause an exceedance of an applicable emission limit. The Startup, Shutdown, and Malfunction plan shall:

1. Ensure that at all times the owner or operator operates and maintains the units identified in Table 1-1, and the associated air pollution control and monitoring equipment, in a manner which satisfies the general duty to minimize emissions;
2. Ensure that the owner or operator is prepared to correct malfunctions as soon as practicable after their occurrence in order to minimize excess emissions; and

3. Reduce the reporting burden associated with periods of startup, shutdown, and malfunction (including corrective action taken to restore malfunctioning process and air pollution control equipment to its normal or usual manner of operation).

To satisfy this requirement, the owner or operator may use its standard operating procedures manual, an Occupational Safety and Health Administration (OSHA) plan, or another plan, provided the alternative plans meet all the requirements of this permit condition and are made available for inspection or submitted when requested by the Secretary.

The owner or operator shall make revisions to the Startup, Shutdown, and Malfunction plan, if it is determined that the plan does not address a startup, shutdown, or malfunction event that has occurred; fails to provide for the operation of a unit (including associated air pollution control and monitoring equipment) during a startup, shutdown, or malfunction event in a manner consistent with the general duty to minimize emissions; or does not provide adequate procedures for correcting malfunctioning process and/or air pollution control and monitoring equipment as quickly as practicable. Revisions to the Startup, Shutdown, and Malfunction plan are not considered a permit revision.

**5.11 Tank Farm Operational Restriction** . In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall operate the storage tanks in the tank farm under one of the two operating scenarios:

1. The volatile organic compound emissions from Units # 71 through #174 shall be routed to one of the two thermal oxidizers identified as Unit #175 and/or #176; or
2. The volatile organic compound emissions from Units #71 through #96, Units #111 through #133, Unit #140, Unit #146, Units #149 through #162, and Units #166 through #171 shall be routed to one of the two thermal oxidizers identified as Unit #175 and/or #176. The liquid stored in Units #97 through 110, Units #134 through #139, Units #141 through #145, Unit #147, Unit #148, Unit #164, Unit #165, Unit #172, and Unit #173 shall be equipped with an internal floating roof and shall not contain a liquid with a maximum true vapor pressure greater than 0.3 pounds per square inch. Unit #163 shall only store amine (lean) liquid.

## **6.0 New Source Performance Standards**

**6.1 New source performance standard – Subpart A.** In accordance with ARSD 74:36:07:01, as referenced to 40 CFR Part 60, Subpart A, the owner or operator shall comply with all applicable notification, recordkeeping, performance testing, compliance with standards and maintenance requirements, monitoring, general control device requirements, general notice and reporting requirements, and other general provisions for the new source performance standards.

**6.2 New source performance standard – Subpart Da.** In accordance with ARSD 74:36:07:03, as referenced to 40 CFR Part 60, Subpart Da, the owner or operator shall comply with all applicable standards, compliance provisions, monitoring, compliance determination

methods and procedures, reporting, and recordkeeping requirements in the standards of performance for electric utility steam generating units for which construction is commenced after September 18, 1978. This permit condition is applicable to Unit #60 through #64 under option one. The permit condition is applicable to Unit #60 through #64 under option two if the PSA tail gas provides 50 percent or more of the fuel source to Unit #60 through #64.

**6.3 New source performance standard – Subpart J.** In accordance with ARSD 74:36:07:46, as referenced to 40 CFR Part 60 Subpart J, the owner or operator shall comply with all applicable standards, monitoring, performance testing, compliance procedures, reporting, and recordkeeping requirements in the standards of performance for petroleum refineries. This permit condition is applicable to Unit #1 through #30 and #42a through #42f.

**6.4 New source performance standard – Subpart Ja.** In accordance with 40 CFR Part 60, Subpart Ja, the owner or operator shall comply with all applicable emission limitations, work practice standards, performance tests, monitoring of emissions and operations, reporting, and recordkeeping requirements in the standards of performance for petroleum refineries that commenced construction, reconstruction, or modification after May 14, 2007. This permit condition is applicable to Unit #1 through #40, #42a through #42f, and #45a.

**6.5 New source performance standard – Subpart Kb.** In accordance with ARSD 74:36:07:14, as referenced to 40 CFR Part 60, Subpart Kb, the owner or operator shall comply with all applicable standards, testing, alternative emission limits, reporting, recordkeeping, monitoring requirements in the standards of performance for volatile organic liquid storage vessels (including petroleum liquid storage vessels) for which construction, reconstruction or modification commences after July 23, 1984. This permit condition is applicable to Unit #160, #161, and #162.

**6.6 New source performance standard – Subpart Y.** In accordance with ARSD 74:36:07:16, as referenced to 40 CFR Part 60, Subpart Y, the owner or operator shall comply with all applicable standards, monitoring, and testing requirements in the standards of performance for coal preparation plants. This permit condition is applicable to Unit #47.

**6.7 New source performance standard – Subpart UU.** In accordance with ARSD 74:36:07:71, as referenced to 40 CFR Part 60, Subpart UU, the owner or operator shall comply with all applicable standards, monitoring, and testing requirements in the standards of performance for asphalt processing and asphalt roofing manufacture. This permit condition is applicable to Unit #154 and #155.

**6.8 New source performance standard – Subpart NNN.** In accordance with ARSD 74:36:07:26, as referenced to 40 CFR Part 60, Subpart NNN, the owner or operator shall comply with all applicable standards, monitoring, testing, reporting, and recordkeeping requirements in the standards of performance for volatile organic compound emissions from synthetic organic chemical manufacturing industry (SOCMI) distillation operations. This permit condition is applicable to processes that produce refinery gas or burn refinery gas.

**6.9 New source performance standard – Subpart OOO.** In accordance with ARSD

74:36:07:27, as referenced to 40 CFR Part 60, Subpart OOO, the owner or operator shall comply with all applicable standards and limitations, reporting, monitoring, recordkeeping, testing, and notification requirements in the standards of performance for nonmetallic mineral processing plants. This permit condition is applicable to Unit #48 the fugitive emissions from the flux building.

**6.10 New source performance standard – Subpart RRR.** In accordance with ARSD 74:36:07:32, as referenced to 40 CFR Part 60, Subpart RRR, the owner or operator shall comply with all applicable standards, monitoring, testing, reporting, and recordkeeping requirements in the standards of performance for volatile organic compound emissions from synthetic organic chemical manufacturing industry (SOCMI) reactor processes. This permit condition is applicable to processes that produce refinery gas or burn refinery gas.

**6.11 New source performance standard – Subpart IIII.** In accordance with ARSD 74:36:07:88, as referenced to 40 CFR Part 60, Subpart IIII, the owner or operator shall comply with all applicable standards, fuel requirements, monitoring, compliance, testing, notification, reporting, and recordkeeping requirements in the standards of performance for stationary compression ignition internal combustion engines. This permit condition is applicable to Unit #65 through #70.

**6.12 New source performance standard – Subpart KKKK.** In accordance with ARSD 74:36:07:89, as referenced to 40 CFR Part 60, Subpart KKKK, the owner or operator shall comply with all applicable limits, compliance, monitoring, reporting, and testing requirements in the standards of performance for stationary combustion turbines. This permit condition is applicable to Unit #60 through #64. The permit condition is applicable to Unit #60 through #64 under option two if the PSA tail gas provides less than 50 percent of the fuel source to Unit #60 through #64.

## **7.0 National Emission Standards for Hazardous Air Pollutants**

**7.1 National emission standards for hazardous air pollutants – Subpart A.** In accordance with ARSD 74:36:08:01, as referenced to 40 CFR Part 61, Subpart A, the owner or operator shall comply with all applicable notification, reporting, compliance, testing, and monitoring requirements, and other general provisions for the national emission standards for hazardous air pollutants.

**7.2 National emission standards for hazardous air pollutants – Subpart FF.** In accordance with 40 CFR Part 61, Subpart FF, the owner or operator shall comply with all applicable standards, alternative limits, monitoring, testing, reporting, and recordkeeping requirements in the national emission standards for benzene waste operations.

## **8.0 Maximum Achievable Control Technology Standard**

**8.1 Maximum Achievable Control Technology Standard – Subpart A.** In accordance with ARSD 74:36:08:03, as referenced to 40 CFR Part 63 Subpart A, the owner or operator shall comply with all applicable notification, compliance, maintenance, testing, monitoring, reporting, recordkeeping, and control device requirements, and other general provisions for maximum achievable control technology standards.

**8.2 Maximum Achievable Control Technology Standard – Subpart B.** In accordance with ARSD 74:36:08:03.01, as referenced to 40 CFR Part 63, Subpart B, the owner or operator shall comply with all applicable standards and limits in Table 8-1.

*Table 8-1 – Case-by-Case MACT Limits*

<b>Unit</b>	<b>Description</b>	<b>Organic and Metal Hazardous Air Pollutants</b>	<b>In-organic Hazardous Air Pollutants (Hydrogen Chloride) <sup>1</sup></b>
#1	Atmospheric crude charge heater #1	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#2	Atmospheric crude charge heater #2	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#3	Vacuum charge heater #1	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#4	Vacuum charge heater #2	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#5	Naphtha hydrotreater charge heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#6	Naphtha hydrotreater stripper reboiler heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#7	Naphtha splitter reboiler heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#8	Distillate hydrotreater feed heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#9	Delayed coker #1A heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#10	Delayed coker #1B heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#11	Delayed coker #2A heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#12	Delayed coker #2B heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#13	Number one platformer charge and interheater #1	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#14	Number one platformer interheater #2 and #3	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#15	Number two platformer charge and interheater #1	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus

<b>Unit</b>	<b>Description</b>	<b>Organic and Metal Hazardous Air Pollutants</b>	<b>In-organic Hazardous Air Pollutants (Hydrogen Chloride) <sup>1</sup></b>
#16	Number two platformer interheater #2 and #3	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#17	Oleflex heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#18	Reformate splitter reboiler	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#19	Number one hydrocracker fractionator feed heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#20	Number two hydrocracker fractionator feed heater	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#21	Number one hydrocracker heater #1A	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#22	Number one hydrocracker heater #1B	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#23	Number one hydrocracker heater #1C	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#24	Number one hydrocracker heater #2A	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#25	Number one hydrocracker heater #2B	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#26	Number two hydrocracker heater #1A	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#27	Number two hydrocracker heater #1B	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#28	Number two hydrocracker heater #1C	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#29	Number two hydrocracker heater #2A	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus
#30	Number two hydrocracker heater #2B	Permit Conditions 4.1 and 4.5	0.0012 pounds per million Btus

<sup>1</sup> – Compliance with the hydrogen chloride limit shall be based on the average of three one-hour test runs based on the performance test procedures and requirements in Chapter 10.0.

**8.3 Maximum Achievable Control Technology Standard – Subpart H.** In accordance with ARSD 74:36:08:07, as referenced to 40 CFR Part 63, Subpart H, the owner or operator shall comply with all applicable standards, quality improvement programs, alternative means of emission limitation, testing, reporting, and recordkeeping requirements in the maximum achievable control technology standards for organic hazardous air pollutants for equipment leaks from the petroleum refinery.

**8.4 Maximum Achievable Control Technology Standard – Subpart Q.** In accordance

with ARSD 74:36:08:11, as referenced to 40 CFR Part 63, Subpart Q, the owner or operator shall comply with all applicable standards, compliance, notification, reporting, recordkeeping, requirements in the maximum achievable control technology standards for industrial process cooling towers.

**8.5 Maximum Achievable Control Technology Standard – Subpart CC.** In accordance with ARSD 74:36:08:50, as referenced to 40 CFR Part 63, Subpart CC, the owner or operator shall comply with all applicable standards, provisions, monitoring, testing, reporting, and recordkeeping requirements in the national emission standards for hazardous air pollutants from petroleum refineries.

**8.6 Maximum Achievable Control Technology Standard – Subpart UUU.** In accordance with ARSD 74:36:08:67, as referenced to 40 CFR Part 63, Subpart UUU, the owner or operator shall comply with all applicable limitations, work practice standards, testing, monitoring, reporting, and recordkeeping requirements in the national emission standards for hazardous air pollutants from petroleum refineries – catalytic cracking, catalytic reforming, and sulfur recovery units.

## **9.0 Other Applicable Limits**

**9.1 State opacity limit.** In accordance with ARSD 74:36:12:01, the owner or operator may not discharge into the ambient air an air contaminant of a density equal to or greater than that designated as 20 percent opacity from any permitted unit, operation, or process listed in Table 1-1. This provision does not apply when the presence of uncombined water is the only reason for failure to meet the requirement. An exceedance of the opacity limit is not considered a violation during brief periods of soot blowing, startup, shutdown, or malfunction. Malfunction means any sudden and unavoidable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. A failure caused entirely or in part by poor maintenance, careless operation, preventable equipment breakdown, or any other cause within the control of the owner or operator of the source is not a malfunction and is considered a violation.

## **10.0 PERFORMANCE TESTS**

**10.1 Performance test may be required.** In accordance with ARSD 74:36:11:02, the Secretary may request a performance test. A performance test shall be conducted while operating the unit at or greater than 90 percent of its maximum design capacity, unless otherwise specified by the Secretary. A performance test that is conducted while operating the unit less than 90 percent of its maximum design capacity will result in the operation being limited to the percent achieved during the performance test. The Secretary has the discretion to extend the deadline for completion of the performance test required by the Secretary, if circumstances reasonably warrant but will not extend the deadline past a federally required performance test deadline.

**10.2 Test methods and procedures.** The owner or operator shall conduct the performance test in accordance with 40 CFR Part 60, Appendix A; 40 CFR Part 63, Appendix A; and 40 CFR Part 51, Appendix M. The Secretary may approve an alternative method if a performance test specified in 40 CFR Part 60, Appendix A; 40 CFR Part 63, Appendix A; and 40 CFR Part 51, Appendix M is not federally applicable or federally required.

**10.3 Representative performance test.** In accordance with ARSD 74:36:07:01, as referenced to 40 CFR §60.8(c), performance tests shall be conducted under such conditions as the Secretary shall specify to the owner or operator based on the representative performance of the unit being tested. The owner or operator shall make available to the Secretary such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test.

**10.4 Submittal of test plan.** In accordance with ARSD 74:36:11:01, the owner or operator shall submit the proposed testing procedures to the Secretary at least 30 days prior to any performance test. The Secretary will notify the owner or operator if the proposed test procedures are approved or denied. If the proposed test procedures are denied, the Secretary will provide written notification that outlines what needs to be completed for approval.

**10.5 Notification of test.** In accordance with ARSD 74:36:11:03, the owner or operator shall notify the Secretary at least 10 days prior to the start of a performance test to arrange for an agreeable test date when the Secretary may observe the test. The Secretary may extend the deadline for the performance test in order to accommodate schedules in arranging an agreeable test date.

**10.6 Performance test report.** In accordance with ARSD 74:36:05:16.01(9), the owner or operator shall submit a performance test report to the Secretary within 60 days after completing the performance test or by a date designated by the Secretary. The performance test report shall contain the following information:

1. A brief description of the process and the air pollution control system being tested;
2. Sampling location description(s);
3. A description of sampling and analytical procedures and any modifications to standard procedures;
4. Test results;
5. Quality assurance procedures and results;
6. Records of operating conditions during the test, preparation of standards, and calibration procedures;
7. Raw data sheets for field sampling and field and laboratory analyses;
8. Documentation of calculations;
9. All data recorded and used to establish parameters for compliance monitoring; and
10. Any other information required by the test method.

**10.7 Initial particulate performance tests.** In accordance with ARSD 74:36:11:02, the owner or operator shall conduct an initial performance test on the units specified in Table 10-1.

Unless otherwise specified, the initial performance test shall be conducted to determine emission rates of particulate matter 10 microns in diameter or less (filterable and condensable). The initial performance tests shall be conducted within three years after initial startup of the petroleum refinery. The owner or operator shall complete at a minimum 20 of the performance tests within one year after initial startup of the petroleum refinery, have 40 of the performance tests completed within two years after initial startup of the petroleum refinery, and have all the performance tests completed within three years after initial startup of the petroleum refinery.

**Table 10-1 - Particulate Matter Performance Tests for Specified Units**

<b>Unit</b>	<b>Description</b>
#1	Atmospheric crude charge heater #1
#2	Atmospheric crude charge heater #2
#3	Vacuum charge heater #1
#4	Vacuum charge heater #2
#5	Naphtha hydrotreater charge heater
#6	Naphtha hydrotreater stripper reboiler heater
#7	Naphtha splitter reboiler heater
#8	Distillate hydrotreater feed heater
#9	Delayed coker #1A heater
#10	Delayed coker #1B heater
#11	Delayed coker #2A heater
#12	Delayed coker #2B heater
#13	Number one platformer charge and interheater #1
#14	Number one platformer interheater #2 and #3
#15	Number two platformer charge and interheater #1
#16	Number two platformer interheater #2 and #3
#17	Oleflex heater
#18	Reformate splitter reboiler
#19	Number one hydrocracker fractionator feed heater
#20	Number two hydrocracker fractionator feed heater
#21	Number one hydrocracker heater #1A
#22	Number one hydrocracker heater #1B
#23	Number one hydrocracker heater #1C
#24	Number one hydrocracker heater #2A
#25	Number one hydrocracker heater #2B
#26	Number two hydrocracker heater #1A
#27	Number two hydrocracker heater #1B
#28	Number two hydrocracker heater #1C
#29	Number two hydrocracker heater #2A
#30	Number two hydrocracker heater #2B
#31	Number one platformer catalyst regenerator
#32	Number two platformer catalyst regenerator
#33	Oleflex catalyst regenerator
#42a	Sulfur recovery plant thermal oxidizer #1

Unit	Description
#42b	Sulfur recovery plant thermal oxidizer #2
#42c	Sulfur recovery plant thermal oxidizer #3
#42d	Sulfur recovery plant thermal oxidizer #4
#42e	Sulfur recovery plant thermal oxidizer #5
#42f	Sulfur recovery plant thermal oxidizer #6
#45a	Wastewater treatment plant thermal oxidizer
#46a	Petroleum coke storage building baghouse #1 <sup>1</sup>
#46b	Petroleum coke storage building baghouse #2 <sup>1</sup>
#46c	Petroleum coke storage building baghouse #3 <sup>1</sup>
#46d	Petroleum coke storage building baghouse #4 <sup>1</sup>
#47	Coal/Coke unloading building <sup>1</sup>
#48	Flux unloading building <sup>1</sup>
#49	Slag loading building <sup>1</sup>
#51 through #58	One of the eight gasifier startup burner
#60	Combined cycle gas turbine #1
#61	Combined cycle gas turbine #2
#62	Combined cycle gas turbine #3
#63	Combined cycle gas turbine #4
#64	Combined cycle gas turbine #5
#175	Tank farm thermal oxidizer
#176	Tank farm thermal oxidizer

<sup>1</sup> - The initial performance test shall be conducted to determine emission rates of particulate matter 10 microns in diameter or less (filterable).

**10.8 Initial sulfur dioxide performance tests.** In accordance with ARSD 74:36:11:02, the owner or operator shall obtain an initial fuel supplier certification for the first load of ultra low sulfur distillate oil purchased or received. The fuel supplier certification shall include the following information:

1. The name of the oil supplier;
2. A statement from the oil supplier that the distillate oil complies with the specifications under the definition of distillate oil. Distillate oil means fuel oil that complies with the specifications for fuel oil numbers 1 or 2. Specifications for fuel oils are defined in the American Society for Testing and Materials in ASTM D396-78, "Standards Specifications for Fuel Oils"; and
3. A statement that the sulfur content of the distillate oil does not exceed 0.0015 weight percent sulfur.

In the case where a fuel supplier certification is not obtained, the owner or operator shall collect a grab sample from the distillate oil storage tank. The grab sample shall be analyzed to determine the sulfur content of the distillate oil in the storage tank prior to burning the distillate oil.

The owner or operator shall obtain an initial fuel supplier certification certifying that the natural gas purchased or received is classified as pipeline quality natural gas as defined in 40 CFR §72.2.

The owner or operator shall conduct an initial performance test on the units specified in Table 10-2. The initial performance test shall be conducted to determine emission rates of sulfur dioxide. The initial performance test shall be conducted within one year after initial startup of the refinery.

**Table 10-2 - Sulfur Dioxide Performance Tests for Specific Units**

Unit	Description
31	Number One Platformer Catalyst Regenerator.
32	Number Two Platformer Catalyst Regenerator.
33	Oleflex Catalyst Regenerator.

**10.9 Initial nitrogen oxide performance tests.** In accordance with ARSD 74:36:11:02, the owner or operator shall conduct an initial performance test on the units specified in Table 10-3. The initial performance test shall be conducted to determine emission rates of nitrogen oxides. The initial performance test shall be conducted within one year after initial startup of the refinery.

**Table 10-3 - Nitrogen Oxide Performance Tests for Specific Units**

Unit	Description
#31	Number one platformer catalyst regenerator
#32	Number two platformer catalyst regenerator
#33	Oleflex catalyst regenerator
#51 through #58	One of the eight gasifier startup burner
#175	Tank farm thermal oxidizer
#176	Tank farm thermal oxidizer

**10.10 Initial volatile organic compound performance tests.** In accordance with ARSD 74:36:11:02, the owner or operator shall conduct an initial performance test on the units specified in Table 10-4. The initial performance test shall be conducted to determine emission rates of volatile organic compounds as carbon. The initial performance tests shall be conducted within three years after initial startup of the petroleum refinery. The owner or operator shall complete at a minimum 15 of the performance tests within one year after initial startup of the petroleum refinery, have 30 of the performance completed within two years after initial startup of the petroleum refinery, and have all the performance tests completed within three years after initial startup of the petroleum refinery.

**Table 10-4 - Volatile Organic Compounds as Carbon Performance Tests for Specific Units**

Unit	Description
#1	Atmospheric crude charge heater #1
#2	Atmospheric crude charge heater #2

<b>Unit</b>	<b>Description</b>
<b>#3</b>	Vacuum charge heater #1
<b>#4</b>	Vacuum charge heater #2
<b>#5</b>	Naphtha hydrotreater charge heater
<b>#6</b>	Naphtha hydrotreater stripper reboiler heater
<b>#7</b>	Naphtha splitter reboiler heater
<b>#8</b>	Distillate hydrotreater feed heater
<b>#9</b>	Delayed coker #1A heater
<b>#10</b>	Delayed coker #1B heater
<b>#11</b>	Delayed coker #2A heater
<b>#12</b>	Delayed coker #2B heater
<b>#13</b>	Number one platformer charge and interheater #1
<b>#14</b>	Number one platformer interheater #2 and #3
<b>#15</b>	Number two platformer charge and interheater #1
<b>#16</b>	Number two platformer interheater #2 and #3
<b>#17</b>	Oleflex heater
<b>#18</b>	Reformate splitter reboiler
<b>#19</b>	Number one hydrocracker fractionator feed heater
<b>#20</b>	Number two hydrocracker fractionator feed heater
<b>#21</b>	Number one hydrocracker heater #1A
<b>#22</b>	Number one hydrocracker heater #1B
<b>#23</b>	Number one hydrocracker heater #1C
<b>#24</b>	Number one hydrocracker heater #2A
<b>#25</b>	Number one hydrocracker heater #2B
<b>#26</b>	Number two hydrocracker heater #1A
<b>#27</b>	Number two hydrocracker heater #1B
<b>#28</b>	Number two hydrocracker heater #1C
<b>#29</b>	Number two hydrocracker heater #2A
<b>#30</b>	Number two hydrocracker heater #2B
<b>#42a through 42f</b>	One of the six sulfur recovery plant thermal oxidizer
<b>#43</b>	Railcar loading rack
<b>#44</b>	Truck loading rack
<b>#45a</b>	Wastewater treatment plant thermal oxidizer
<b>#51 through 58</b>	One of the eight gasifier startup burner
<b>#60</b>	Combined cycle gas turbine #1
<b>#61</b>	Combined cycle gas turbine #2
<b>#62</b>	Combined cycle gas turbine #3
<b>#63</b>	Combined cycle gas turbine #4
<b>#64</b>	Combined cycle gas turbine #5
<b>#175</b>	Tank farm thermal oxidizer

Unit	Description
#176	Tank farm thermal oxidizer

**10.11 Initial carbon monoxide performance tests.** In accordance with ARSD 74:36:11:02, the owner or operator shall conduct an initial performance test on the units specified in Table 10-5. The initial performance test shall be conducted to determine emission rates of carbon monoxide. The initial performance test shall be conducted within one year after initial startup of the refinery.

*Table 10-5 - Carbon Monoxide Performance Tests for Specific Units*

Unit	Description
#31	Number one platformer catalyst regenerator
#32	Number two platformer catalyst regenerator
#33	Oleflex catalyst regenerator
#45a	Wastewater treatment plant thermal oxidizer
#51 through #58	One of the eight gasifier startup burner
#175	Tank farm thermal oxidizer
#176	Tank farm thermal oxidizer

**10.12 Initial hydrogen sulfide performance tests.** In accordance with ARSD 74:36:11:02, the owner or operator shall conduct an initial performance test on the units specified in Table 10-6. The initial performance test shall be conducted to determine emission rates of hydrogen sulfide. The initial performance test shall be conducted within one year after initial startup of the refinery.

*Table 10-6 - Hydrogen Sulfide Performance Tests for Specific Units*

Unit	Description
#42a	Sulfur recovery plant thermal oxidizer #1
#42b	Sulfur recovery plant thermal oxidizer #2
#42c	Sulfur recovery plant thermal oxidizer #3
#42d	Sulfur recovery plant thermal oxidizer #4
#42e	Sulfur recovery plant thermal oxidizer #5
#42f	Sulfur recovery plant thermal oxidizer #6

**10.13 Initial hydrogen chloride performance tests.** In accordance with ARSD 74:36:11:02, the owner or operator shall conduct an initial performance test on the units specified in Table 10-7. The initial performance test shall be conducted to determine emission rates of hydrogen chloride. The initial performance tests shall be conducted within three years after initial startup of the petroleum refinery. The owner or operator shall complete at a minimum 10 of the performance tests within one year after initial startup of the petroleum refinery, have 20 of the performance tests completed within two years after initial startup of the petroleum refinery, and have all the performance tests completed within three years after initial startup of the petroleum refinery.

**Table 10-7 Hydrogen Chloride Performance Tests for Specific Units**

<b>Unit</b>	<b>Description</b>
#1	Atmospheric crude charge heater #1
#2	Atmospheric crude charge heater #2
#3	Vacuum charge heater #1
#4	Vacuum charge heater #2
#5	Naphtha hydrotreater charge heater
#6	Naphtha hydrotreater stripper reboiler heater
#7	Naphtha splitter reboiler heater
#8	Distillate hydrotreater feed heater
#9	Delayed coker #1A heater
#10	Delayed coker #1B heater
#11	Delayed coker #2A heater
#12	Delayed coker #2B heater
#13	Number one platformer charge and interheater #1
#14	Number one platformer interheater #2 and #3
#15	Number two platformer charge and interheater #1
#16	Number two platformer interheater #2 and #3
#17	Oleflex heater
#18	Reformate splitter reboiler
#19	Number one hydrocracker fractionator feed heater
#20	Number two hydrocracker fractionator feed heater
#21	Number one hydrocracker heater #1A
#22	Number one hydrocracker heater #1B
#23	Number one hydrocracker heater #1C
#24	Number one hydrocracker heater #2A
#25	Number one hydrocracker heater #2B
#26	Number two hydrocracker heater #1A
#27	Number two hydrocracker heater #1B
#28	Number two hydrocracker heater #1C
#29	Number two hydrocracker heater #2A
#30	Number two hydrocracker heater #2B

**10.14 Initial certification of continuous emission monitoring system.** In accordance with ARSD 74:36:11:02, the owner or operator shall conduct the initial certification of each continuous emission monitoring system required in permit chapter 11.0 within 60 days of achieving maximum production or within 180 days after initial startup of the refinery, whichever comes first.

## **11.0 CONTINUOUS EMISSION MONITORING SYSTEMS**

**11.1 Sulfur dioxide continuous emission monitoring systems.** In accordance with ARSD

74:36:07, 74:36:09, and 74:36:13, the owner or operator shall install, calibrate, maintain, and operate continuous emission monitoring systems for sulfur dioxide or total sulfur in the fuel gas being burned for the units specified in Table 11-1. The continuous emission monitoring systems that record the emissions at the stack exit shall meet the performance specifications in 40 CFR Part 75, Appendix A and the quality assurance requirements in 40 CFR Part 75, Appendix B. The continuous emission monitoring systems that record the parts per million by volume sulfur, as hydrogen sulfide, in the fuel gases being burned shall meet the performance specifications and the quality assurance requirements in 40 CFR Subpart J or Ja.

The continuous emission monitoring systems shall report the emission rates that conform to the applicable emission limits (e.g. in parts per million by volume sulfur in fuel gases being burned, pounds of sulfur dioxide per million Btus, pounds of sulfur dioxide per hour). The owner or operator may convert the measured results between parts per million by volume sulfur, as hydrogen sulfide, in fuel gas to or from pounds of sulfur dioxide per million Btus and pounds sulfur dioxide per hour by assuming that all the sulfur in the fuel gas is converted to sulfur dioxide.

The continuous emission monitoring systems shall measure and record the emissions at all times, including periods of startup, shutdown, malfunctions or emergency conditions. Monitor downtime is allowed for system breakdowns, repairs, calibration checks, zero and span adjustments, and when the unit is not in operation.

**Table 11-1 – Sulfur Dioxide Continuous Emission Monitoring System**

<b>Unit</b>	<b>Description</b>
#1	Atmospheric crude charge heater #1
#2	Atmospheric crude charge heater #2
#3	Vacuum charge heater #1
#4	Vacuum charge heater #2
#5	Naphtha hydrotreater charge heater
#6	Naphtha hydrotreater stripper reboiler heater
#7	Naphtha splitter reboiler heater
#8	Distillate hydrotreater feed heater
#9	Delayed coker #1A heater
#10	Delayed coker #1B heater
#11	Delayed coker #2A heater
#12	Delayed coker #2B heater
#13	Number one platformer charge and interheater #1
#14	Number one platformer interheater #2 and #3
#15	Number two platformer charge and interheater #1
#16	Number two platformer interheater #2 and #3
#17	Oleflex heater
#18	Reformate splitter reboiler

Unit	Description
#19	Number one hydrocracker fractionator feed heater
#20	Number two hydrocracker fractionator feed heater
#21	Number one hydrocracker heater #1A
#22	Number one hydrocracker heater #1B
#23	Number one hydrocracker heater #1C
#24	Number one hydrocracker heater #2A
#25	Number one hydrocracker heater #2B
#26	Number two hydrocracker heater #1A
#27	Number two hydrocracker heater #1B
#28	Number two hydrocracker heater #1C
#29	Number two hydrocracker heater #2A
#30	Number two hydrocracker heater #2B
#42a	Sulfur recovery plant thermal oxidizer #1
#42b	Sulfur recovery plant thermal oxidizer #2
#42c	Sulfur recovery plant thermal oxidizer #3
#42d	Sulfur recovery plant thermal oxidizer #4
#42e	Sulfur recovery plant thermal oxidizer #5
#42f	Sulfur recovery plant thermal oxidizer #6
#45a	Wastewater treatment plant thermal oxidizer
#59	Power island acid gas removal system <sup>1</sup>
#60	Combined cycle gas turbine #1
#61	Combined cycle gas turbine #2
#62	Combined cycle gas turbine #3
#63	Combined cycle gas turbine #4
#64	Combined cycle gas turbine #5
#175	Tank farm thermal oxidizer
#176	Tank farm thermal oxidizer

<sup>1</sup> – The continuous emission monitoring system is for hydrogen sulfide.

**11.2 Nitrogen oxide continuous emission monitoring systems.** In accordance with ARSD 74:36:07, 74:36:09, and 74:36:13, the owner or operator shall install, calibrate, maintain, and operate continuous emission monitoring systems for nitrogen oxide for the units specified in Table 11-2. The continuous emission monitoring systems shall report the emission rates in pounds per million Btus and pounds per hour. The continuous emission monitoring systems shall measure and record the emissions at all times, including periods of startup, shutdown, malfunctions or emergency conditions. Monitor downtime is allowed for system breakdowns, repairs, calibration checks, zero and span adjustments, and when the unit is not in operation. The continuous emission monitoring systems shall meet the performance specifications in 40 CFR Part 75, Appendix A and the quality assurance requirements in 40 CFR Part 75, Appendix B.

**Table 11-2 – Nitrogen Oxide Continuous Emission Monitoring System**

Unit	Description
#1	Atmospheric crude charge heater #1
#2	Atmospheric crude charge heater #2

<b>Unit</b>	<b>Description</b>
#3	Vacuum charge heater #1
#4	Vacuum charge heater #2
#5	Naphtha hydrotreater charge heater
#6	Naphtha hydrotreater stripper reboiler heater
#7	Naphtha splitter reboiler heater
#8	Distillate hydrotreater feed heater
#9	Delayed coker #1A heater
#10	Delayed coker #1B heater
#11	Delayed coker #2A heater
#12	Delayed coker #2B heater
#13	Number one platformer charge and interheater #1
#14	Number one platformer interheater #2 and #3
#15	Number two platformer charge and interheater #1
#16	Number two platformer interheater #2 and #3
#17	Oleflex heater
#18	Reformate splitter reboiler
#19	Number one hydrocracker fractionator feed heater
#20	Number two hydrocracker fractionator feed heater
#21	Number one hydrocracker heater #1A
#22	Number one hydrocracker heater #1B
#23	Number one hydrocracker heater #1C
#24	Number one hydrocracker heater #2A
#25	Number one hydrocracker heater #2B
#26	Number two hydrocracker heater #1A
#27	Number two hydrocracker heater #1B
#28	Number two hydrocracker heater #1C
#29	Number two hydrocracker heater #2A
#30	Number two hydrocracker heater #2B
#42a	Sulfur recovery plant thermal oxidizer #1
#42b	Sulfur recovery plant thermal oxidizer #2
#42c	Sulfur recovery plant thermal oxidizer #3
#42d	Sulfur recovery plant thermal oxidizer #4
#42e	Sulfur recovery plant thermal oxidizer #5
#42f	Sulfur recovery plant thermal oxidizer #6
#45a	Wastewater treatment plant thermal oxidizer
#60	Combined cycle gas turbine #1
#61	Combined cycle gas turbine #2
#62	Combined cycle gas turbine #3
#63	Combined cycle gas turbine #4
#64	Combined cycle gas turbine #5

**11.3 Carbon monoxide continuous emission monitoring systems.** In accordance with ARSD 74:36:07, 74:36:09, and 74:36:13, the owner or operator shall install, calibrate, maintain,

and operate continuous emission monitoring systems for carbon monoxide for the units specified in Table 11-3. The continuous emission monitoring systems shall measure and record the emissions at all times, including periods of startup, shutdown, malfunctions or emergency conditions. Monitor downtime is allowed for system breakdowns, repairs, calibration checks, zero and span adjustments, and when the unit is not in operation. The continuous emission monitoring systems shall meet the performance specifications in 40 CFR Part 60, Appendix B and the quality assurance requirements in 40 CFR Part 60, Appendix F.

**Table 11-3 – Carbon Monoxide Continuous Emission Monitoring System**

<b>Unit</b>	<b>Description</b>
#1	Atmospheric crude charge heater #1
#2	Atmospheric crude charge heater #2
#3	Vacuum charge heater #1
#4	Vacuum charge heater #2
#5	Naphtha hydrotreater charge heater
#6	Naphtha hydrotreater stripper reboiler heater
#7	Naphtha splitter reboiler heater
#8	Distillate hydrotreater feed heater
#9	Delayed coker #1A heater
#10	Delayed coker #1B heater
#11	Delayed coker #2A heater
#12	Delayed coker #2B heater
#13	Number one platformer charge and interheater #1
#14	Number one platformer interheater #2 and #3
#15	Number two platformer charge and interheater #1
#16	Number two platformer interheater #2 and #3
#17	Oleflex heater
#18	Reformate splitter reboiler
#19	Number one hydrocracker fractionator feed heater
#20	Number two hydrocracker fractionator feed heater
#21	Number one hydrocracker heater #1A
#22	Number one hydrocracker heater #1B
#23	Number one hydrocracker heater #1C
#24	Number one hydrocracker heater #2A
#25	Number one hydrocracker heater #2B
#26	Number two hydrocracker heater #1A
#27	Number two hydrocracker heater #1B
#28	Number two hydrocracker heater #1C
#29	Number two hydrocracker heater #2A
#30	Number two hydrocracker heater #2B
#42a	Sulfur recovery plant thermal oxidizer #1
#42b	Sulfur recovery plant thermal oxidizer #2
#42c	Sulfur recovery plant thermal oxidizer #3
#42d	Sulfur recovery plant thermal oxidizer #4

Unit	Description
#42e	Sulfur recovery plant thermal oxidizer #5
#42f	Sulfur recovery plant thermal oxidizer #6
#59	Power island acid gas removal system
#60	Combined cycle gas turbine #1
#61	Combined cycle gas turbine #2
#62	Combined cycle gas turbine #3
#63	Combined cycle gas turbine #4
#64	Combined cycle gas turbine #5

## 12.0 REFINERY FLARE WORK PRACTICE STANDARDS

**12.1 Refinery flare operations.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not flare the gases from the refinery, except during a malfunction. Malfunction means any sudden and unavoidable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. A failure caused entirely or in part by poor maintenance, careless operation, preventable equipment breakdown, or any other cause within the control of the owner or operator of the source is not a malfunction. The flaring of gases from the refinery during a malfunction shall be completed in accordance with a flare minimization plan.

**12.2 Refinery flare design.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall meet the design and operational requirements of 40 CFR 60.18.

**12.3 Refinery flare minimization plan.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall develop a flare minimization plan in accordance with the following requirements:

1. A facility plot plan showing the location of each flare in relation to the refinery layout;
2. Information regarding design capacity, operation and maintenance for each flare;
3. Information regarding design pilot gas and purge gas flow rate, in standard cubic feet per minute, for each flare;
4. Drawing(s), preferably to scale with dimensions, and an “as built” process flow diagram of the flare system. The drawing(s) shall identify major components of the flare system, such as flare header, flare stack, flare tips or burners, purge gas system, pilot gas systems, ignition systems, assist systems, water seals, knockout drums and molecular seals;
5. A representative flow diagram showing the interconnections of the gas flare system(s) with vapor recovery system(s), process units and other equipment as applicable;
6. A complete description of the assist system process control, flame detection system and pilot ignition system;
7. A complete description of the flaring process which describes the method of operation of the flares (e.g. sequential, etc.);

8. A complete description of the vapor recovery system(s) which have interconnection to a flare, such as compressor descriptions, design capacities of each compressor and the vapor recovery system, and the method to be used to determine and record the amount of vapors recovered;
9. A detailed description of manufacturer's specifications, including but not limited to, make, model, type, range, precision, accuracy, calibration, maintenance, and quality assurance procedures for each flow metering device;
10. A complete description of each on/off flow indicator, including the following:
  - a. The data used to determine and to set the actuating and deactuating of the flow indicator; and
  - b. The method to be used to verify the actuating and deactuating settings for each flow indicator;
11. A complete description of proposed analytical and sampling methods or estimation methods, if applicable, for determining higher (gross) heating value and total sulfur content of any gases combusted in a flare during a flare event;
12. A complete description of proposed locations for obtaining representative samples of the gas flow to each flare during a flare event;
13. A complete description of the proposed data recording, collection and management for each flare monitoring system;
14. A complete description of proposed method to determine, monitor and record total volume of gases vented to a flare for each flare event;
15. A complete description of the proposed method to alert personnel designated to collect samples that a recordable flare event has started;
16. A complete description of any proposed alternative criteria to determine a recordable flare event for each specific flare, if any, and detailed information used for the basis of establishing such criteria;
17. A complete description of the methods to determine emissions associated with recordable events during periods when the flare monitoring system is out of service;
18. Description and evaluation of prevention measures to address the following:
  - a. Flaring that has occurred or reasonably may be expected to occur during planned major maintenance activities, including startup and shutdown. The evaluation shall include a review of flaring that has occurred during these activities in the past five years and shall consider the feasibility of performing these activities without flaring;
  - b. Flaring that may reasonably be expected to occur due to issues of gas quantity and quality. The evaluation shall include an audit of the storage capacity available for excess vent gases, the scrubbing capacity available for vent gases including any limitations associated with scrubbing the vent gases for use as a fuel, and shall consider the feasibility of reducing flaring through the recovery, treatment, and use of the gas or other means; and
  - c. Flaring caused by the recent failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. The evaluation shall consider the adequacy of existing maintenance schedules and protocols for such equipment. For purposes of this section, a failure is recurrent if it occurs more than twice in any five year period as a result of the same causes as identified in the event-specific investigations;

19. A program of corrective action for malfunctioning process, air pollution control, and monitoring equipment related to the performance of flares;
20. Procedures for conducting a root cause analysis; and
21. The methods for estimating particulate matter, sulfur dioxide, nitrogen oxide, volatile organic compound, and carbon monoxide emissions during a flaring event.

The owner or operator shall review and revise, if applicable, the flare minimization plan once per calendar year to ensure the plan remains current and complies with the above requirements.

**12.4 Refinery flare recordkeeping and reporting.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall record the following during each flare event:

1. Identify and record the date and time that the flare event started and the duration of the flare event;
2. Within 15 minutes after the start of the flare event, submit notification to the Secretary, indicating (based on available information) the cause of the flare event, the process system(s) involved, and the anticipated duration of the flare event;
3. Measure and record the gas flow to each flare, using continuous flow monitoring devices;
4. Beginning no more than 15 minutes after the start of the flare event, perform a visible emissions observation for the duration of the flare event, using 40 CFR Part 60, Appendix A, Method 9. Visible emissions observations are not required between sunset and sunrise or during other periods when valid observations using Method 9 are not possible;
5. Take a representative sample of the gas flow to each flare;
6. Determine and record the higher (gross) heating value of the gas flow to each flare;
7. Determine and record the total sulfur content of the gas flow to each flare;
8. Calculate and record the particulate matter, sulfur dioxide, nitrogen oxide, volatile organic compounds, and carbon monoxide emissions from the flare during the flare event; and
9. Within 24 hours after the end of the flare event, submit notification to the Secretary, summarizing all information required to be recorded in steps 1 through 9 (based on available information).

**12.5 Root cause analysis, recordkeeping and reporting.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall conduct a root cause analysis of flaring event that exceeds 5,000 standard cubic foot of gas and report the findings of the root cause analysis to the Secretary within 45 days after the flaring event. The natural gas fired in the pilot flame does not count toward the 5,000 standard cubic foot criteria. The root cause analysis and report shall contain the following:

1. The date and time that the flaring event started and ended;
2. The total quantity of gas flared during each event;
3. The quantity of particulate matter, sulfur dioxide, nitrogen oxide, volatile organic compounds, and carbon monoxide emissions emitted and the calculations used to determine the quantities;
4. The steps taken to limit the duration of the flaring event or the quantity of emissions associated with the event;
5. A detailed analysis that sets forth the root cause and all significant contributing causes of the flaring event to the extent determinable;

6. An analysis of the measures, if any, available to reduce the likelihood of a recurrence of a flaring event resulting from the same root cause or significant contributing causes in the future; and
7. A demonstration that the actions taken during the flaring event are consistent with the procedures specified in the flare minimization plan, as appropriate. If the actions taken during the flaring event are not consistent with the procedures specified in the appropriate plan, then the owner or operator must record the actions taken for that event and identify the reasons why the plan was not followed.

## **13.0 IGCC FLARE WORK PRACTICE STANDARDS**

**13.1 IGCC flare operations.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not flare the gases from the gasification system, except during startup, shutdown, or a malfunction. Malfunction means any sudden and unavoidable failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. A failure caused entirely or in part by poor maintenance, careless operation, preventable equipment breakdown, or any other cause within the control of the owner or operator of the source is not a malfunction. The flaring of gases from the refinery during startup, shutdown, or a malfunction shall be completed in accordance with a flare minimization plan.

**13.2 IGCC flare design.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall meet the design and operational requirements of 40 CFR §60.18.

**13.3 IGCC flare minimization plan.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall develop a flare minimization plan in accordance with the following requirements:

1. A facility plot plan showing the location of each flare in relation to the refinery layout;
2. Information regarding design capacity, operation and maintenance for each flare;
3. Information regarding design pilot gas and purge gas flow rate, in standard cubic feet per minute, for each flare;
4. Drawing(s), preferably to scale with dimensions, and an “as built” process flow diagram of the flare system. The drawing(s) shall identify major components of the flare system, such as flare header, flare stack, flare tips or burners, purge gas system, pilot gas systems, ignition systems, assist systems, water seals, knockout drums and molecular seals;
5. A representative flow diagram showing the interconnections of the gas flare system(s) with vapor recovery system(s), process units and other equipment as applicable;
6. A complete description of the assist system process control, flame detection system and pilot ignition system;
7. A complete description of the flaring process which describes the method of operation of the flares (e.g. sequential, etc.);
8. A complete description of the vapor recovery system(s) which have interconnection to a flare, such as compressor descriptions, design capacities of each compressor and the vapor

recovery system, and the method to be used to determine and record the amount of vapors recovered;

9. A detailed description of manufacturer's specifications, including but not limited to, make, model, type, range, precision, accuracy, calibration, maintenance, and quality assurance procedures for each flow metering device;
10. A complete description of each on/off flow indicator, including the following:
  - a. The data used to determine and to set the actuating and deactuating of the flow indicator; and
  - b. The method to be used to verify the actuating and deactuating settings for each flow indicator;
11. A complete description of proposed analytical and sampling methods or estimation methods, if applicable, for determining higher (gross) heating value and total sulfur content of any gases combusted in a flare during a flare event;
12. A complete description of proposed locations for obtaining representative samples of the gas flow to each flare during a flare event;
13. A complete description of the proposed data recording, collection and management for each flare monitoring system;
14. A complete description of proposed method to determine, monitor and record total volume of gases vented to a flare for each flare event;
15. A complete description of the proposed method to alert personnel designated to collect samples that a recordable flare event has started;
16. A complete description of any proposed alternative criteria to determine a recordable flare event for each specific flare, if any, and detailed information used for the basis of establishing such criteria;
17. A complete description of the methods to determine emissions associated with recordable events during periods when the flare monitoring system is out of service;
18. Description and evaluation of prevention measures to address the following:
  - a. Flaring that has occurred or reasonably may be expected to occur during planned major maintenance activities, including startup and shutdown. The evaluation shall include a review of flaring that has occurred during these activities in the past five years and shall consider the feasibility of performing these activities without flaring;
  - b. Flaring that may reasonably be expected to occur due to issues of gas quantity and quality. The evaluation shall include an audit of the storage capacity available for excess vent gases, the scrubbing capacity available for vent gases including any limitations associated with scrubbing the vent gases for use as a fuel, and shall consider the feasibility of reducing flaring through the recovery, treatment, and use of the gas or other means; and
  - c. Flaring caused by the recent failure of air pollution control equipment, process equipment, or a process to operate in a normal or usual manner. The evaluation shall consider the adequacy of existing maintenance schedules and protocols for such equipment. For purposes of this section, a failure is recurrent if it occurs more than twice in any five year period as a result of the same causes as identified in the event-specific investigations;
19. A program of corrective action for malfunctioning process, air pollution control, and monitoring equipment related to the performance of flares; and

20. The methods for estimating particulate matter, sulfur dioxide, nitrogen oxide, volatile organic compound, and carbon monoxide emissions during a flaring event.

The owner or operator shall review and revise, if applicable, the flare minimization plan once per calendar year to ensure the plan remains current and complies with the above requirements.

**13.4 IGCC flare recordkeeping and reporting.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall record the following during each flare event:

1. Identify and record the date and time that the flare event started and the duration of the flare event;
2. Within 15 minutes after the start of the flare event, submit notification to the Secretary, indicating (based on available information) the cause of the flare event, the process system(s) involved, and the anticipated duration of the flare event;
3. Measure and record the gas flow to each flare, using continuous flow monitoring devices;
4. Beginning no more than 15 minutes after the start of the flare event, perform a visible emissions observation for the duration of the flare event, using 40 CFR Part 60, Appendix A, Method 9. Visible emissions observations are not required between sunset and sunrise or during other periods when valid observations using Method 9 are not possible;
5. Take a representative sample of the gas flow to each flare;
6. Determine and record the higher (gross) heating value of the gas flow to each flare;
7. Determine and record the total sulfur content of the gas flow to each flare;
8. Calculate and record the particulate matter, sulfur dioxide, nitrogen oxide, volatile organic compounds, and carbon monoxide emissions from the flare during the flare event; and
9. Within 24 hours after the end of the flare event, submit notification to the Secretary, summarizing all information required to be recorded in steps 1 through 9 (based on available information).

## **14.0 LDAR PROGRAM**

**14.1 Periodic monitoring of pumps in light liquid service.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor each pump in light liquid service to detect leaks as follows:

1. Each pump in light liquid service shall be monitored each calendar month to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;
2. Each pump shall be checked by visual inspection each calendar week. A leak is detected if there is indications of liquid drippings from the pump seal;
3. When a leak is detected; a first attempt at repairing the leak shall be completed within 24 hours of detecting the leak. The first attempt at the repair may include, but are not limited to: tightening of packing gland nuts and ensuring that the seal flush is operating at design pressure and temperature. The leak shall be successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12;

4. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired.
5. Each pump equipped with a dual mechanical seal system that includes a barrier fluid system is exempt from steps 1 and 2 provided the following requirements in steps 5a through 5d are met:
  - a. Each dual mechanical seal system is
    - i. Operated with a barrier fluid at a pressure that is at all times greater than the pump stuffing box pressure; or
    - ii. Equipped with a barrier fluid degassing reservoir that is routed to a fuel gas system or connected by a closed-vent system to a control device that complies with permit condition 14.9; or
    - iii. Equipped with a closed-loop system that purges the barrier fluid into a process stream; and
  - b. The barrier fluid is not in light liquid service;
  - c. Each barrier fluid system is equipped with a sensor that will detect failure of the seal system, the barrier fluid system, or both. The sensor shall be observed daily or equipped with an alarm. Based on design considerations, a leak is detected if the established criteria for the sensor are triggered. The criteria established for the sensor shall be equivalent to monitoring a leak at 500 parts per million;
  - d. Each pump shall be checked by visual inspection each calendar week. Based on design considerations, a leak is detected if the established criteria for the liquid drippings from the pump seal are exceeded. The criteria established for the sensor shall be equivalent to monitoring a leak at 500 parts per million. If there are indications of liquid drippings from the pump seal is less than the design criteria, the pump shall be monitored to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;
6. Each pump that is designed with no externally actuated shaft penetrating the pump housing is exempt from steps 1, 2, and 3.
7. Each pump that is equipped with a closed vent system capable of capturing and transporting any leakage from the seal or seals to a process or to a fuel gas system or to a control device that complies with permit condition 14.9 is exempt from steps 1, 2, and 3.

**14.2 Periodic monitoring of compressors.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor each compressor to detect leaks as follows

1. Each compressor shall be monitored each calendar month to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;
2. When a leak is detected; a first attempt at repairing the leak shall be completed within 24 hours of detecting the leak. The leak shall be successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12;
3. Each compressor shall be equipped with a seal system that includes a barrier fluid system and that prevents leakage of process fluid to the atmosphere is exempt from step 1.
  - a. Each compressor system shall meet one of the following requirements

- i. Operated with a barrier fluid at a pressure that is at all times greater than the compressor stuffing box pressure; or
  - ii. Equipped with a barrier fluid degassing reservoir that is routed to a fuel gas system or connected by a closed-vent system to a control device that complies with permit condition 14.9; or
  - iii. Equipped with a closed-loop system that purges the barrier fluid into a process stream; and
- b. The barrier fluid is not in light liquid service;
- c. Each barrier fluid system is equipped with a sensor that will detect failure of the seal system, the barrier fluid system, or both. The sensor shall be observed daily or equipped with an alarm. Based on design considerations, a leak is detected if the established criteria for the sensor are triggered. The criteria established for the sensor shall be equivalent to monitoring a leak at 500 parts per million;
- 4. Each compressor that is equipped with a closed vent system capable of capturing and transporting any leakage from the compressor draft shaft seal to a process or to a fuel gas system or to a control device that complies with permit condition 14.9 is exempt from steps 1, 2, and 3; and
- 5. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired.

**14.3 Periodic monitoring of pressure relief devices in gas/vapor service.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor each pressure relief devices in gas/vapor service to detect leaks as follows:

- 1. Each pressure relief device shall be monitored each calendar month to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured, except during pressure releases;
- 2. When a leak is detected and/or after each pressure release; a first attempt at repairing the leak or at returning the pressure release device back to its normal operational setting shall be completed within 24 hours of detecting the leak and/or pressure release. The leak shall be successfully repaired or the pressure release device shall be returned to its normal operational setting within 5 days of detecting the leak except for as provided in permit condition 14.12;
- 3. Within 24 hours after the attempt to repair the leak has been completed or within five days after the pressure release, whichever is earlier, a reading based on the method specified in 40 CFR §63.180 shall be made to verify pressure relief device has been repaired;
- 4. Each pressure relief device that is routed to a process or fuel gas system or that equipped with a closed vent system capable of capturing and transporting any leakage from the pressure relief device to a control device that complies with permit condition 14.9 is exempt from steps 1 and 2; and
- 5. Each pressure relief device that is equipped with a rupture disk upstream of the pressure relief device is exempt from steps 1 and 2. After each pressure release, a rupture disk shall be re-installed upstream of the pressure release device within 5 days after the pressure release except for as provided in permit condition 14.12;

**14.4 Periodic monitoring of sampling connection systems.** In accordance with ARSD

74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor each sampling connection system to detect leaks as follows:

1. Each sampling connection system shall be equipped with a closed-purge, closed-loop, or closed-vent system. The gases displaced during the filling of the sample container are not required to be collected or captured;
2. Each closed-purge, closed-loop, or closed vent system shall do the following:
  - a. Return the purged process fluid directly to the process line; or
  - b. Collect and recycle the purged process fluid to a process; or
  - c. Design and operate to capture and transport the purged process fluid to a control device that complies with permit condition 14.9; or
  - d. Collect, store, and transport the purged process fluid to a waste management unit that is covered by a National Pollutant Discharge Elimination System permit; and
3. In-situ sampling systems and sampling systems without purges are exempt from the requirements of steps 1 and 2.

**14.5 Periodic monitoring of open-ended valves and lines.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor each open ended valves or lines as follows:

1. Each open ended valve or line shall be equipped with a cap, blind flange, plug, or second valve. The cap, blind flange, plug, or second valve shall seal the open end at all times, except during operations requiring process fluid flow through the open-ended valve or line, or during maintenance or repair;
2. Each open ended valve or line equipped with a second valve shall be operated in a manner such that the valve on the process fluid end is closed before the second valve is closed;
3. When a double block and bleed system is being used, the bleed valve or line may remain open during operations that require venting the line between the block valves;
4. Open-ended valves or lines in an emergency shutdown system which are designed to open automatically in the event of a process upset are exempt from steps 1, 2, and 3; and
5. Open-ended valves containing materials which would autocatalytically polymerize or would present an explosion, serious overpressure, or other safety hazard if capped or equipped with a double block and bleed system are exempt from steps 1, 2, and 3

**14.6 Periodic monitoring of valves in gas/vapor service and light liquid service.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor each valve in gas/vapor service and light liquid service as follows:

1. Each valve shall be monitored each calendar month to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 100 parts per million or greater is measured;
2. When a leak is detected; a first attempt at repairing the leak shall be completed within 24 hours of detecting the leak. The first attempt at the repair may include, but are not limited to: tightening of bonnet bolts; replacement of bonnet bolts, tightening of packing gland nuts; and injection of lubricant into lubricated packing. The leak shall be

successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12;

3. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired;
4. Each valve that is designated as an unsafe-to-monitor is exempt from steps 1, 2, and 3. A valve is considered unsafe-to-monitor if personnel would be exposed to an immediate danger while completing steps 1, 2, and 3. Each valve designated as an unsafe-to-monitor shall have a written plan that requires monitoring of a valve as frequently as practicable but not more frequently than monthly and not less than annually; and
5. Each valve that is designated as an difficult-to-monitor is exempt from steps 1, 2, and 3. A valve is considered difficult-to-monitor if the valve cannot be monitored without elevating personnel more than 2 meters (6.6 ft) above a support surface or if it is not accessible at anytime in a safe manner. Each valve designated as a difficult-to-monitor shall have a written plan that requires monitoring of a valve as frequently as practicable but not more frequently than monthly and not less than annually. The number of valves designated as difficult-to-monitor shall be less than 3 percent of the total number of valves at the facility.

**14.7 Periodic monitoring of other pumps, valves, connectors, etc.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor each pump, valve, connector, and agitator in heavy liquid service, pressure relief devices in light liquid or heavy liquid service and instrumentation systems as follows:

1. Each pump, valve, connector, and agitator in heavy liquid service, pressure relief devices in light liquid or heavy liquid service and instrumentation systems shall be checked by visual inspection each calendar week. A leak is detected if liquid drippings from the equipment is observed;
2. Each pump, valve, connector, and agitator in heavy liquid service, pressure relief devices in light liquid or heavy liquid service and instrumentation systems shall be monitored each calendar month or within 24 hours after a visual inspection that indicated any evidence of a leak by any visual, audible, or olfactory method to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;
3. When a leak is detected; a first attempt at repairing the leak shall be completed within 24 hours of detecting the leak. The first attempt at the repair may include, but are not limited to: tightening of bonnet bolts; replacement of bonnet bolts, tightening of packing gland nuts; and injection of lubricant into lubricated packing. The leak shall be successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12;
4. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired;

**14.8 Periodic monitoring of surge control vessels and bottom receivers.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall equip each surge control vessel or bottoms that has a capacity between 38 and 151 cubic meters and a

maximum true vapor pressure greater than or equal to 13.1 kilopascals and/or a capacity greater than or equal to 151 cubic meters and a maximum true vapor pressure greater than or equal to 0.7 kilopascals with a closed-vent system that routes the organic vapors vented from the surge control vessel or bottoms receiver back to the process or to a control device.

**14.9 Periodic monitoring of closed vent systems and control devices.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall operate and periodically monitor each closed vent system and control device as follows:

1. A recovery or recapture device shall be designed and operated to recover volatile organic compound emission vented to them with an efficiency of 98 percent efficient or to an exit concentration of 20 parts per million by volume, whichever is less stringent;
2. An enclosed combustion device shall be designed and operated to recover volatile organic compound emission vented to them with an efficiency of 98 percent efficient or to an exit concentration of 20 parts per million by volume, whichever is less stringent;
3. A flare shall be designed and operated in accordance with 40 CFR §60.18;
4. Each closed vent system and control device shall be monitored each calendar quarter to detect leaks by the method specified in 40 CFR §63.180. A leak is detected in an instrument reading of 500 parts per million or greater is measured;
5. Each closed vent system and control device shall be monitored each calendar month. A leak is detected if there is any visible, audible, or olfactory indications of leaks;
6. When a leak is detected; a first attempt at repair the leak shall be completed within 24 hours of detecting the leak. The leak shall be successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12
7. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired;
8. For each closed vent system that contains bypass lines that could divert a vent stream away from the control device and to the atmosphere, the owner or operator shall meet the following:
  - a. Install, set or adjust, maintain, and operate a flow indicator that takes a reading at least once every 15 minutes. The flow indicator shall be installed at the entrance to any bypass line; or
  - b. Secure the bypass line valve in the non-diverting position with a carseal or a lock-and-key type configuration. A visual inspection of the seal or closure mechanism shall be performed at least once every month to ensure the valve is maintained in the non-diverting position and the vent stream is not diverted through the bypass line; and
  - c. Equipment such as low leg drains, high point bleeds, analyzer vents, open ended valves or lines, and pressure relief valves needed for safety purposes are not applicable to step 8;
9. Each closed vent system and control device that is designated as unsafe-to-monitor is exempt from Steps 4 and 5. A closed vent system and control device is considered unsafe-to-monitor if personnel would be exposed to an immediate danger while completing steps 4 and 5. Each closed vent system and control device shall have a written plan that requires monitoring of the closed vent system and control device as frequent as practicable but not more frequently than monthly and not less than annually;
10. Each closed vent system and control device that is designated as difficult-to-monitor is

exempt from Steps 4 and 5. A closed vent system and control device is considered difficult-to-monitor if the closed vent system and control device cannot be monitored without elevating personnel more than 2 meters (6.6 feet) above a support. Each closed vent system and control device shall have a written plan that requires monitoring of the closed vent system and control device as frequent as practicable but not more frequently than monthly and not less than annually

**14.10 Periodic monitoring of agitators in gas/vapor service and in light liquid service.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor agitator in gas/vapor service and in light liquid service to detect leaks as follows:

1. Each agitator in gas/vapor service and in light liquid service shall be monitored each calendar month to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;
2. Each agitator in gas/vapor service and in light liquid service shall be checked by visual inspection each calendar week. A leak is detected if there is indications of liquid drippings;
3. When a leak is detected; a first attempt at repairing the leak shall be completed within 24 hours of detecting the leak. The leak shall be successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12;
4. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired.
5. Each agitator in gas/vapor service and in light liquid service equipped with a dual mechanical seal system that includes a barrier fluid system is exempt from steps 1 and 2 provided the following requirements in steps 5a through 5d are met:
  - a. Each dual mechanical seal system is
    - i. Operated with a barrier fluid at a pressure that is at all times greater than the agitator stuffing box pressure; or
    - ii. Equipped with a barrier fluid degassing reservoir that is routed to a fuel gas system or connected by a closed-vent system to a control device that complies with permit condition 14.9; or
    - iii. Equipped with a closed-loop system that purges the barrier fluid into a process stream; and
  - b. The barrier fluid is not in light liquid service;
  - c. Each barrier fluid system is equipped with a sensor that will detect failure of the seal system, the barrier fluid system, or both. The sensor shall be observed daily or equipped with an alarm. Based on design considerations, a leak is detected if the established criteria for the sensor are triggered. The criteria established for the sensor shall be equivalent to monitoring a leak at 500 parts per million;
  - d. Each agitator in gas/vapor service and in light liquid service shall be checked by visual inspection each calendar week. Based on design considerations, a leak is detected if the established criteria for the liquid drippings from the pump seal are exceeded. The criteria established for the liquid drippings shall be equivalent to monitoring a leak at 500 parts per million. If there are indications of liquid drippings from the pump seal is less than the design criteria, the pump shall be monitored to detect leaks by the method specified in

40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;

6. Each agitator in gas/vapor service and in light liquid service that is designed with no externally actuated shaft penetrating the pump housing is exempt from steps 1, 2, and 3.
7. Each agitator in gas/vapor service and in light liquid service that is equipped with a closed vent system capable of capturing and transporting any leakage from the seal or seals to a process or to a fuel gas system or to a control device that complies with permit condition 14.9 is exempt from steps 1, 2, and 3
8. Each agitator in gas/vapor service and in light liquid service that is designated as unsafe-to-monitor is exempt from Steps 1 through 5. A agitator in gas/vapor service and in light liquid service is considered unsafe-to-monitor if personnel would be exposed to an immediate danger while completing steps 1 through 5. Each agitator in gas/vapor service and in light liquid service shall have a written plan that requires monitoring of the agitator in gas/vapor service and in light liquid service as frequent as practicable but not more frequently than monthly and not less than annually;
9. Each agitator in gas/vapor service and in light liquid service that is designated as difficult-to-monitor is exempt from Steps 1 through 5. A agitator in gas/vapor service and in light liquid service if the agitator in gas/vapor service and in light liquid service cannot be monitored without elevating personnel more than 2 meters (6.6 feet) above a support or it is not accessible at anytime in a safe manner. Each agitator in gas/vapor service and in light liquid service shall have a written plan that requires monitoring of the agitator in gas/vapor service and in light liquid service as frequent as practicable but not more frequently than monthly and not less than annually. The owner or operator shall not designate more than 3 percent of the agitator in gas/vapor service and in light liquid service at the facility as difficult-to-monitor;
10. Each agitator in gas/vapor service and in light liquid service that is obstructed by equipment or piping that prevents access to the agitator by a monitor probe is exempt from Steps 1 through 5.

**14.11 Periodic monitoring of connectors in gas/vapor service and in light liquid service.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall periodically monitor connectors in gas/vapor service and in light liquid service to detect leaks as follows:

1. Each connector in gas/vapor service and in light liquid service shall be monitored each calendar year to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;
2. Each connector in gas/vapor service and in light liquid service that has been opened or has had the seal broken shall be monitored within calendar months after being returned to service to detect leaks by the method specified in 40 CFR §63.180. A leak is detected if an instrument reading of 500 parts per million or greater is measured;
3. When a leak is detected; a first attempt at repairing the leak shall be completed within 24 hours of detecting the leak. The leak shall be successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12
4. Each connector in gas/vapor service and in light liquid service that is designated as unsafe-to-monitor is exempt from Steps 1 and 2. A connector in gas/vapor service and in light

liquid service is considered unsafe-to-monitor if personnel would be exposed to an immediate danger while completing steps 1 and 2. Each connector in gas/vapor service and in light liquid service shall have a written plan that requires monitoring of the connector in gas/vapor service and in light liquid service as frequent as practicable but not more frequently than monthly and not less than annually

5. Each connector in gas/vapor service and in light liquid service that is inaccessible or is ceramic or ceramic lined (e.g., porcelain, glass, or glass-lined), is exempt from steps 1 and 2. An inaccessible connector is one that is one of the following;
  - a. Buried;
  - b. Insulated in a manner that prevents access to the connector by a monitor probe;
  - c. Obstructed by equipment or piping that prevents access to the connector by a monitor probe;
  - d. Unable to be reached from a wheeled scissor-lift or hydraulic-type scaffold which would allow access to connectors up to 7.6 meters (25 feet) above the ground;
  - e. Inaccessible because it would require elevating the monitoring personnel more than 2 meters (6 feet) above a permanent support surface or would require the erection of scaffold; or
  - f. Not able to be accessed at any time in a safe manner to perform monitoring. Unsafe access includes, but is not limited to, the use of a wheeled scissor-lift on unstable or uneven terrain, the use of a motorized man-lift basket in areas where an ignition potential exists, or access would require near proximity to hazards such as electrical lines, or would risk damage to equipment.
6. Each connector in gas/vapor service and in light liquid service that is inaccessible or is ceramic or ceramic lined shall be shall be monitored each calendar year. A leak is detected if there is any visible, audible, or olfactory indications of leaks observed; and
7. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired.

**14.12 Repair delay.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), a delay of repair of equipment for which leaks have been detected will be allowed in the following circumstances:

1. If the delay would not cause the percent leaking components to exceed any of the following
  - a. 1.0 percent of the total number of pumps in light liquid service and compressors on a facility-wide basis;
  - b. 1.0 percent of the total number of pressure relief devices on a facility-wide basis;
  - c. 0.3 percent of the total number of valves in gas/vapor service and valves in light liquid service on a facility-wide basis;
  - d. 0.3 percent of the total number of connectors in gas/vapor service and connectors in light liquid service on a facility-wide basis; and
2. As long as step one is maintained, a delay may occur if the repair is technically infeasible without a process unit shutdown. Repair of this equipment shall occur before the end of the next process unit shutdown;

3. As long as step one is maintained, a delay of repair of equipment will be allowed for equipment which is isolated from the process and which does not remain in volatile organic compound service;
4. As long as step one is maintained, a delay of repair for valves will be allowed if:
  - a. The owner or operator demonstrates that emissions of purged material resulting from immediate repair are greater than the fugitive emissions likely to result from delay of repair; and
  - b. When repair procedures are affected, the purged material is collected and destroyed or recovering a control device complying with permit condition 14.9 of this permit.
4. As long as step one is maintained, delay of repair for pumps will be allowed if:
  - a. Repair requires the use of a dual mechanical seal system that includes a barrier fluid system; and
  - b. Repair is completed as soon as practicable, but not later than six months after the leak was detected.
5. As long as step one is maintained, delay of repair beyond a process unit shutdown will be allowed for a valve, if valve assembly replacement is necessary during the process unit shutdown, and valve assembly supplies had been sufficiently stocked and have been depleted. Delay of repair beyond the next process unit shutdown will not be allowed unless the next process unit shutdown occurs sooner than six months after the first process units shutdown.

**14.13 Cooling tower heat exchanger.** In accordance with ARSD 74:36:09:02, as referenced to 40 CFR §52.21(j)(3), the owner or operator shall install and operate hydrocarbon detectors downstream of the return water outlet from the cooling tower process heater exchange banks or units where a process fluid containing volatile organic compound is at a higher pressure than the cooling water. If hydrocarbons are found in the water a leak is detected. When a leak is detected, a first attempt at repair the leak shall be completed within 24 hours of detecting the leak. The leak shall be successfully repaired within 7 days of detecting the leak except for as provided in permit condition 14.12. Within 24 hours after the attempt to repair the leak has been completed, another reading based on the method that determined the leak shall be made to verify if the leak has been repaired

## **15.0 WASTEWATER TREATMENT FACILITY STANDARDS**

**15.1 Wastewater collection system.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall meet the closed vent system and dual carbon canister design standards in 40 CFR §61.349 for each wastewater collection system drain having a vent.

**15.2 Wastewater stripper.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall maintain a flow-weighted average of 10 parts per million by weight of benzene determined on a 365-day rolling average in the wastewater that enters the oil/water separators.

**15.3 Equalization tank.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall meet the floating roof design standards in 40 CFR §61.351 for each equalization tank.

**15.4 Oil/Water Separator and DAF Units.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall meet the closed vent system and thermal oxidizer design standards in 40 CFR §61.341 for each oil/water separator and each primary dissolved air flotation (DAF) units, with the exemption the control efficiency of the system must meet the requirements in permit condition 4.4 for the wastewater treatment facility's thermal oxidizer.

## **16.0 FUGITIVE DUST CONTROLS**

**16.1 Fugitive dust plan.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(9), the owner or operator shall develop, maintain, and implement a fugitive dust plan. The fugitive dust plan shall be maintained on-site and contain the following information:

1. The specific work practice standards that will be implemented in accordance with permit condition 16.2 through 16.8, inclusive;
2. The frequency of the opacity readings required to verify compliance with the opacity limits in permit condition 16.8 will be conducted; and
3. Documentation that the work practice standards were implemented and a copy of each opacity reading.

**16.2 Unpaved road controls.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall apply a chemical stabilizer on all main haul roads and a chemical stabilizer or water on all secondary roads that have daily vehicular traffic or an alternative method approved by the Secretary. The frequency of applying chemical stabilizer or water will be on an as needed basis to comply with the opacity limit in permit condition 16.7. The owner or operator may pave the main haul roads or secondary roads with tack seal, asphalt, recycled asphalt, or concrete. If the main haul road or secondary haul road is paved, the owner or operator shall meet the requirements of permit condition 16.2. A main haul road is defined as a passageway between the mining area and the processing facility or between the processing facility and the storage area in which material is transferred on a road. A secondary haul road is defined as a passageway in which there is daily vehicular traffic on normal working days other than the main haul roads. This condition applies during both the construction and operational phase of the facility.

**16.3 Paved roads and parking area controls.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall use a mechanical sweeper that collects particulate matter and is equipped with wet suppressions, a vacuum sweeper, or water flush all paved roads and parking areas to remove particulate matter that has the potential to be re-suspended during the spring, summer, and fall. During the winter months or during freezing weather, the paved roads and parking lots shall be cleaned with the mechanical sweeper that collects particulate matter and is equipped with wet suppressions or a vacuum sweeper. The frequency of cleaning will be on an as needed basis to comply with the opacity limit in permit

condition 16.7. This condition applies during both the construction and operational phase of the facility.

**16.4 Track out area controls.** A track out area is defined as the driving surface from the owner's or operator's facility to a paved public roadway upon which particulate matter may be deposited by transport vehicles. In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall pave (asphalt or concrete) a track out area to maintain a stabilized surface starting from the point of intersection with the public paved surface into the facility boundary for a total distance of at least 100 feet and a width of at least 20 feet or install a wash station and require all haul truck vehicles leaving the facility to remove track out materials through the use of water. For temporary track out areas (in use for less than 60 days in a calendar year), techniques and/or controls shall be implemented so as to prevent particulate matter from becoming entrained in violation of the opacity limit in permit condition 16.7. This condition applies during both the construction and operational phase of the facility.

**16.5 Open storage pile control.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall sample and analyze the silt content of open storage piles that have a height greater than or equal to three feet and have a total surface area greater than or equal to 150 square feet. The analysis shall be conducted once per calendar year and in accordance with ASTM C-136 or another equivalent method approved by the Secretary. Open storage pile controls shall be applied to each open storage pile that has a silt content of four percent by weight or greater. Silt is defined as any material with a particulate size less than 74 micrometers in diameter and passes through a number 200 sieve. Open storage pile controls shall be applied or constructed in a manner that maintains compliance with the opacity limit in permit condition 16.7. Open storage pile controls shall consist of at least one of the following:

1. Apply chemical stabilizer to the surface area of all open storage piles;
2. Apply water to the surface area of all open storage piles;
3. Install at least a two-sided enclosure with walls extending, at a minimum, to the top of the open storage pile; or
4. An alternative method approved by the Secretary

This condition applies during both the construction and operational phase of the facility.

**16.6 Waste pit controls.** In accordance with ARSD 74:36:05:16.01(8), the owner or operator shall apply a soil cement, water spray, or similar application to create a crusted surface over the entire waste pit or implement a combination of wind protection (i.e., wind-fence, wind-screen, three wall enclosure, etc.) and water spray application. Waste pit controls shall be applied or constructed in a manner that maintains compliance with the opacity limit in permit condition 16.7. This condition applies during both the construction and operational phase of the facility.

**16.7 Wash out concrete truck area.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator is not required to add controls to the washout concrete truck area provided the area stays in compliance with the opacity limit in permit condition 16.7. This condition applies during both the construction and operational phase of the facility.

**16.8 Opacity limit for fugitive sources.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not discharge a visible emission to the ambient air of a density equal to or greater than 20 percent opacity from an unpaved road or parking lot, paved road or parking lot, open storage pile, track out area, open storage pile, waste pit or wash out concrete truck area. The 20 percent opacity reading is based on a series of two minute averages with a minimum observation period of six minutes. The opacity reading shall be determined by 40 CFR Part 60, Appendix A, Method 9.

If an operation exceeds the opacity limit, the Secretary will allow the owner or operator two opportunities to correct the exceedance with existing controls and/or control measures. In the event of a third exceedance from the same operation, the Secretary will notify the owner or operator that the Best Available Control Measure (BACM) for that operation must be reevaluated. The owner or operator shall reevaluate BACM for that operation and submit a written proposal to the Secretary on the proposed new BACM for the operation within 60 days of receiving the Secretary's notification. The Secretary shall approve or disapprove the proposed new BACM within 60 days of receiving the proposal from the owner or operator.

**16.9 Coke moisture content.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall utilize water sprays to maintain the coke moisture content above 10 percent for coke handling operating occurring in the coke pit.

**16.10 Material unloading.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall unload petroleum coke, coal, and flux and load slag within a building.

**16.11 Coke pit.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall construct wall on all sides of the coke pit.

**16.12 Opacity limit for storage building.** In accordance with ARSD 74:36:09:02, as referenced to ARSD 74:36:05:16.01(8), the owner or operator shall not discharge a visible emission to the ambient air of a density equal to or greater than 0 percent opacity from the coke storage building, coke/coal unloading building, flux unloading building, and slag building.

## **17.0 RECOMMENDATION**

A review of this facility indicates it can operate in compliance with South Dakota's Air Pollution Control rules and the federal Clean Air Act. The Secretary, therefore, recommends that the Board of Minerals and Environment issue this permit with conditions to ensure compliance with SDCL 34A-1 and the federal Clean Air Act. Any questions pertaining to the Secretary's recommendation should be directed to Kyrik Rombough, Natural Resources Engineering Director, at (605) 773-3151.