

Town of Colome Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	296	System Population:	296
Certified Operator:	Mr Dave Witt PO Box 237 Colome, SD 57528-0237	Work Phone:	(605)842-0853
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	witty232000@yahoo.com
Financial Contact:	Ms Carol Moyer PO Box 237 Colome, SD 57528-0237	Work Phone:	(605)842-0853
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityofcolome@gmail.com
Other Contacts:	Mayor Todd Hauf PO Box 237 Colome, SD 57528-0237	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	June 4, 2015		
Type of System:	Community	Area Served:	Tripp County
Number of Service Connections:	150	Contamination Risk:	low
Water Produced And Used By The Town of Colome Public Water System			
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Monitoring/Reporting - Entry Point

Town of Colome

EPA ID: 0094

SAMPLING

Entry point: Treat Site - Well #1

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Nov-11		
	B. Arsenic	Every nine years	Yes	Nov-11		
	C. Barium	Every nine years	Yes	Nov-11		
	D. Beryllium	Every nine years	Yes	Nov-11		
	E. Cadmium	Every nine years	Yes	Nov-11		
	F. Chromium	Every nine years	Yes	Nov-11		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Dec-11		
	I. Mercury	Every nine years	Yes	Nov-11		
	J. Nickel	Every nine years	Yes	Nov-11		
	K. Selenium	Every nine years	Yes	Nov-11		
	L. Thallium	Every nine years	Yes	Nov-11		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Quarterly	No	Jul-17	2017	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Nov-17		
	B. Method 524	Triennially	No	Nov-17		
	C. Method 525	Triennially	No	Nov-17		
	D. Method 531.1	Triennially	No	Nov-17		
	E. Method 547	Triennially	No	Nov-17		
	F. Method 548	Triennially	No	Nov-17		
	G. Method 549	Triennially	No	Nov-17		
5	Nitrate	Annually	N/A	Jul-17		
6	Nitrite	Triennially	N/A	Jul-17		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>August 25, 2017</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2017</u>
E Lead - 90% Level	<u>2.6</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.165</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>0.44</u> mg/l
D Running Annual Average:	<u>0.48</u> mg/l
E Date of last DBP test:	<u>August 7, 2017</u>
F THM - Qtr Average:	<u>10.7</u> ug/l
G Haa5 - Qtr Average:	<u>3.99</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Colome

EPA ID: 0094

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Failure to Monitor	VOCs - Toluene	01/01/2014	Public Notice Requested
	VOCs - Toluene		Compliance Achieved
Failure to Monitor	VOCs - Trichloroethylene	01/01/2014	Public Notice Requested
	VOCs - Trichloroethylene		Compliance Achieved
Failure to Monitor	VOCs - 1,2 Dichloroethane	01/01/2014	Public Notice Requested
	VOCs - 1,2 Dichloroethane		Compliance Achieved
Failure to Monitor	VOCs - p-Dichlorobenzene	01/01/2014	Public Notice Requested
	VOCs - p-Dichlorobenzene		Compliance Achieved
Failure to Monitor	VOCs - Benzene	01/01/2014	Public Notice Requested
	VOCs - Benzene		Compliance Achieved
Failure to Monitor	VOCs - 1,2 Dichloropropane	01/01/2014	Public Notice Requested
	VOCs - 1,2 Dichloropropane		Compliance Achieved
Failure to Monitor	VOCs - trans 1,2 Dichloroethylene	01/01/2014	Public Notice Requested
	VOCs - trans 1,2 Dichloroethylene		Compliance Achieved
Failure to Monitor	VOCs - o-Dichlorobenzene	01/01/2014	Public Notice Requested
	VOCs - o-Dichlorobenzene		Compliance Achieved
Failure to Monitor	VOCs - Styrene	01/01/2014	Public Notice Requested
	VOCs - Styrene		Compliance Achieved
Failure to Monitor	VOCs - Chlorobenzene	01/01/2014	Public Notice Requested
	VOCs - Chlorobenzene		Compliance Achieved
Failure to Monitor	VOCs - Carbon Tetrachloride	01/01/2014	Public Notice Requested
	VOCs - Carbon Tetrachloride		Compliance Achieved
Failure to Monitor	VOCs - 1,1 Dichloroethylene	01/01/2014	Public Notice Requested
	VOCs - 1,1 Dichloroethylene		Compliance Achieved
Failure to Monitor	VOCs - Total Xylenes	01/01/2014	Public Notice Requested
	VOCs - Total Xylenes		Compliance Achieved
Failure to Monitor	VOCs - 1,1,2 Trichloroethane	01/01/2014	Public Notice Requested
	VOCs - 1,1,2 Trichloroethane		Compliance Achieved
Failure to Monitor	VOCs - 1,2,4 Trichlorobenzene	01/01/2014	Public Notice Requested
	VOCs - 1,2,4 Trichlorobenzene		Compliance Achieved
Failure to Monitor	VOCs - Dichloromethane	01/01/2014	Public Notice Requested
	VOCs - Dichloromethane		Compliance Achieved
Failure to Monitor	VOCs - Ethylbenzene	01/01/2014	Public Notice Requested
	VOCs - Ethylbenzene		Compliance Achieved
Failure to Monitor	VOCs - Tetrachloroethylene	01/01/2014	Public Notice Requested
	VOCs - Tetrachloroethylene		Compliance Achieved
Failure to Monitor	VOCs - 1,1,1 Trichloroethane	01/01/2014	Public Notice Requested
	VOCs - 1,1,1 Trichloroethane		Compliance Achieved
Failure to Monitor	VOCs - Vinyl Chloride	01/01/2014	Public Notice Requested
	VOCs - Vinyl Chloride		Compliance Achieved
Failure to Monitor	VOCs - cis 1,2 Dichloroethylene	01/01/2014	Public Notice Requested
	VOCs - cis 1,2 Dichloroethylene		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0094 System Name: Town of Colome

Sampler- Mr Dave Witt Work Phone-(605)842-0853
Title- Utilities Manager
Address- PO Box 237
Colome SD 57528-0237

Location- City: Colome County: Tripp
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Groundwater Supply

Population Served- 296 Service Connections- 150

Sources for Colome

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1974	55	8	Permanent	Groundwater	Vulnerable	Treatment At Plant
02	#2	1974	55	8	Emergency	Groundwater	Vulnerable	No Treatment
03	TRIPP COUNTY RWS	1983			Emergency	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
05	TREAT SITE - WELL #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Gas Chlorine

EPA ID#: 0094 System Name: Town of Colome

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	12/01/82	243	343	7.30	150	0	4	3.3	62.5	2.5	0.02	0.02	4.9	12	183	0	166	-0.49	3.8	0.36
02	Raw	12/01/82	224	312	7.00	126	0	3	2.9	57.0	1.4	1.21	0.07	5.0	12	154	0	148	-0.90	4.6	0.28
03	Raw	08/24/83	269	388	7.62	145	0	13	5.6	57.1	6.9	0.02	0.02	5.6	12	177	0	171	-0.26	6.4	0.00
02	Raw	10/23/02	252	371	7.77	169	0	3	3.7	70.5	2.4	0.03	0.02	3.0	10	206	0	186	+0.36	2.5	0.37
01	Raw	10/22/02	255	385	7.68	168	0	3	3.6	69.3	2.2	0.03	0.02	3.0	10	205	0	182	+0.26	2.4	0.43
02	Raw	10/26/05	196	271	8.22	122	0	2	3.4	51.9	0.9	0.03	0.02	3.0	15	149	0	133	+0.55	2.6	0.38
01	Raw	10/26/05	243	342	7.46	165	0	2	3.4	67.6	2.1	0.03	0.02	3.0	10	201	0	177	+0.02	2.2	0.43
Averages			240	345	7.58	149	0	4	3.7	62.3	2.6	0.20	0.03	3.9	12	182	0	166		3.5	0.32

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
05	Treated	06/21/00	228	316	7.84	142	0	2	2.8	59.5	1.8	0.02	0.02	3.0	10	173	0	156	+0.29	2.5	0.30
05	Treated	02/14/12	245	342	7.60	156	0	3	3.2	60.5	2.7	0.08	0.14	3.0	10	190	0	162	+0.09	2.7	0.41
05	Treated	06/04/15	232	328	7.63	152	0	4	4.4	59.2	3.4	0.00	0.03	0.0	0	185	0	161	+0.10	2.6	0.66
Averages			235	329	7.69	150	0	3	3.5	59.7	2.6	0.03	0.06	2.0	7	183	0	160		2.6	0.46

You can contact us by calling
(605)842-0853 or write us at
PO Box 237
Colome SD 57528-0237

Town of Colome

2017 Drinking Water Report

It's your tap water!



EPA ID: 0094



Water Quality

Last year, the Town of Colome monitored your drinking water for possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source

We serve more than 296 customers an average of 22,200 gallons of water per day. Our water is groundwater that we produce from local wells. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Colome public water supply system is low.

For more information about your water and information on opportunities to participate in public meetings, call (605)842-0853 and ask for Carol Moyer.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Colome public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2017 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

2017 Table of Detected Contaminants For Colome (EPA ID 0094)

Terms and abbreviations used in this table:

- * *Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*
- * *Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*
- * *Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.*
- * *Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU*
- * *Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.*

Units:

- *MFL: million fibers per liter
- *mrem/year: millirems per year(a measure of radiation absorbed by the body)
- *NTU: Nephelometric Turbidity Units
- *pCi/l: picocuries per liter(a measure of radioactivity)
- *ppm: parts per million, or milligrams per liter(mg/l)
- *ppb: parts per billion, or micrograms per liter(ug/l)
- *ppt: parts per trillion, or nanograms per liter
- *ppq: parts per quadrillion, or picograms per liter
- *pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.2	0	08/25/17	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	3	0	08/25/17	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Haloacetic Acids (RAA)	3.99		08/07/17	60	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Nitrate (as Nitrogen)	2.4		07/11/17	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Total trihalomethanes (RAA)	10.7		08/07/17	80	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.

Please direct questions regarding this information to Mr Dave Witt with the Colome public water system at (605)842-0853.