

City of Freeman Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	1,298	System Population:	1,298
Certified Operator:	Mr Duane Walter PO Box 178 Freeman, SD 57029-0178	Work Phone:	(605)925-7127
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	duane@cityoffreeman.org
Financial Contact:	Mr Adam Van Ningen PO Box 178 Freeman, SD 57029-0178	Work Phone:	(605)925-7127
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	adam@cityoffreeman.org
Other Contacts:	Mayor Sam Sorensen PO Box 178 Freeman, SD 57029-0178	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	April 11, 2017		
Type of System:	Community	Area Served:	Hutchinson County
Number of Service Connections:	611	Contamination Risk:	low
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>24</u>
B Samples required:	<u>Two Samples Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>24</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>August 2, 2017</u>
B Samples required:	<u>10</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2017</u>
E Lead - 90% Level	<u>0.7</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>24</u>
B Samples required:	<u>Two Samples Each Month.</u>
C Last Qtr Cl Residual:	<u>0.57</u> mg/l
D Running Annual Average:	<u>0.69</u> mg/l
E Date of last DBP test:	<u>August 14, 2017</u>
F THM - Qtr Average:	<u>31.7</u> ug/l
G Haa5 - Qtr Average:	<u>23.7</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Freeman

EPA ID: 0134

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	04/01/2016	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0134 System Name: City of Freeman

Sampler- Mr Duane Walter Work Phone-(605)925-7127
 Title- Utilities Manager
 Address- PO Box 178
 Freeman SD 57029-0178

Location- City: Freeman County: Hutchinson
 Service Area- Municipality
 PWS Owner Type- Local Government
 Water Supply Type- Purchased Surface Water Supply

Population Served- 1,298 Service Connections- 611

Sources for Freeman

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
03	WEST	1985	180	8	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
04	LAYNE	1967	180	10	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
05	TREATMENT PLANT				Emergency	Treatment Plant	Non-Vulnerable	Aeration Coagulation, Softening - KMnO4 Disinfection - Gas Chlorine Filtration - Anthrafilter Corrosion Control - Fluoridation - H2SiF6
06	B-Y RWS	1996			Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
09	SUBMERSIBLE	1972	180	8	Emergency	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 0134 System Name: City of Freeman

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Raw	12/12/89	1823	2100	7.21	353	0	209	25.1	235.0	64.7	0.99	0.20	14.0	877	431	0	853	+0.25	0.1	0.62
02	Raw	11/20/91	0	0	0.00	0	0	0	0.0	0.0	0.0	2.26	0.18	0.0	0	0	0	900	0.00	0.0	0.00
04	Raw	08/16/88	1879	2255	7.17	381	0	216	23.4	252.0	70.3	2.52	0.19	16.4	1013	465	0	919	+0.27	0.1	0.59
Averages			1234	1452	4.79	245	0	142	16.2	162.3	45.0	1.92	0.19	10.1	630	299	0	891		0.1	0.40

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
01	Treated	12/12/89	1841	2100	7.64	330	0	211	25.5	236.0	64.7	0.20	0.18	20.3	881	403	0	856	+0.65	1.6	1.81
02	Treated	11/20/91	1737	2205	7.47	370	0	205	21.6	217.0	62.7	0.27	0.05	16.9	867	451	0	800	+0.48	1.1	0.64
Averages			1789	2153	7.56	350	0	208	23.6	226.5	63.7	0.24	0.12	18.6	874	427	0	828		1.4	1.23

You can contact us by calling
(605)925-7127 or write us at
PO Box 178
Freeman SD 57029-0178

City of Freeman

2017 Drinking Water Report

It's your tap water!



EPA ID: 0134



Water Quality

Last year, the City of Freeman monitored your drinking water for possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source

We serve more than 1,298 customers an average of 139,000 gallons of water per day. Our water is surface water that we purchase from another water system. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Freeman public water supply system is low.

For more information about your water and information on opportunities to participate in public meetings, call (605)925-7127 and ask for Adam Van Ningen.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Freeman public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2017 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

The City of Freeman public water system purchases 100% of their water from Bon Homme-Yankton RWS (0865).

2017 Table of Detected Contaminants For Freeman (EPA ID 0134)

Terms and abbreviations used in this table:

- * Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- * Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- * Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.
- * Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU
- * Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.

Units:

- *MFL: million fibers per liter
- *pCi/l: picocuries per liter(a measure of radioactivity)
- *ppt: parts per trillion, or nanograms per liter
- *mrem/year: millirems per year(a measure of radiation absorbed by the body)
- *ppm: parts per million, or milligrams per liter(mg/l)
- *ppq: parts per quadrillion, or picograms per liter
- *NTU: Nephelometric Turbidity Units
- *ppb: parts per billion, or micrograms per liter(ug/l)
- *pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.0	0	08/02/17	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	1	0	08/02/17	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Antimony *	0.3		05/13/13	6	6	ppb	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Arsenic *	3		05/13/13	10	0	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium *	0.014		05/13/13	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Chromium *	1.7		05/13/13	100	100	ppb	Discharge from steel and pulp mills; erosion of natural deposits.
Fluoride *	0.84	0.41 - 0.84	12/11/17	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Haloacetic Acids (RAA)	23.7		08/14/17	60	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Haloacetic Acids (RAA) *	20.30		12/05/17	60	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Selenium *	1.9		05/13/13	50	50	ppb	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Total trihalomethanes (RAA)	31.7		08/14/17	80	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Total trihalomethanes (RAA) *	34.33		12/05/17	80	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
-----------	------------------------	-------	-------------	-----------------------------	-------------------	-------	-----------------------------

Please direct questions regarding this information to Mr Duane Walter with the Freeman public water system at (605)925-7127.

* Bon Homme-Yankton RWS (0865) test result.