

City of Huron Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

| | | | |
|---------------------------------------|---|----------------------------|-------------------------------|
| Population Served: | 12,592 | System Population: | 12,592 |
| Certified Operator: | Mr Vince Juelfs PO Box 1369 Huron, SD 57350 | Work Phone: | (605)353-8547 |
| | | Home Phone: | |
| | | Cell Phone: | |
| | | Fax: | |
| | | Email: | wasteh2o@huronsd.com |
| Financial Contact: | Ms Pullyn Carey PO Box 1369 Huron, SD 57350-1369 | Work Phone: | (605)352-6639 |
| | | Home Phone: | |
| | | Cell Phone: | |
| | | Fax: | (605)353-8506 |
| | | Email: | financeofficer@huronsd.com |
| Other Contacts: | Mayor Paul Aylward PO Box 1369 Huron, SD 57350-1369 | Work Phone: | |
| | | Home Phone: | |
| | | Cell Phone: | |
| | | Fax: | |
| | | Email: | |
| Last Inspection: | August 30, 2017 | | |
| Type of System: | Community | Area Served: | Beadle County |
| Number of Service Connections: | 5,134 | Contamination Risk: | low |
| Water Purchased From: | | | Mid-Dakota Rural Water (2175) |
| PWS Owner Type: | Local Government | Service Area: | Municipality |
| Contract Laboratory: | | | State Health Lab, Pierre |

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

| | | |
|---|----------------------|--------------------------------|
| A | Samples submitted: | <u>120</u> |
| B | Samples required: | <u>Ten Samples Each Month.</u> |
| C | Survey samples: | <u>0</u> |
| D | Safe samples: | <u>120</u> |
| E | Unsafe samples: | <u>0</u> |
| F | Repeat samples: | <u>0</u> |
| H | Groundwater Samples: | <u></u> |

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

| | | |
|---|--------------------|-------------------------------------|
| A | Date Last Tested: | <u>July 6, 2017</u> |
| B | Samples required: | <u>30</u> |
| C | Sampling Frequency | <u>Triennially</u> |
| D | Date Due Next | <u>2017</u> |
| E | Lead - 90% Level | <u>6.7</u> Action Level - 15 ug/l |
| F | Copper 90% Level | <u>0.53</u> Action Level - 1.3 mg/l |

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

| | | |
|---|-------------------------|--------------------------------|
| A | Samples submitted: | <u>120</u> |
| B | Samples required: | <u>Ten Samples Each Month.</u> |
| C | Last Qtr Cl Residual: | <u>3.22</u> mg/l |
| D | Running Annual Average: | <u>3.12</u> mg/l |
| E | Date of last DBP test: | <u>November 15, 2017</u> |
| F | THM - Qtr Average: | <u>31.28</u> ug/l |
| G | Haa5 - Qtr Average: | <u>14.98</u> ug/l |

Asbestos

| | | |
|---|--------------------|--------------------------------------|
| A | Date of last test: | <u>Waiver - Testing Not Required</u> |
| B | Asbestos Result: | <u></u> million fibers per liter |

Comments

Violations and Significant Deficiencies

City of Huron

EPA ID: 0169

Violations From **January 1, 2013** To **January 1, 2018**

| Violation Type | Parameter | Date | Status |
|----------------|-----------|------|--------|
| No Violations | | | |
| | | | |

| Significant Deficiency | Date Identified | Date Corrected |
|------------------------|-----------------|----------------|
| | | |
| | | |

EPA ID#: 0169 System Name: City of Huron

Sampler- Mr Vince Juelfs Work Phone-(605)353-8547
 Title- Water Superintendent
 Address- PO Box 1369
 Huron SD 57350

Location- City: Huron County: Beadle
 Service Area- Municipality
 PWS Owner Type- Local Government
 Water Supply Type- Purchased Surface Water Supply

Population Served- 12,592 Service Connections- 5,134

Sources for Huron

| Source | Name | Year Built | Depth (feet) | Diameter (inches) | Availability | Type | Vulnerability | Treatment |
|--------|-------------------|------------|--------------|-------------------|--------------|-------------------|----------------|--|
| 01 | JAMES RIVER | 0000 | 0000 | 0000 | | Surface Water | Vulnerable | Treatment At Plant |
| 02 | #1 | 1957 | 0089 | 0018 | | Groundwater | Non-Vulnerable | No Treatment |
| 03 | #2 | 1957 | 0089 | 0018 | | Groundwater | Non-Vulnerable | No Treatment |
| 04 | #3 | 1978 | 0080 | 0016 | | Groundwater | Non-Vulnerable | No Treatment |
| 05 | #4 | 1983 | 86 | 16 | Permanent | Groundwater | Non-Vulnerable | Treatment At Plant |
| 06 | #6 | 1983 | 96 | 16 | Permanent | Groundwater | Non-Vulnerable | Treatment At Plant |
| 07 | #7 | 1983 | 91 | 16 | Permanent | Groundwater | Non-Vulnerable | Treatment At Plant |
| 08 | #8 | 1983 | 94 | 16 | Permanent | Groundwater | Non-Vulnerable | Treatment At Plant |
| 09 | #9 | 1983 | 81 | 16 | Permanent | Groundwater | Non-Vulnerable | Treatment At Plant |
| 10 | #10 | 1983 | 81 | 16 | Permanent | Groundwater | Non-Vulnerable | Treatment At Plant |
| 11 | OLD JAMES R PLANT | | | | | Treatment Plant | Non-Vulnerable | Aeration Coagulation, Softening - Alum KMnO4 Lime Polymers Disinfection - Gas Chlorine Filtration - Anthrafilter Corrosion Control - Phosphates Mixing Device Ammoniation - Ammonia Gas Recarbonation Sedimentation Fluoridation - Na2SiF6 |
| 16 | NEW GW WTP | 2003 | | | Permanent | Treatment Plant | Non-Vulnerable | Aeration Coagulation, Softening - KMnO4 Disinfection - Gas Chlorine Filtration - Green Sand Corrosion Control - Phosphates Sedimentation Fluoridation - H2SiF6 |
| 17 | MID-DAKOTA RWS | 2003 | | | Permanent | Purchased Surface | Non-Vulnerable | Water Treated By Seller - Purchased Surface Only |

EPA ID#: 0169 System Name: City of Huron

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

| Source | Type | Date | TDS | Conductance | pH | Alk-M | Alk-P | Na | K | Ca | Mg | Fe | Mn | Cl | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F |
|----------|------|----------|------|-------------|------|-------|-------|-----|------|-------|------|-------|------|------|-----|------|-----|----------|----------|-----|------|
| 11 | Raw | 06/10/94 | 663 | 927 | 8.28 | 281 | 0 | 85 | 15.9 | 75.3 | 41.6 | 0.98 | 0.42 | 55.5 | 208 | 343 | 0 | 359 | +1.12 | 0.1 | 0.00 |
| 11 | Raw | 09/22/97 | 657 | 984 | 8.13 | 253 | 0 | 71 | 16.8 | 72.0 | 44.6 | 2.08 | 0.48 | 35.0 | 240 | 309 | 0 | 363 | +0.81 | 0.3 | 0.25 |
| 11 | Raw | 10/06/99 | 1318 | 1850 | 7.58 | 401 | 0 | 282 | 15.6 | 102.0 | 36.5 | 1.82 | 0.55 | 38.6 | 541 | 489 | 0 | 405 | +0.52 | 0.1 | 0.29 |
| 11 | Raw | 06/25/03 | 944 | 1350 | 8.27 | 299 | 0 | 122 | 22.0 | 94.1 | 60.0 | 0.55 | 1.23 | 67.0 | 371 | 365 | 0 | 482 | +1.09 | 0.1 | 0.27 |
| 16 | Raw | 06/09/09 | 1252 | 1840 | 7.68 | 458 | 0 | 316 | 11.9 | 84.5 | 25.5 | 1.60 | 0.66 | 34.0 | 515 | 559 | 0 | 316 | +0.60 | 0.2 | 0.35 |
| 16 | Raw | 07/07/11 | 1284 | 1830 | 7.71 | 355 | 0 | 282 | 12.0 | 87.8 | 28.5 | 1.40 | 0.67 | 37.0 | 557 | 433 | 0 | 336 | +0.54 | 0.2 | 0.36 |
| 16 | Raw | 11/05/14 | 570 | 1950 | 7.55 | 454 | 0 | 304 | 13.5 | 99.0 | 31.6 | 31.80 | 2.16 | 37.0 | 570 | 554 | 0 | 377 | +0.53 | 0.0 | 0.35 |
| Averages | | | 955 | 1533 | 7.89 | 357 | 0 | 209 | 15.4 | 87.8 | 38.3 | 5.75 | 0.88 | 43.4 | 429 | 436 | 0 | 377 | | 0.1 | 0.27 |

| Source | Type | Date | TDS | Conductance | pH | Alk-M | Alk-P | Na | K | Ca | Mg | Fe | Mn | Cl | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F |
|----------|---------|----------|------|-------------|------|-------|-------|-----|------|------|------|------|------|------|-----|------|-----|----------|----------|-----|------|
| 11 | Treated | 06/10/94 | 492 | 714 | 8.37 | 57 | 0 | 86 | 16.6 | 31.5 | 20.0 | 0.04 | 0.02 | 57.4 | 249 | 67 | 0 | 161 | +0.16 | 0.1 | 0.00 |
| 11 | Treated | 09/22/97 | 509 | 804 | 8.48 | 61 | 1 | 70 | 16.5 | 52.0 | 18.1 | 0.06 | 0.02 | 38.0 | 260 | 73 | 1 | 204 | +0.43 | 0.3 | 1.36 |
| 11 | Treated | 10/06/99 | 780 | 1200 | 8.81 | 92 | 10 | 188 | 15.3 | 26.0 | 21.3 | 0.04 | 0.02 | 48.0 | 392 | 88 | 12 | 153 | +0.59 | 0.1 | 1.39 |
| 11 | Treated | 06/25/03 | 830 | 1240 | 9.03 | 82 | 11 | 184 | 19.6 | 55.6 | 10.0 | 0.04 | 0.02 | 61.0 | 424 | 73 | 13 | 180 | +1.08 | 0.2 | 1.16 |
| 16 | Treated | 06/21/06 | 1299 | 1880 | 7.63 | 419 | 0 | 308 | 15.8 | 94.1 | 28.4 | 0.03 | 0.02 | 37.0 | 550 | 511 | 0 | 352 | +0.56 | 0.1 | 0.97 |
| 16 | Treated | 06/09/09 | 1267 | 1880 | 7.89 | 447 | 0 | 312 | 12.6 | 83.8 | 25.3 | 0.03 | 0.02 | 38.0 | 521 | 545 | 0 | 313 | +0.80 | 0.2 | 0.36 |
| 16 | Treated | 07/07/11 | 679 | 1020 | 8.10 | 226 | 0 | 126 | 6.7 | 65.0 | 22.9 | 0.03 | 0.04 | 21.0 | 292 | 276 | 0 | 256 | +0.68 | 0.2 | 1.05 |
| 16 | Treated | 11/05/14 | 773 | 1160 | 8.00 | 234 | 0 | 138 | 7.7 | 67.9 | 29.2 | 0.00 | 0.00 | 19.0 | 360 | 285 | 0 | 290 | +0.60 | 0.0 | 0.97 |
| Averages | | | 829 | 1237 | 8.29 | 202 | 3 | 176 | 13.9 | 59.5 | 21.9 | 0.03 | 0.02 | 39.9 | 381 | 240 | 3 | 239 | | 0.2 | 0.91 |

You can contact us by calling
(605)352-6639 or write us at
PO Box 1369
Huron SD 57350-1369

City of Huron

2017 Drinking Water Report

It's your tap water!



EPA ID: 0169



Water Quality



Secretary's Award

The City of Huron has supplied seventeen consecutive years of safe drinking water to the public it serves and has been awarded the Secretary's Award for Drinking Water Excellence by the South Dakota Department of Environment and Natural Resources. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source

We serve more than 12,592 customers an average of 2,557,000 gallons of water per day. Our water is surface water that we purchase from another water system. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Huron public water supply system is low.

For more information about your water and information on opportunities to participate in public meetings, call (605)352-6639 and ask for Paullyn Carey.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Huron public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2017 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

The City of Huron public water system purchases 77% of their water from Mid-Dakota Rural Water (2175).

2017 Table of Detected Contaminants For Huron (EPA ID 0169)

Terms and abbreviations used in this table:

* Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

* Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

* Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU

* Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.

Units:

*MFL: million fibers per liter

*pCi/l: picocuries per liter(a measure of radioactivity)

*ppt: parts per trillion, or nanograms per liter

*mrem/year: millirems per year(a measure of radiation absorbed by the body)

*ppm: parts per million, or milligrams per liter(mg/l)

*ppq: parts per quadrillion, or picograms per liter

*NTU: Nephelometric Turbidity Units

*ppb: parts per billion, or micrograms per liter(ug/l)

*pspm: positive samples per month

| Substance | 90% Level | Test Sites > Action Level | Date Tested | Highest Level Allowed (AL) | Ideal Goal | Units | Major Source of Contaminant |
|-----------|-----------|---------------------------|-------------|----------------------------|------------|-------|---|
| Copper | 0.5 | 0 | 06/27/17 | AL=1.3 | 0 | ppm | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. |
| Lead | 7 | 0 | 06/29/17 | AL=15 | 0 | ppb | Corrosion of household plumbing systems; erosion of natural deposits. |

| Substance | Highest Level Detected | Range | Date Tested | Highest Level Allowed (MCL) | Ideal Goal (MCLG) | Units | Major Source of Contaminant |
|--------------------------|------------------------|-------------|-------------|-----------------------------|-------------------|-------|--|
| Alpha emitters * | 4 | ND - 4 | 09/27/16 | 15 | 0 | pCi/l | Erosion of natural deposits. |
| Antimony * | 0.4 | | 03/19/13 | 6 | 6 | ppb | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder. |
| Arsenic * | 3 | | 03/19/13 | 10 | 0 | ppb | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes. |
| Barium * | 0.042 | | 03/19/13 | 2 | 2 | ppm | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits. |
| Chromium * | 1.6 | | 03/19/13 | 100 | 100 | ppb | Discharge from steel and pulp mills; erosion of natural deposits. |
| Fluoride | 0.53 | 0.44 - 0.53 | 07/12/17 | 4 | 4 | ppm | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories. |
| Fluoride * | 0.50 | | 10/27/17 | 4 | 4 | ppm | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories. |
| Haloacetic Acids (RAA) | 19.75 | | 11/15/17 | 60 | 0 | ppb | By-product of drinking water chlorination. Results are reported as a running annual average of test results. |
| Haloacetic Acids (RAA) * | 23.60 | | 11/29/17 | 60 | 0 | ppb | By-product of drinking water chlorination. Results are reported as a running annual average of test results. |
| Nitrate (as Nitrogen) * | 0.3 | | 03/24/17 | 10 | 10 | ppm | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits. |

| Substance | Highest Level Detected | Range | Date Tested | Highest Level Allowed (MCL) | Ideal Goal (MCLG) | Units | Major Source of Contaminant |
|-------------------------------|------------------------|-------|-------------|-----------------------------|-------------------|-------|--|
| Selenium * | 1.4 | | 03/19/13 | 50 | 50 | ppb | Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines. |
| Total trihalomethanes (RAA) | 32.45 | | 11/15/17 | 80 | 0 | ppb | By-product of drinking water chlorination. Results are reported as a running annual average of test results. |
| Total trihalomethanes (RAA) * | 40.33 | | 11/29/17 | 80 | 0 | ppb | By-product of drinking water chlorination. Results are reported as a running annual average of test results. |

Please direct questions regarding this information to Mr Vince Juelfs with the Huron public water system at (605)352-6639.

* Mid-Dakota Rural Water (2175) test result.