

Edelweiss Mountain Improvement Assoc Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served: 70 **System Population:** 172

Certified Operator: Mr Ed Striebel
7005 Timberline Road
Black Hawk, SD 57718
Work Phone: (605)787-5653
Home Phone: (605)787-5653
Cell Phone:
Fax: (605)787-5653
Email: estriebel@rap.midco.net

Financial Contact: Ms Catherine Haveman
PO Box 2128
Rapid City, SD 57709
Work Phone:
Home Phone:
Cell Phone:
Fax:
Email:

Other Contacts: Mr Greg Howe
205 Alpine Drive
Rapid City, SD 57702
Work Phone: (605)574-3642
Home Phone: (605)574-3642
Cell Phone:
Fax:
Email: emiamngr@wildblue.net

Last Inspection: May 25, 2016

Type of System: Community **Area Served:** Pennington County

Number of Service Connections: 70 **Contamination Risk:** moderate

Water Produced And Used By The Edelweiss Mountain Improvement Assoc Public Water System

PWS Owner Type: Private Ownership **Service Area:** Housing Development

Contract Laboratory: Midcontinent Laboratory

Monitoring/Reporting - Entry Point

Edelweiss Mountain Improvement Assoc

EPA ID: 0273

SAMPLING

Entry point: Entry Pt For 3 Wells

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Mar-12		
	B. Arsenic	Every nine years	Yes	Mar-12		
	C. Barium	Every nine years	Yes	Mar-12		
	D. Beryllium	Every nine years	Yes	Mar-12		
	E. Cadmium	Every nine years	Yes	Mar-12		
	F. Chromium	Every nine years	Yes	Mar-12		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Mar-12		
	I. Mercury	Every nine years	Yes	Mar-12		
	J. Nickel	Every nine years	Yes	Mar-12		
	K. Selenium	Every nine years	Yes	Mar-12		
	L. Thallium	Every nine years	Yes	Mar-12		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Quarterly	No	Nov-15	2018	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jul-15	2018	
	B. Method 524	Triennially	No	Jul-15	2018	
	C. Method 525	Triennially	No	Jul-15	2018	
	D. Method 531.1	Triennially	No	Jul-15	2018	
	E. Method 547	Triennially	No	Jul-15	2018	
	F. Method 548	Triennially	No	Jul-15	2018	
	G. Method 549	Triennially	No	Jul-15	2018	
5	Nitrate	Annually	N/A	Sep-17		
6	Nitrite	Triennially	N/A	Aug-16		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 2, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>5</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.095</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1</u> mg/l
D	Running Annual Average:	<u>1</u> mg/l
E	Date of last DBP test:	<u>September 17, 2015</u>
F	THM - Qtr Average:	<u>8.51</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Edelweiss Mountain Improvement Assoc

EPA ID: 0273

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0273 System Name: Edelweiss Mountain Improvement Assoc

Sampler- Mr Ed Striebel Work Phone-(605)787-5653
Title- Clearwater Consultin
Address- 7005 Timberline Road
Black Hawk SD 57718

Location- City: Rapid City County: Pennington
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 172 Service Connections- 70

Sources for Edelweiss Mountain Improvement Assoc

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1 (ALPINE DRIVE)	1976	203	6	Permanent	Groundwater	Vulnerable	Treatment At Plant
02	#2 (MAIN GATE)	1977	417	6	Permanent	Groundwater	Vulnerable	Treatment At Plant
03	ENTRY PT FOR 3 WELLS				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#3 (BEAR GULCH)	1994	323	6	Permanent	Groundwater	Vulnerable	Treatment At Plant

EPA ID#: 0273 System Name: Edelweiss Mountain Improvement Assoc

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
03	Raw	03/23/95	202	350	7.30	136	0	7	1.0	32.0	18.0	0.05	0.03	5.0	30	166	0	154	+0.50	0.3	0.25
03	Raw	10/03/00	276	435	7.22	152	0	8	3.0	44.0	13.0	0.03	0.01	20.0	32	185	1	163	-0.50	0.2	0.20
Averages			239	393	7.26	144	0	8	2.0	38.0	15.5	0.04	0.02	12.5	31	176	1	159		0.2	0.23

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langelier	NO3	F
03	Treated	09/18/97	208	390	7.40	150	0	6	2.0	47.0	15.0	0.05	0.03	10.0	26	183	0	179	-0.20	0.1	0.25
03	Treated	03/25/04	243	426	7.55	164	0	8	1.0	45.9	17.8	0.07	17.80	14.0	36	200	0	188	-0.07	0.5	0.26
03	Treated	02/08/07	228	428	7.73	170	0	9	1.1	50.1	18.3	0.05	0.03	14.0	34	207	0	200	+0.16	0.6	0.30
03	Treated	06/18/13	212	425	7.44	133	0	11	1.2	55.1	14.5	0.05	0.11	37.0	26	163	0	197	+0.20	0.5	0.15
Averages			223	417	7.53	154	0	9	1.3	49.5	16.4	0.05	4.49	18.8	30	188	0	191		0.4	0.24

You can contact us by calling or
write us at
PO Box 2128
Rapid City SD 57709

Edelweiss Mountain Improvement Assoc

2017 Drinking Water Report

It's your tap water!





Water Quality



Secretary's Award

The Edelweiss Mountain Improvement Assoc has supplied fourteen consecutive years of safe drinking water to the public it serves and has been awarded the Secretary's Award for Drinking Water Excellence by the South Dakota Department of Environment and Natural Resources. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source

We serve more than 172 customers an average of 12,900 gallons of water per day. Our water is groundwater that we produce from local wells. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Edelweiss Mountain Improvement Assoc public water supply system is medium.

For more information about your water and information on opportunities to participate in public meetings, call and ask for Catherine Haveman.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Edelweiss Mountain Improvement Assoc public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2017 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

2017 Table of Detected Contaminants For Edelweiss Mountain Improvement Assoc (EPA ID 0273)

Terms and abbreviations used in this table:

- * Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- * Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- * Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.
- * Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU
- * Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.

Units:

- *MFL: million fibers per liter
- *mrem/year: millirems per year(a measure of radiation absorbed by the body)
- *NTU: Nephelometric Turbidity Units
- *pCi/l: picocuries per liter(a measure of radioactivity)
- *ppm: parts per million, or milligrams per liter(mg/l)
- *ppb: parts per billion, or micrograms per liter(ug/l)
- *ppt: parts per trillion, or nanograms per liter
- *ppq: parts per quadrillion, or picograms per liter
- *pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.1	0	09/02/15	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	5	0	09/01/15	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
-----------	------------------------	-------	-------------	-----------------------------	-------------------	-------	-----------------------------

Data for the water system needs to be added to this table.

Please direct questions regarding this information to Mr Ed Striebel with the Edelweiss Mountain Improvement Assoc public water system.