

Beaver Lake Campground Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Operator Certification Not Required

Population Served: 300 **System Population:** 300

Certified Operator: Mr Max Hammer
12005 W Hwy 16
Custer, SD 57730

Work Phone: (605)673-2464
Home Phone: (605)673-2308
Cell Phone:
Fax:
Email: beaverlake@gwtc.net

Financial Contact: Mr Max Hammer
12005 W Hwy 16
Custer, SD 57730

Work Phone: (605)673-2464
Home Phone:
Cell Phone:
Fax:
Email:

Other Contacts:

Last Inspection: July 3, 2013

Type of System: Non-Community

Area Served: Custer County

Number of Service Connections: 6

Contamination Risk: high

Water Produced And Used By The Beaver Lake Campground Public Water System

PWS Owner Type: Private Ownership

Service Area: Recreation Area

Contract Laboratory: Midcontinent Laboratory

Violations and Significant Deficiencies

Beaver Lake Campground

EPA ID: 0529

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Exceedance of Allowable Contaminant Level	Nitrate	01/01/2016	Public Notice Requested
	Nitrate		Public Notice Received
	Nitrate		Compliance Achieved
Failure to Develop Sample Site Plan	RTCR	06/01/2016	Reminder Notice
	RTCR		Compliance Achieved
Exceedance of Allowable Contaminant Level	Total Coliform Bacteria	05/01/2014	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0529 System Name: Beaver Lake Campground

Sampler- Mr Max Hammer Work Phone-(605)673-2464
Title- Beaver Lake Cg
Address- 12005 W Hwy 16
Custer SD 57730

Location- City: Custer County: Custer
Service Area- Recreation Area
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 300 Service Connections- 96

Months that System is Open to Public-Season Opening Date- March 15th Season Closing Date- October 31st

Sources for Beaver Lake Campground

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1983	200	6	Permanent	Groundwater	Vulnerable	No Treatment
03	#2	2003	270	6	Permanent	Groundwater	Non-Vulnerable	No Treatment
04	ENTRY #1 & #2				Emergency		Non-Vulnerable	No Treatment

EPA ID#: 0529 System Name: Beaver Lake Campground

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	05/12/92	0	0	0.00	0	0	0	0.0	0.0	0.0	0.00	0.00	0.0	0	0	0	0	0.00	4.4	0.00