



# Monitoring/Reporting - Entry Point

Deer Mountain/Union Resort

EPA ID: 0549

## SAMPLING

Entry point: Treatment Plant

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Annually	No	Dec-17		
	B. Arsenic	Annually	No	Dec-17		
	C. Barium	Annually	No	Dec-17		
	D. Beryllium	Annually	No	Dec-17		
	E. Cadmium	Annually	No	Dec-17		
	F. Chromium	Annually	No	Dec-17		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Annually	No	Dec-17		
	I. Mercury	Annually	No	Dec-17		
	J. Nickel	Annually	No	Dec-17		
	K. Selenium	Annually	No	Dec-17		
	L. Thallium	Annually	No	Dec-17		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Triennially	Yes	Feb-15	2018	Surface Water Waiver
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Feb-15	2018	
	B. Method 524	Triennially	No	Feb-15	2018	
	C. Method 525	Triennially	No	Feb-15	2018	
	D. Method 531.1	Triennially	No	Feb-15	2018	
	E. Method 547	Triennially	No	Feb-15	2018	
	F. Method 548	Triennially	No	Feb-15	2018	
	G. Method 549	Triennially	No	Feb-15	2018	
5	Nitrate	Annually-1st Qtr	N/A	Feb-17		
6	Nitrite	Triennially	N/A	Feb-15		

(These values are calculated from available data. Check correspondence for verification.)

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 14, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>2.5</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.235</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.43</u> mg/l
D	Running Annual Average:	<u>2.47</u> mg/l
E	Date of last DBP test:	<u>August 22, 2017</u>
F	THM - Qtr Average:	<u>5.45</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

**Deer Mountain/Union Resort**

**EPA ID: 0549**

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Failure To Address Significant Deficiency On	LT2 ESWTR	06/01/2015	Reminder Notice
	LT2 ESWTR		Compliance Achieved
Failure to Monitor	Nitrate	01/01/2014	Public Notice Requested
	Nitrate		Compliance Achieved
Failure to Issue PN for Violation 00193	Public Notice	04/09/2013	
	Public Notice		Compliance Achieved
Failure to Issue PN for Violation 00191	Public Notice	03/03/2013	
	Public Notice		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected

**EPA ID#: 0549 System Name: Deer Mountain/Union Resort**

Sampler- Mr Steve Ryan Work Phone-  
Title- Water Manager/operat  
Address- 1204 Washington  
Lead SD 57754

Location- City: Deadwood County: Lawrence  
Service Area- Homeowners Association  
PWS Owner Type- Private Ownership  
Water Supply Type- Surface Water Supply

Population Served- 125 Service Connections- 100

**Sources for Deer Mountain/Union Resort**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREATMENT PLANT	1978			Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Filtration -
03	RAW H2O FROM LDSD	1978	0	0	Permanent	Surface Water	Non-Vulnerable	Treatment At Plant

# EPA ID#: 0549 System Name: Deer Mountain/Union Resort

## Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	09/10/96	265	486	8.08	257	0	1	0.5	61.6	30.2	0.06	0.02	3.0	10	314	0	278	+0.79	0.3	0.10
03	Raw	06/20/03	261	479	8.29	269	0	1	0.5	61.9	24.8	0.05	0.05	0.5	10	328	0	15	+1.00	0.5	0.09
03	Raw	06/28/06	243	484	8.31	265	0	1	0.5	58.4	26.1	0.05	0.01	1.8	10	321	0	253	+1.00	0.2	0.10
03	Raw	06/19/12	277	486	8.15	282	0	1	0.4	64.6	29.4	0.03	0.04	3.0	10	344	0	282	+0.92	0.2	0.11
Averages			262	484	8.21	268	0	1	0.5	61.6	27.6	0.05	0.03	2.1	10	327	0	207		0.3	0.10

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	03/13/84	0	0	0.00	0	0	0	0.0	0.0	0.0	0.00	0.00	0.0	0	0	0	0	0.00	0.1	0.00
01	Treated	09/10/96	274	432	8.09	260	0	1	0.4	60.4	29.6	0.06	0.02	3.0	10	317	0	273	+0.79	0.4	0.11
01	Treated	08/25/99	272	498	8.02	269	0	2	0.5	63.5	28.0	0.03	0.01	1.1	10	328	0	274	+0.76	0.0	0.10
01	Treated	06/20/03	252	483	8.17	270	0	2	0.5	64.7	23.8	0.05	0.05	1.3	12	330	0	15	+0.91	0.7	0.09
01	Treated	06/28/06	246	487	8.25	266	0	1	0.5	56.9	25.9	0.05	0.01	1.8	10	324	0	249	+0.93	0.5	0.10
01	Treated	06/23/09	276	497	8.19	277	0	1	0.5	49.3	30.0	0.05	0.01	0.5	12	338	0	247	+0.82	0.5	0.11
01	Treated	08/26/14	277	488	8.24	277	0	2	0.5	66.4	26.2	0.08	0.05	0.0	0	338	0	274	+1.01	0.0	0.10
Averages			228	412	6.99	231	0	1	0.4	51.6	23.4	0.05	0.02	1.1	8	282	0	190		0.3	0.09

You can contact us by calling or  
write us at  
1715 Palo Verde Drive  
Rapid City SD 57701

# Deer Mountain/Union Resort

## 2017 Drinking Water Report

*It's your tap water!*



EPA ID: 0549



# Water Quality

*Last year, the Deer Mountain/Union Resort monitored your drinking water for possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.*

## Water Source

We serve more than 125 customers an average of 9,375 gallons of water per day. We get our water from surface water sources. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Deer Mountain/Union Resort public water supply system is low.

For more information about your water and information on opportunities to participate in public meetings, call and ask for Mark Brockman.

## Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Deer Mountain/Union Resort public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2017 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

## 2017 Table of Detected Contaminants For Deer Mountain/Union Resort (EPA ID 0549)

### Terms and abbreviations used in this table:

- \* Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- \* Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- \* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.
- \* Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU
- \* Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.

### Units:

- \*MFL: million fibers per liter
- \*mrem/year: millirems per year(a measure of radiation absorbed by the body)
- \*NTU: Nephelometric Turbidity Units
- \*pCi/l: picocuries per liter(a measure of radioactivity)
- \*ppm: parts per million, or milligrams per liter(mg/l)
- \*ppb: parts per billion, or micrograms per liter(ug/l)
- \*ppt: parts per trillion, or nanograms per liter
- \*ppq: parts per quadrillion, or picograms per liter
- \*pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.2	0	09/14/15	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	3	0	09/14/15	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Barium	0.074		12/18/17	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride	0.1		12/18/17	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate (as Nitrogen)	0.786		02/14/17	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Total trihalomethanes (RAA)	5.45		08/22/17	80	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.

Please direct questions regarding this information to Mr Steve Ryan with the Deer Mountain/Union Resort public water system.