

Black Hills Chairlift Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	150	System Population:	150
Certified Operator:	Mr Ed Striebel 7005 Timberline Road Black Hawk, SD 57718	Work Phone:	(605)787-5653
		Home Phone:	(605)787-5653
		Cell Phone:	
		Fax:	(605)787-5653
		Email:	estriebel@rap.midco.net
Financial Contact:	Mr Bob Munsell 21120 Stewart Slope Road Lead, SD 57754-3700	Work Phone:	(605)584-2165
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	bmunsell@terrypeak.com
Other Contacts:			
Last Inspection:	February 28, 2013		
Type of System:	Non-Community	Area Served:	Lawrence County
Number of Service Connections:	10	Contamination Risk:	moderate
Water Produced And Used By The Black Hills Chairlift Public Water System			
PWS Owner Type:	Private Ownership	Service Area:	Recreation Area
Contract Laboratory:			Midcontinent Laboratory

Violations and Significant Deficiencies

Black Hills Chairlift

EPA ID: 0595

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
Failure to Develop Sample Site Plan	RTCR	06/01/2016	Reminder Notice
	RTCR		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0595 System Name: Black Hills Chairlift

Sampler- Mr Ed Striebel Work Phone-(605)787-5653
 Title- Water Manager
 Address- 7005 Timberline Road
 Black Hawk SD 57718

Location- City: Lead County: Lawrence
 Service Area- Other Transient Area
 PWS Owner Type- Private Ownership
 Water Supply Type- Groundwater Supply

Population Served- 150 Service Connections- 2

Months that System is Open to Public-Season Opening Date- December 1st Season Closing Date- March 31st

Sources for Black Hills Chairlift

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Emergency	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Filtration - Zeolite
03	TREAT SITE-#2				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Filtration - Zeolite
04	#1	1976			Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
05	#2	1993	145	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 0595 System Name: Black Hills Chairlift

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	02/26/92	0	0	0.00	0	0	0	0.0	0.0	0.0	0.00	0.00	0.0	0	0	0	0	0.00	0.1	0.00