

Battle Creek Resort Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Operator Certification Not Required

Population Served: 50 **System Population:** 50

Certified Operator: Mr Shawn Petersen
45059 260th Street
Canistota, SD 57012

Work Phone: (605)296-3606
Home Phone:
Cell Phone:
Fax:
Email: spete44@hotmail.com

Financial Contact: Mr Shawn Petersen
45059 260th Street
Canistota, SD 57012

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email:

Other Contacts:

Last Inspection: May 14, 2015

Type of System: Non-Community

Area Served: McCook County

Number of Service Connections: 50

Contamination Risk: moderate

Water Produced And Used By The Battle Creek Resort Public Water System

PWS Owner Type: Private Ownership

Service Area: Recreation Area

Contract Laboratory: Sioux Falls Health Laboratory

Violations and Significant Deficiencies

Battle Creek Resort

EPA ID: 0648

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
FTM-Routine Samples	RTCR	09/01/2016	Public Notice Requested
	RTCR		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0648 System Name: Battle Creek Resort

Sampler- Mr Shawn Petersen Work Phone-(605)296-3606
Title- Battlecreek Cg
Address- 45059 260th Street
Canistota SD 57012

Location- City: Canistota County: McCook
Service Area- Recreation Area
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 50 Service Connections- 43

Months that System is Open to Public-Season Opening Date- May 25th Season Closing Date- September 30th

Sources for Battle Creek Resort

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1969	110	6	Permanent	Groundwater	Non-Vulnerable	No Treatment
04	TM RURAL WATER	1999			Emergency	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0648 System Name: Battle Creek Resort

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	03/23/94	0	0	0.00	0	0	0	0.0	0.0	0.0	0.00	0.00	0.0	439	0	0	0	0.00	0.0	0.00
01	Raw	06/23/10	1914	2140	7.47	334	0	35	8.0	313.0	134.0	0.03	0.02	17.0	1020	407	0	1330	+0.76	0.2	0.21
Averages			957	1070	3.74	167	0	17	4.0	156.5	67.0	0.02	0.01	8.5	730	204	0	665		0.1	0.11