

Custer-Mount Rushmore KOA Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Operator Certification Not Required

Population Served:	90	System Population:	90
Certified Operator:	Mr Jim Murray 12021 US Hwy 16 Custer, SD 57730	Work Phone:	(605)673-4304
		Home Phone:	(605)673-4305
		Cell Phone:	
		Fax:	
		Email:	info@custerkoa.com
Financial Contact:	Mr Walter Hodgson 12021 US Hwy 16 Custer, SD 57730	Work Phone:	(605)673-4304
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	info@custerkoa.com
Other Contacts:			
Last Inspection:	July 18, 2013		
Type of System:	Non-Community	Area Served:	Custer County
Number of Service Connections:	64	Contamination Risk:	high
Water Produced And Used By The Custer-Mount Rushmore KOA Public Water System			
PWS Owner Type:	Private Ownership	Service Area:	Recreation Area
Contract Laboratory:			Midcontinent Laboratory

Violations and Significant Deficiencies

Custer-Mount Rushmore KOA

EPA ID: 0650

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Failure to Develop Sample Site Plan	RTCR	06/01/2016	Reminder Notice
	RTCR		Compliance Achieved
Routine Sample Monitoring Violation	Total Coliform Bacteria	07/01/2013	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0650 System Name: Custer-Mount Rushmore KOA

Sampler- Mr Jim Murray Work Phone-(605)673-4304
Title- Custer Mt Rushmore K
Address- 12021 US Hwy 16
Custer SD 57730

Location- City: Custer County: Custer
Service Area- Recreation Area
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 90 Service Connections- 77

Months that System is Open to Public-Season Opening Date- May 1st Season Closing Date- September 30th

Sources for Custer-Mount Rushmore KOA

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT-OLD OFFICE WELL				Emergency	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
02	NEW CG WELL	1978	202	8	Permanent	Groundwater	Non-Vulnerable	No Treatment
05	OLD OFFICE WELL	1970	168	8	Permanent	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 0650 System Name: Custer-Mount Rushmore KOA

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	09/10/92	0	0	0.00	0	0	0	0.0	0.0	0.0	0.00	0.00	0.0	0	0	0	0	0.00	5.0	0.00