

Clark Rural Water System Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	3,967	System Population:	2,130
Certified Operator:	Mr Terry Kaufman PO Box 162 Clark, SD 57225-0162	Work Phone:	(605)532-5201
		Home Phone:	(605)532-5457
		Cell Phone:	
		Fax:	(605)532-3531
		Email:	crws@itctel.com
Financial Contact:	Mr Terry Kautman PO Box 162 Clark, SD 57225-0162	Work Phone:	(605)532-5201
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:	Mr Steve Arnesen 44139 156th Street Florence, SD 57235-5005	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	June 24, 2015		
Type of System:	Community	Area Served:	Codington, Clark, Day, Hamlin County
Number of Service Connections:	865	Contamination Risk:	low
Water Sold To:			Bradley, Clark, Raymond, Wallace, Henry
PWS Owner Type:	Private Ownership	Service Area:	Rural Water System/Colonies
Contract Laboratory:			State Health Lab, Pierre

Monitoring/Reporting - Entry Point

Clark Rural Water System

EPA ID: 0881

SAMPLING

Entry point: Treatment Plant

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Nov-13		
	B. Arsenic	Every nine years	Yes	Nov-13		
	C. Barium	Every nine years	Yes	Nov-13		
	D. Beryllium	Every nine years	Yes	Nov-13		
	E. Cadmium	Every nine years	Yes	Nov-13		
	F. Chromium	Every nine years	Yes	Nov-13		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Every nine years	Yes	Nov-13		
	J. Nickel	Every nine years	Yes	Nov-13		
	K. Selenium	Every nine years	Yes	Nov-13		
	L. Thallium	Every nine years	Yes	Nov-13		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Quarterly	No	Aug-16	2019	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Aug-16	2019	
	B. Method 524	Triennially	No	Aug-16	2019	
	C. Method 525	Triennially	No	Aug-16	2019	
	D. Method 531.1	Triennially	No	Aug-16	2019	
	E. Method 547	Triennially	No	Aug-16	2019	
	F. Method 548	Triennially	No	Aug-16	2019	
	G. Method 549	Triennially	No	Aug-16	2019	
5	Nitrate	Annually	N/A	May-17		
6	Nitrite	Triennially	N/A	May-15		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>24</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 13, 2016</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2019</u>
E	Lead - 90% Level	<u>0.46</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.85</u> mg/l
D	Running Annual Average:	<u>0.7</u> mg/l
E	Date of last DBP test:	<u>August 7, 2017</u>
F	THM - Qtr Average:	<u>40.2</u> ug/l
G	Haa5 - Qtr Average:	<u>10.2</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Clark Rural Water System

EPA ID: 0881

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 0881 System Name: Clark Rural Water System

Sampler- Mr Terry Kaufman Work Phone-(605)532-5201
 Title- Manager
 Address- PO Box 162
 Clark SD 57225-0162

Location- City: Clark County: Codington, Clark, Day, Hamlin
 Service Area- Other residential areas
 PWS Owner Type- Private Ownership
 Water Supply Type- Groundwater Supply

Population Served- 2,130 Service Connections- 865

Sources for Clark Rural Water System

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1979	67	12		Groundwater	Vulnerable	Treatment At Plant
02	#2	1981	52	12	Permanent	Groundwater	Vulnerable	Treatment At Plant
03	#3	1980	47	12	Permanent	Groundwater	Vulnerable	Treatment At Plant
04	#4	1991	53	12	Permanent	Groundwater	Vulnerable	Treatment At Plant
06	TREATMENT PLANT				Permanent	Treatment Plant	Non-Vulnerable	Aeration Coagulation, Softening - Lime Disinfection - Gas Chlorine Filtration - Gravity Mixing Device Recarbonation Sedimentation Fluoridation - H2SiF6
07	#5	1996	77	12		Groundwater	Vulnerable	Treatment At Plant
12	#6	2002	30	12	Permanent	Groundwater	Vulnerable	Treatment At Plant
15	NEW #1	2014	28	12	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
16	NEW #5	2014	28	12	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 0881 System Name: Clark Rural Water System

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
05	Raw	02/22/95	527	880	7.35	295	0	13	5.8	125.9	42.0	1.31	0.46	14.0	200	360	0	487	+0.36	0.3	0.21
02	Raw	04/29/91	636	877	7.44	290	0	19	5.2	128.0	34.5	1.70	0.40	12.4	200	354	0	462	+0.14	2.9	0.20
03	Raw	01/19/89	637	887	7.59	289	0	26	6.1	120.0	41.9	1.27	0.38	10.3	217	353	0	472	+0.30	0.1	0.35
Averages			600	881	7.46	291	0	19	5.7	124.6	39.5	1.43	0.41	12.2	206	356	0	474		1.1	0.25

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
05	Treated	02/22/95	0	0	0.00	0	0	0	0.0	0.0	0.0	0.04	0.02	0.0	0	0	0	0	+0.00	0.0	0.00
06	Treated	03/05/98	656	962	0.00	274	0	16	5.5	123.1	43.2	0.08	0.03	13.0	248	334	0	485	+0.35	0.1	1.32
06	Treated	12/05/00	699	959	7.71	275	0	16	6.4	124.0	43.3	0.02	0.03	9.0	258	336	0	488	+0.65	0.2	1.08
06	Treated	01/23/03	658	960	7.59	280	0	16	5.1	123.0	40.8	0.03	0.02	11.0	239	342	0	475	+0.55	0.1	1.10
06	Treated	12/18/08	673	991	7.77	286	0	16	5.1	125.0	47.2	0.03	0.02	14.0	253	349	0	506	+0.74	0.2	1.35
06	Treated	08/21/13	423	607	7.57	24	0	17	6.2	45.9	37.8	0.03	0.02	6.0	259	29	0	270	-0.92	0.2	1.07
Averages			518	747	5.11	190	0	14	4.7	90.2	35.4	0.04	0.02	8.8	210	232	0	371		0.1	0.99

You can contact us by calling
(605)532-5201 or write us at
PO Box 162
Clark SD 57225-0162

Clark Rural Water System

2017 Drinking Water Report

It's your tap water!



EPA ID: 0881



Water Quality

Last year, the Clark Rural Water System monitored your drinking water for possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source

We serve more than 2,130 customers an average of 860,000 gallons of water per day. Our water is groundwater that we produce from local wells. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Clark Rural Water System public water supply system is low.

For more information about your water and information on opportunities to participate in public meetings, call (605)532-5201 and ask for Terry Kautman.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Clark Rural Water System public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2017 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

2017 Table of Detected Contaminants For Clark Rural Water System (EPA ID 0881)

Terms and abbreviations used in this table:

- * *Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.*
- * *Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*
- * *Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.*
- * *Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU*
- * *Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.*

Units:

- *MFL: million fibers per liter
- *pCi/l: picocuries per liter(a measure of radioactivity)
- *ppt: parts per trillion, or nanograms per liter
- *mrem/year: millirems per year(a measure of radiation absorbed by the body)
- *ppm: parts per million, or milligrams per liter(mg/l)
- *ppq: parts per quadrillion, or picograms per liter
- *NTU: Nephelometric Turbidity Units
- *ppb: parts per billion, or micrograms per liter(ug/l)
- *pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.0	0	08/13/16	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	0	0	08/10/16	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Arsenic	2		11/04/13	10	0	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium	0.009		11/04/13	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Chromium	0.7		11/04/13	100	100	ppb	Discharge from steel and pulp mills; erosion of natural deposits.
Fluoride	0.70	0.52 - 0.70	06/05/17	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Haloacetic Acids (RAA)	10.2		08/07/17	60	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Nitrate (as Nitrogen)	0.4		05/17/17	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Selenium	0.7		11/04/13	50	50	ppb	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Total trihalomethanes (RAA)	40.2		08/07/17	80	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.

Please direct questions regarding this information to Mr Terry Kaufman with the Clark Rural Water System public water system at (605)532-5201.