

Dinosaur Museum Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation , Operator Certification Not Required

Population Served: 125 **System Population:** 125

Certified Operator: Mr Fritz Hoppe
8973 S Highway 16
Rapid City, SD 57702

Work Phone: (605)342-8140
Home Phone:
Cell Phone:
Fax:
Email: fritzhoppe@hotmail.com

Financial Contact: Mr Fred Hoppe
105 Pershing Road
Columbus, NE 68601

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email: dinomuseum@icloud.com

Other Contacts:

Last Inspection: June 30, 2015

Type of System: Non-Community

Area Served: Pennington County

Number of Service Connections: 100

Contamination Risk: moderate

Water Produced And Used By The Dinosaur Museum Public Water System

PWS Owner Type: Private Ownership

Service Area: Restaurant

Contract Laboratory: Midcontinent Laboratory

Violations and Significant Deficiencies

Dinosaur Museum

EPA ID: 1061

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
FTM-Routine Samples	RTCR	08/01/2017	Public Notice Requested
Failure to Complete Start-Up Procedure	RTCR	05/30/2017	Public Notice Requested
	RTCR		Public Notice Received
FTM-Routine Samples	RTCR	06/01/2017	Public Notice Requested
	RTCR		Compliance Achieved
Failure to Issue PN for Violation 00107	Public Notice	10/08/2016	
Failure to Develop Sample Site Plan	RTCR	06/01/2016	Reminder Notice
	RTCR		Compliance Achieved
Failure to Complete Start-Up Procedure	RTCR	06/01/2016	Public Notice Requested
	RTCR		Compliance Achieved
Routine Sample Monitoring Violation	Total Coliform Bacteria	07/01/2015	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		DENR Issued PN

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 1061 System Name: Dinosaur Museum

Sampler- Mr Fritz Hoppe Work Phone-(605)342-8140
Title- Manager
Address- 8973 S Highway 16
Rapid City SD 57702

Location- City: Rapid City County: Pennington
Service Area- Restaurant
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 125 Service Connections- 2

Months that System is Open to Public-Season Opening Date- May 30th Season Closing Date- October 31st

Sources for Dinosaur Museum

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1965	89	6		Groundwater	Non-Vulnerable	No Treatment
02	#2	1992	580	5	Permanent	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 1061 System Name: Dinosaur Museum

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	08/19/96	0	0	0.00	0	0	0	0.0	0.0	0.0	0.00	0.00	0.0	10	0	0	0	0.00	0.2	0.00