

Golden Valley Water Company Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation

Population Served:	138	System Population:	138
Certified Operator:	Mr Ed Striebel 7005 Timberline Road Black Hawk, SD 57718	Work Phone:	(605)787-5653
		Home Phone:	(605)787-5653
		Cell Phone:	
		Fax:	(605)787-5653
		Email:	estriebe1@rap.midco.net
Financial Contact:	Mr Ed Striebel 7005 Timberline Road Black Hawk, SD 57718	Work Phone:	(605)787-5653
		Home Phone:	(605)787-5653
		Cell Phone:	
		Fax:	(605)787-5653
		Email:	estriebe1@rap.midco.net
Other Contacts:	Mr. Kent Hagg PO Box 8452 Rapid City, SD 57702	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	November 24, 2015		
Type of System:	Community	Area Served:	Meade County
Number of Service Connections:	55	Contamination Risk:	moderate
Water Produced And Used By The Golden Valley Water Company Public Water System			
PWS Owner Type:	Private Ownership	Service Area:	Housing Development
Contract Laboratory:			Midcontinent Laboratory

Monitoring/Reporting - Entry Point

Golden Valley Water Company

EPA ID: 2261

SAMPLING

Entry point: Treat Site - Well #1

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Mar-11		
	B. Arsenic	Every nine years	Yes	Mar-11		
	C. Barium	Every nine years	Yes	Mar-11		
	D. Beryllium	Every nine years	Yes	Mar-11		
	E. Cadmium	Every nine years	Yes	Mar-11		
	F. Chromium	Every nine years	Yes	Mar-11		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Mar-11		
	I. Mercury	Every nine years	Yes	Mar-11		
	J. Nickel	Every nine years	Yes	Mar-11		
	K. Selenium	Every nine years	Yes	Mar-11		
	L. Thallium	Every nine years	Yes	Mar-11		
2	Radiological Chemicals	Quarterly	N/A			
3	VOC Chemicals	Quarterly	No	Apr-16	2019	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Apr-16	2019	
	B. Method 524	Triennially	No	Apr-16	2019	
	C. Method 525	Triennially	No	Apr-16	2019	
	D. Method 531.1	Triennially	No	Apr-16	2019	
	E. Method 547	Triennially	No	Apr-16	2019	
	F. Method 548	Triennially	No	Apr-16	2019	
	G. Method 549	Triennially	No	Apr-16	2019	
5	Nitrate	Annually	N/A	Feb-17		
6	Nitrite	Triennially	N/A	Feb-17		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 6, 2016</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2019</u>
E	Lead - 90% Level	<u>9.5</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.18</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.03</u> mg/l
D	Running Annual Average:	<u>0.98</u> mg/l
E	Date of last DBP test:	<u>September 19, 2016</u>
F	THM - Qtr Average:	<u>0</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Golden Valley Water Company

EPA ID: 2261

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Exceedance of Allowable Contaminant Level	Combined Radium	10/01/2017	Public Notice Requested
			Public Notice Received
			State Action-No Penalty
Exceedance of Allowable Contaminant Level	Combined Radium	07/01/2017	Public Notice Requested
	Combined Radium		State Action-No Penalty
	Combined Radium		Public Notice Received
Exceedance of Allowable Contaminant Level	Combined Radium	04/01/2017	Public Notice Requested
	Combined Radium		Public Notice Received
	Combined Radium		State Action-No Penalty
Exceedance of Allowable Contaminant Level	Combined Radium	01/01/2017	Public Notice Requested
	Combined Radium		Public Notice Received
	Combined Radium		State Action-No Penalty
Exceedance of Allowable Contaminant Level	Combined Radium	10/01/2016	Public Notice Requested
	Combined Radium		Public Notice Received
	Combined Radium		State Action-No Penalty
Exceedance of Allowable Contaminant Level	Alpha Emitters	07/01/2016	Public Notice Requested
	Alpha Emitters		Public Notice Received
	Alpha Emitters		State Action-No Penalty
Exceedance of Allowable Contaminant Level	Alpha Emitters	04/01/2016	Public Notice Requested
	Alpha Emitters		Public Notice Received
	Alpha Emitters		State Action-No Penalty
Exceedance of Allowable Contaminant Level	Alpha Emitters	01/01/2016	Public Notice Requested
	Alpha Emitters		Public Notice Received
	Alpha Emitters		State Action-No Penalty
Exceedance of Allowable Contaminant Level	Alpha Emitters	04/01/2014	Public Notice Requested
	Alpha Emitters		Public Notice Received
	Alpha Emitters		Compliance Achieved
Exceedance of Allowable Contaminant Level	Alpha Emitters	01/01/2014	Public Notice Requested
	Alpha Emitters		Public Notice Received
	Alpha Emitters		Compliance Achieved
Exceedance of Allowable Contaminant Level	Alpha Emitters	10/01/2013	Public Notice Requested
	Alpha Emitters		Public Notice Received
	Alpha Emitters		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 2261 System Name: Golden Valley Water Company

Sampler- Mr Ed Striebel Work Phone-(605)787-5653
Title- Clearwater Consultin
Address- 7005 Timberline Road
Black Hawk SD 57718

Location- City: Rapid City County: Meade
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 138 Service Connections- 55

Sources for Golden Valley Water Company

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	2005	1344	7	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
02	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites

EPA ID#: 2261 System Name: Golden Valley Water Company

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	02/06/07	536	866	8.05	205	0	80	8.0	79.5	21.5	0.25	0.01	5.8	222	251	0	287	+0.76	0.5	0.36
02	Treated	05/20/13	572	894	7.85	212	0	61	8.0	107.0	28.2	0.29	0.03	4.3	265	259	0	383	+0.70	0.5	0.39
Averages			554	880	7.95	209	0	70	8.0	93.3	24.9	0.27	0.02	5.0	244	255	0	335		0.5	0.37

You can contact us by calling
(605)787-5653 or write us at
7005 Timberline Road
Black Hawk SD 57718

Golden Valley Water Company

2017 Drinking Water Report

It's your tap water!



EPA ID: 2261



Water Quality

Last year, the Golden Valley Water Company monitored your drinking water for possible contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies.

Water Source

We serve more than 138 customers an average of 10,350 gallons of water per day. Our water is groundwater that we produce from local wells. The state has performed an assessment of our source water and they have determined that the relative susceptibility rating for the Golden Valley Water Company public water supply system is medium.

For more information about your water and information on opportunities to participate in public meetings, call (605)787-5653 and ask for Ed Striebel.

Additional Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants can be obtained by calling the Environment Protection Agency's Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Golden Valley Water Company public water supply system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Detected Contaminants

The attached table lists all the drinking water contaminants that we detected during the 2017 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Violations

Your system had violations in 2017. Please see the attached Table of Violations for information concerning these violations.

2017 Table of Detected Contaminants For Golden Valley Water Company (EPA ID 2261)

Terms and abbreviations used in this table:

- * **Maximum Contaminant Level Goal(MCLG):** the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- * **Maximum Contaminant Level(MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- * **Action Level(AL):** the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.
- * **Treatment Technique(TT):** A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU
- * **Running Annual Average(RAA):** Compliance is calculated using the running annual average of samples from designated monitoring locations.

Units:

- *MFL: million fibers per liter
- *pCi/l: picocuries per liter(a measure of radioactivity)
- *ppt: parts per trillion, or nanograms per liter
- *mrem/year: millirems per year(a measure of radiation absorbed by the body)
- *ppm: parts per million, or milligrams per liter(mg/l)
- *ppq: parts per quadrillion, or picograms per liter
- *NTU: Nephelometric Turbidity Units
- *ppb: parts per billion, or micrograms per liter(ug/l)
- *pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.2	0	09/06/16	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	10	0	09/06/16	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Alpha emitters	17	13 - 17	09/11/17	15	0	pCi/l	Erosion of natural deposits.
Combined Radium	7	4 - 7	09/11/17	5	0	pCi/l	Erosion of natural deposits.
Combined Uranium	9	ND - 9	06/12/17	30	0	ppb	Erosion of natural deposits.

Please direct questions regarding this information to Mr Ed Striebel with the Golden Valley Water Company public water system at (605)787-5653.

2017 Information on Violations For Golden Valley Water Company (EPA ID 2261)

(This Drinking Water Report can be used as a Tier III Public Notice if distributed to each customer within 12 months of when the system was notified of the violation.)

Violation Type	Parameter	Date System Notified	Duration In Months	Health Effects Language	Action Taken By Your System
Exceedance of Allowable Contaminant Level	Combined Radium	04/10/17		Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.	<p>Corrective action taken by your system:</p> <p><input type="checkbox"/> We have since completed the required compliance measures.</p> <p><input type="checkbox"/> We have taken additional measures within the water system administration to be sure that samples are taken properly in the future.</p> <p><input type="checkbox"/> The proper number of samples was taken in the following month and we are now back in compliance with the sampling regulations.</p> <p><input type="checkbox"/> Other(specify)_____</p>
Exceedance of Allowable Contaminant Level	Combined Radium	07/31/17		Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.	<p>Corrective action taken by your system:</p> <p><input type="checkbox"/> We have since completed the required compliance measures.</p> <p><input type="checkbox"/> We have taken additional measures within the water system administration to be sure that samples are taken properly in the future.</p> <p><input type="checkbox"/> The proper number of samples was taken in the following month and we are now back in compliance with the sampling regulations.</p> <p><input type="checkbox"/> Other(specify)_____</p>
Exceedance of Allowable Contaminant Level	Combined Radium	11/01/17		Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.	<p>Corrective action taken by your system:</p> <p><input type="checkbox"/> We have since completed the required compliance measures.</p> <p><input type="checkbox"/> We have taken additional measures within the water system administration to be sure that samples are taken properly in the future.</p> <p><input type="checkbox"/> The proper number of samples was taken in the following month and we are now back in compliance with the sampling regulations.</p> <p><input type="checkbox"/> Other(specify)_____</p>
Exceedance of Allowable Contaminant Level	Combined Radium	01/02/18		Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.	<p>Corrective action taken by your system:</p> <p><input type="checkbox"/> We have since completed the required compliance measures.</p> <p><input type="checkbox"/> We have taken additional measures within the water system administration to be sure that samples are taken properly in the future.</p> <p><input type="checkbox"/> The proper number of samples was taken in the following month and we are now back in compliance with the sampling regulations.</p> <p><input type="checkbox"/> Other(specify)_____</p>

For additional information concerning any violation please contact Mr Ed Striebel with the Golden Valley Water Company public water system at (605)787-5653.