

Cosmos Mystery Area Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation , Operator Certification Not Required

Population Served:	600	System Population:	600
Certified Operator:	Ms Nicole LaJeunesse 24040 Cosmos Road Rapid City, SD 57702	Work Phone:	(605)343-9802
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cosmosmysteryarea@gmail.com
Financial Contact:	Ms Nicole LaJeunesse 24040 Cosmos Road Rapid City, SD 57702	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cosmosmysteryarea@gmail.com
Other Contacts:	Mr Lyle Scandrett 24040 Cosmos Road Rapid City, SD 57702	Work Phone:	
		Home Phone:	(605)343-9501
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	July 9, 2015		
Type of System:	Non-Community	Area Served:	Pennington County
Number of Service Connections:	306	Contamination Risk:	high
Water Produced And Used By The Cosmos Mystery Area Public Water System			
PWS Owner Type:	Private Ownership	Service Area:	Summer Camp
Contract Laboratory:			Midcontinent Laboratory

Violations and Significant Deficiencies

Cosmos Mystery Area

EPA ID: 2305

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Failure to Issue PN for Violation 00111	Public Notice	08/12/2017	
Failure to Take Source Samples	E. Coli	09/05/2017	Public Notice Requested
	E. Coli		Public Notice Received
	E. Coli		Compliance Achieved
FTM-Routine Samples	RTCR	07/01/2016	Public Notice Requested
	RTCR		Compliance Achieved
	RTCR		Public Notice Received
	RTCR		DENR Issued PN
Exceedance of Allowable Contaminant Level	Total Coliform Bacteria	10/01/2013	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received

Significant Deficiency	Date Identified	Date Corrected

EPA ID#: 2305 System Name: Cosmos Mystery Area

Sampler- Mr Kevin Bybee Work Phone-(605)343-9802
Title- Cosmos Mystery Area
Address- 24040 Cosmos Road
Rapid City SD 57702

Location- City: Keystone County: Pennington
Service Area- Summer Camp/Campground
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 600 Service Connections- 1

Months that System is Open to Public-Season Opening Date- April 1st Season Closing Date- October 31st

Sources for Cosmos Mystery Area

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE-NEW WELL				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
02	#1	2008	50	16		Groundwater	Non-Vulnerable	No Treatment
05	NEW WELL	2009	500	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 2305 System Name: Cosmos Mystery Area

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

There is no data for this system.