

Monitoring/Reporting - Entry Point

Valley View Water Company

EPA ID: 0040

SAMPLING

Entry point: Treat Site - Well #1

Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals				
	A. Antimony	Every nine years	Yes	Sep-11	
	B. Arsenic	Every nine years	Yes	Sep-11	
	C. Barium	Every nine years	Yes	Sep-11	
	D. Beryllium	Every nine years	Yes	Sep-11	
	E. Cadmium	Every nine years	Yes	Sep-11	
	F. Chromium	Every nine years	Yes	Sep-11	
	G. Cyanide		Yes		State-wide waiver
	H. Fluoride	Every nine years	Yes	Sep-11	
	I. Mercury	Every nine years	Yes	Sep-11	
	J. Nickel	Every nine years	Yes	Sep-11	
	K. Selenium	Every nine years	Yes	Sep-11	
	L. Thallium	Every nine years	Yes	Sep-11	
2	Radiological Chemicals	Every six years	N/A		
3	VOC Chemicals	Quarterly	No	Nov-17	2017
4	SOC Chemicals				
	A. Method 515.1	Triennially	No	Nov-17	
	B. Method 524	Triennially	No	Nov-17	
	C. Method 525	Triennially	No	Nov-17	
	D. Method 531.1	Triennially	No	Nov-17	
	E. Method 547	Triennially	No	Nov-17	
	F. Method 548	Triennially	No	Nov-17	
	G. Method 549	Triennially	No	Nov-17	
5	Nitrate	Annually	N/A	Jun-17	
6	Nitrite	Triennially	N/A	Dec-16	

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 30, 2017</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>2</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.145</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.7</u> mg/l
D	Running Annual Average:	<u>1.68</u> mg/l
E	Date of last DBP test:	<u>September 30, 2017</u>
F	THM - Qtr Average:	<u>2.06</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Valley View Water Company

EPA ID: 0040

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
Failure to Develop Sample Site Plan	RTCR	04/01/2016	Reminder Notice
	RTCR		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected