

City of Bridgewater Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	492	System Population:	492
Certified Operator:	Mr Todd Letcher PO Box 37 - 430 N Main Bridgewater, SD 57319	Work Phone:	(605)729-2461
		Home Phone:	
		Cell Phone:	
		Fax:	(605)729-2090
		Email:	bh2ocityguy@goldenwest.net
Financial Contact:	Mrs Joan Julson PO Box 37 - 430 N Main Bridgewater, SD 57319-0037	Work Phone:	(605)729-2690
		Home Phone:	
		Cell Phone:	
		Fax:	(605)729-2090
		Email:	bridgewater@unitelsd.com
Other Contacts:	Mayor Michael Damm PO Box 37 Bridgewater, SD 57319-0037	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	October 29, 2014		
Type of System:	Community	Area Served:	McCook County
Number of Service Connections:	270	Contamination Risk:	low
Water Purchased From:			Hanson Rural Water System (0878)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>July 23, 2014</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2014</u>
E Lead - 90% Level	<u>0.3</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>1.84</u> mg/l
D Running Annual Average:	<u>1.72</u> mg/l
E Date of last DBP test:	<u>August 17, 2015</u>
F THM - Qtr Average:	<u>61.1</u> ug/l
G Haa5 - Qtr Average:	<u>31.8</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Bridgewater

EPA ID: 0066

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected