

City of Harrisburg Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	4,300	System Population:	4,300
Certified Operator:	Mr Dan Fink PO Box 26 Harrisburg, SD 57032-0026	Work Phone:	(605)743-5872
		Home Phone:	(605)743-2229
		Cell Phone:	
		Fax:	(605)743-2831
		Email:	dan.fink@harrisburgsd.gov
Financial Contact:	Ms Mary McClung PO Box 26 Harrisburg, SD 57032-0026	Work Phone:	(605)743-5872
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	mary.mcclung@harrisburgsd.gov
Other Contacts:	Mayor Julie Van Luvanee PO Box 26 Harrisburg, SD 57032-0026	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	October 9, 2013		
Type of System:	Community	Area Served:	Lincoln County
Number of Service Connections:	1,454	Contamination Risk:	moderate
Water Purchased From:			Lewis and Clark Regional Water System (2288)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>61</u>
B	Samples required:	<u>Five Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>60</u>
E	Unsafe samples:	<u>1</u>
F	Repeat samples:	<u>3</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 24, 2014</u>
B	Samples required:	<u>20</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>1.4</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.05</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>61</u>
B	Samples required:	<u>Five Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.26</u> mg/l
D	Running Annual Average:	<u>2.17</u> mg/l
E	Date of last DBP test:	<u>August 12, 2015</u>
F	THM - Qtr Average:	<u>34.9</u> ug/l
G	Haa5 - Qtr Average:	<u>16.7</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Harrisburg

EPA ID: 0148

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected