

Town of Kennebec Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	265	System Population:	265
Certified Operator:	Mr Charles Gran PO Box 262 Kennebec, SD 57544	Work Phone:	(605)869-2263
		Home Phone:	
		Cell Phone:	
		Fax:	(605)869-2163
		Email:	kennebecsd@kennebectelephone.com
Financial Contact:	Ms Sarah Caslin PO Box 61 Kennebec, SD 57544-0061	Work Phone:	(605)869-2263
		Home Phone:	
		Cell Phone:	
		Fax:	(605)869-2163
		Email:	kennebecsd@kennebectelephone.com
Other Contacts:	President Eugene Mertens PO Box 61 Kennebec, SD 57544-0061	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 15, 2017		
Type of System:	Community	Area Served:	Lyman County
Number of Service Connections:	141	Contamination Risk:	low
Water Purchased From:			WR/LJ - Mni Wiconi (2223)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>13</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>13</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 10, 2017</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>6.2</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.66</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>13</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.14</u> mg/l
D	Running Annual Average:	<u>0.51</u> mg/l
E	Date of last DBP test:	<u>August 10, 2017</u>
F	THM - Qtr Average:	<u>29.6</u> ug/l
G	Haa5 - Qtr Average:	<u>7.01</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Kennebec

EPA ID: 0182

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
	Lead/Copper		Public Notice Received

Significant Deficiency	Date Identified	Date Corrected