

# City of Kimball Drinking Water Information

## (System Information, Sampling Requirements, and Compliance Report)

**This system is not a candidate for an award:**

Violation

<b>Population Served:</b>	703	<b>System Population:</b>	703
<b>Certified Operator:</b>	Mr Norman Munger PO Box 16 Kimball, SD 57355-0016	<b>Work Phone:</b>	(605)778-6118
		<b>Home Phone:</b>	(605)778-6115
		<b>Cell Phone:</b>	
		<b>Fax:</b>	(605)778-6546
		<b>Email:</b>	kimballshop@midstatesd.net
<b>Financial Contact:</b>	Ms Barb Gakin PO Box 16 Kimball, SD 57355-0016	<b>Work Phone:</b>	(605)778-6277
		<b>Home Phone:</b>	(605)778-6444
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	kimballcitysd@midstatesd.net
<b>Other Contacts:</b>	Mayor Wayne Tupper PO Box 16 Kimball, SD 57355-0016	<b>Work Phone:</b>	(605)778-6546
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Last Inspection:</b>	October 10, 2017		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Brule County
<b>Number of Service Connections:</b>	360	<b>Contamination Risk:</b>	low
<b>Water Purchased From:</b>			Aurora-Brule Rural Water System (0621)
<b>PWS Owner Type:</b>	Local Government	<b>Service Area:</b>	Municipality
<b>Contract Laboratory:</b>			State Health Lab, Pierre

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>June 18, 2014</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Annually</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>4.2</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.16</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>3.4</u> mg/l
D	Running Annual Average:	<u>3.23</u> mg/l
E	Date of last DBP test:	<u>August 15, 2017</u>
F	THM - Qtr Average:	<u>17.8</u> ug/l
G	Haa5 - Qtr Average:	<u>18.8</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

City of Kimball

EPA ID: 0184

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
Follow-up Tap Sample Monitoring Violation	Lead/Copper	10/01/2017	Public Notice Requested

Significant Deficiency	Date Identified	Date Corrected