

Town of Lake Norden Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	424	System Population:	424
Certified Operator:	Mr Dan Koistinen PO Box 213 Lake Norden, SD 57248-0213	Work Phone:	(605)785-3602
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityln@itctel.com
Financial Contact:	Ms Delores Kangas PO Box 213 Lake Norden, SD 57248-0213	Work Phone:	(605)785-3602
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityln@itctel.com
Other Contacts:	Mayor Jason Aho PO Box 213 Lake Norden, SD 57248-0213	Work Phone:	(605)785-3602
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	May 4, 2017		
Type of System:	Community	Area Served:	Hamlin County
Number of Service Connections:	245	Contamination Risk:	high
Water Produced And Used By The Town of Lake Norden Public Water System			
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Monitoring/Reporting - Entry Point

Town of Lake Norden

EPA ID: 0187

SAMPLING

Entry point: Treatment Plant

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Sep-11		
	B. Arsenic	Every nine years	Yes	Sep-11		
	C. Barium	Every nine years	Yes	Sep-11		
	D. Beryllium	Every nine years	Yes	Sep-11		
	E. Cadmium	Every nine years	Yes	Sep-11		
	F. Chromium	Every nine years	Yes	Sep-11		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Every nine years	Yes	Sep-11		
	J. Nickel	Every nine years	Yes	Sep-11		
	K. Selenium	Every nine years	Yes	Sep-11		
	L. Thallium	Every nine years	Yes	Sep-11		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Quarterly	No	Jul-17	2017	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jul-17		
	B. Method 524	Triennially	No	Jul-17		
	C. Method 525	Triennially	No	Jul-17		
	D. Method 531.1	Triennially	No	Jul-17		
	E. Method 547	Triennially	No	Jul-17		
	F. Method 548	Triennially	No	Jul-17		
	G. Method 549	Triennially	No	Jul-17		
5	Nitrate	Annually	N/A	Aug-17		
6	Nitrite	Triennially	N/A	Aug-17		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 26, 2017</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>3.3</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.205</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.41</u> mg/l
D	Running Annual Average:	<u>0.39</u> mg/l
E	Date of last DBP test:	<u>September 6, 2017</u>
F	THM - Qtr Average:	<u>75.5</u> ug/l
G	Haa5 - Qtr Average:	<u>22.9</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Lake Norden

EPA ID: 0187

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected