

Town of Lesterville Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	127	System Population:	127
Certified Operator:	Mr Paul Scherschligt PO Box 36 Lesterville, SD 57040-0036	Work Phone:	(605)364-7793
		Home Phone:	(605)364-7415
		Cell Phone:	
		Fax:	(605)364-7588
		Email:	pjpulling@hotmail.com
Financial Contact:	Ms Janelle Munkvold PO Box 36 Lesterville, SD 57040-0036	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	lestsd@gwtc.net
Other Contacts:	President Kevin Frangenberg PO Box 36 Lesterville, SD 57040-0036	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	August 3, 2016		
Type of System:	Community	Area Served:	Yankton County
Number of Service Connections:	90	Contamination Risk:	low
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 16, 2017</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.03</u> mg/l
D	Running Annual Average:	<u>2.07</u> mg/l
E	Date of last DBP test:	<u>August 16, 2017</u>
F	THM - Qtr Average:	<u>31.7</u> ug/l
G	Haa5 - Qtr Average:	<u>17.9</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Lesterville

EPA ID: 0195

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	04/01/2015	Public Notice Requested
	Chlorine		Compliance Achieved
Routine Sample Monitoring Violation	Total Coliform Bacteria	05/01/2015	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received
Lack of Certified Operator	Certified Operator	02/01/2014	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected