

City of Menno Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	608	System Population:	608
Certified Operator:	Mr Anthony Cokens PO Box 214 Menno, SD 57045-0214	Work Phone:	(605)387-5414
		Home Phone:	(605)387-5643
		Cell Phone:	
		Fax:	
		Email:	menocity@gwtc.net
Financial Contact:	Ms Lisa Edelman PO Box 432 Menno, SD 57045-0432	Work Phone:	(605)387-2427
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	menocity@gwtc.net
Other Contacts:	Mayor Darrell Mehlhaf PO Box 432 Menno, SD 57045-0432	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	May 27, 2015		
Type of System:	Community	Area Served:	Hutchinson County
Number of Service Connections:	352	Contamination Risk:	low
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 20, 2017</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>6.6</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.3</u> mg/l
D	Running Annual Average:	<u>2.33</u> mg/l
E	Date of last DBP test:	<u>September 21, 2017</u>
F	THM - Qtr Average:	<u>33.4</u> ug/l
G	Haa5 - Qtr Average:	<u>13.3</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Menno

EPA ID: 0205

Violations From

January 1, 2013

To

January 1, 2018

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected