

Town of Oldham Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation

Population Served:	133	System Population:	133
Certified Operator:	Mr Randy Jencks PO Box 299 Arlington, SD 57212-0299	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	office@kingbrookruralwater.com
Financial Contact:	Ms Marilou Scheafer 108 S Lillie Oldham, SD 57051	Work Phone:	(605)480-3529
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityofoldham@outlook.com
Other Contacts:	Mayor Gary Krogman 108 S Lillie Oldham, SD 57051	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityofoldham@outlook.com
Last Inspection:	May 31, 2017		
Type of System:	Community	Area Served:	Kingsbury County
Number of Service Connections:	85	Contamination Risk:	low
Water Purchased From:			Kingbrook II Rural Water System (0511)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 24, 2017</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>1.95</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.21</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.65</u> mg/l
D	Running Annual Average:	<u>0.81</u> mg/l
E	Date of last DBP test:	<u>August 22, 2017</u>
F	THM - Qtr Average:	<u>52.4</u> ug/l
G	Haa5 - Qtr Average:	<u>22.3</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Oldham

EPA ID: 0231

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	04/01/2016	Public Notice Requested
	Chlorine		State Action-No Penalty
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	01/01/2016	Public Notice Requested
	Chlorine		State Action-No Penalty
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	07/01/2015	Public Notice Requested
	Chlorine		State Action-No Penalty
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	04/01/2015	Public Notice Requested
	Chlorine		State Action-No Penalty
	Chlorine		Compliance Achieved
Sanitary Survey		05/03/2014	Intentional No-Action
			Compliance Achieved
DBP Failure To Monitor	Chlorine	10/01/2014	Public Notice Requested
	Chlorine		Compliance Achieved
Routine Sample Monitoring Violation	Total Coliform Bacteria	12/01/2014	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received
Lack of Certified Operator	Certified Operator	09/01/2014	Reminder Notice
	DBP		State Action-No Penalty
	DBP		Compliance Achieved
DBP Failure To Monitor	Chlorine	07/01/2013	Public Notice Requested
	Chlorine		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected