

# Town of Peever Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



## Secretary Award For Drinking Water Excellence

<b>Population Served:</b>	168	<b>System Population:</b>	168
<b>Certified Operator:</b>	Mr Darin Roehr PO Box 49 Britton, SD 57430	<b>Work Phone:</b>	(605)448-5417
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	bdm@venturecomm.net
<b>Financial Contact:</b>	Mr Harold Fryer PO Box 23 Peever, SD 57257-0023	<b>Work Phone:</b>	(605)932-3641
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Other Contacts:</b>	President Joel Hortness PO Box 23 Peever, SD 57257-0023	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Last Inspection:</b>	March 21, 2017		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Roberts County
<b>Number of Service Connections:</b>	64	<b>Contamination Risk:</b>	low
<b>Water Purchased From:</b>			Brown-Day-Marshall RWS (0882)
<b>PWS Owner Type:</b>	Local Government	<b>Service Area:</b>	Municipality
<b>Contract Laboratory:</b>			State Health Lab, Pierre

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 20, 2017</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>0.8</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.85</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.9</u> mg/l
D	Running Annual Average:	<u>1.8</u> mg/l
E	Date of last DBP test:	<u>September 6, 2017</u>
F	THM - Qtr Average:	<u>2.55</u> ug/l
G	Haa5 - Qtr Average:	<u>2.25</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

Town of Peever

EPA ID: 0237

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected