

# Town of Raymond Drinking Water Information

## (System Information, Sampling Requirements, and Compliance Report)



### 2017 Certificate of Achievement Award.

<b>Population Served:</b>	50	<b>System Population:</b>	50
<b>Certified Operator:</b>	Mr Darrin Leetch PO Box 72 Raymond, SD 57258-0072	<b>Work Phone:</b>	(605)532-5942
		<b>Home Phone:</b>	(605)532-3740
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	darrinleetch@outlook.com
<b>Financial Contact:</b>	Ms Carrie Reis PO Box 116 Raymond, SD 57258-0116	<b>Work Phone:</b>	(605)237-1454
		<b>Home Phone:</b>	(605)532-5942
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	rareis@itctel.com
<b>Other Contacts:</b>	President Larry Brannan PO Box 116 Raymond, SD 57258-0116	<b>Work Phone:</b>	(605)532-5834
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Last Inspection:</b>	December 30, 2016		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Clark County
<b>Number of Service Connections:</b>	45	<b>Contamination Risk:</b>	low
<b>Water Purchased From:</b>			Clark Rural Water System (0881)
<b>PWS Owner Type:</b>	Local Government	<b>Service Area:</b>	Municipality
<b>Contract Laboratory:</b>			State Health Lab, Pierre

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>August 13, 2015</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2018</u>
E Lead - 90% Level	<u>0.5</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>0.41</u> mg/l
D Running Annual Average:	<u>0.51</u> mg/l
E Date of last DBP test:	<u>August 24, 2015</u>
F THM - Qtr Average:	<u>44.1</u> ug/l
G Haa5 - Qtr Average:	<u>2.84</u> ug/l

### Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

Town of Raymond

EPA ID: 0276

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected