

Town of Ree Heights Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Operator Certification , Violation

Population Served:	70	System Population:	70
Certified Operator:	Mr Delton Beck PO Box 168 Ree Heights, SD 57371-0183	Work Phone:	(605)943-5531
		Home Phone:	(605)943-5532
		Cell Phone:	
		Fax:	
		Email:	dcb@venturecomm.net
Financial Contact:	Ms Nikki Rogers PO Box 182 Ree Heights, SD 57371-0183	Work Phone:	(605)943-5559
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:	President Renae Phinney PO Box 182 Ree Heights, SD 57371-0200	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	January 28, 2016		
Type of System:	Community	Area Served:	Hand County
Number of Service Connections:	30	Contamination Risk:	moderate
Water Purchased From:			Mid-Dakota Rural Water (2175)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 11, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>1.85</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.13</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.2</u> mg/l
D	Running Annual Average:	<u>0.2</u> mg/l
E	Date of last DBP test:	<u>August 28, 2017</u>
F	THM - Qtr Average:	<u>37.8</u> ug/l
G	Haa5 - Qtr Average:	<u>16.6</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Ree Heights

EPA ID: 0278

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/01/2017	Reminder Notice
FTM-Routine Samples	RTCR	08/01/2016	Public Notice Requested
	RTCR		Compliance Achieved
DBP Failure To Monitor	Chlorine	04/01/2016	Public Notice Requested
	Chlorine		Public Notice Received
	Chlorine		Compliance Achieved
FTM-Routine Samples	RTCR	04/01/2016	Public Notice Requested
	RTCR		Compliance Achieved
	RTCR		Public Notice Received
Failure to Develop Sample Site Plan	RTCR	04/01/2016	Reminder Notice
	RTCR		Compliance Achieved
DBP Failure To Monitor	Chlorine	01/01/2016	Public Notice Requested
	Chlorine		Public Notice Received
	Chlorine		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected