

Saint Onge Sewer & Water Co Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served: 255 **System Population:** 255

Certified Operator: Mr Mike Kyte
1221 N Main Street
Spearfish, SD 57783
Work Phone: (605)645-1276
Home Phone: (605)642-4932
Cell Phone:
Fax:
Email: mwkyte@spe.midco.net

Financial Contact: Mr Larry Fierro
PO Box 165
St Onge, SD 57779-0165
Work Phone:
Home Phone:
Cell Phone:
Fax:
Email:

Other Contacts: Ms Stephanie Crowly
PO Box 165
St Onge, SD 57779
Work Phone:
Home Phone:
Cell Phone:
Fax:
Email: crookedoak@sbaccess.net

Last Inspection: May 16, 2017

Type of System: Community **Area Served:** Lawrence County

Number of Service Connections: 85 **Contamination Risk:** low

Water Produced And Used By The Saint Onge Sewer & Water Co Public Water System

PWS Owner Type: Local Government **Service Area:** Rural Water System/Colonies

Contract Laboratory: Midcontinent Laboratory

Monitoring/Reporting - Entry Point

Saint Onge Sewer & Water Co

EPA ID: 0287

SAMPLING

Entry point: Treat Site - Well #1

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Aug-12		
	B. Arsenic	Every nine years	Yes	Aug-12		
	C. Barium	Every nine years	Yes	Aug-12		
	D. Beryllium	Every nine years	Yes	Aug-12		
	E. Cadmium	Every nine years	Yes	Aug-12		
	F. Chromium	Every nine years	Yes	Aug-12		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Aug-12		
	I. Mercury	Every nine years	Yes	Aug-12		
	J. Nickel	Every nine years	Yes	Aug-12		
	K. Selenium	Every nine years	Yes	Aug-12		
	L. Thallium	Every nine years	Yes	Aug-12		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Quarterly	No	Jul-15	2018	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jul-15	2018	
	B. Method 524	Triennially	No	Jul-15	2018	
	C. Method 525	Triennially	No	Jul-15	2018	
	D. Method 531.1	Triennially	No	Jul-15	2018	
	E. Method 547	Triennially	No	Jul-15	2018	
	F. Method 548	Triennially	No	Jul-15	2018	
	G. Method 549	Triennially	No	Jul-15	2018	
5	Nitrate	Annually	N/A	Feb-17		
6	Nitrite	Triennially	N/A	May-16		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 20, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>5</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.35</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.4</u> mg/l
D	Running Annual Average:	<u>0.44</u> mg/l
E	Date of last DBP test:	<u>September 14, 2015</u>
F	THM - Qtr Average:	<u>6.31</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Saint Onge Sewer & Water Co

EPA ID: 0287

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected