

# City of Selby Drinking Water Information

## (System Information, Sampling Requirements, and Compliance Report)

**This system is not a candidate for an award:**

Operator Certification , Violation

<b>Population Served:</b>	642	<b>System Population:</b>	642
<b>Certified Operator:</b>	Mr Xavier Perman PO Box 346 Selby, SD 57472-0346	<b>Work Phone:</b>	(605)649-7874
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	cityofselby@venturecomm.net
<b>Financial Contact:</b>	Ms Vickie Schulkoski PO Box 346 Selby, SD 57472-0346	<b>Work Phone:</b>	(605)649-7301
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	cityofselby@venturecomm.net
<b>Other Contacts:</b>	Mayor Jeff Kosters PO Box 346 Selby, SD 57472-0346	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Last Inspection:</b>	August 20, 2015		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Walworth County
<b>Number of Service Connections:</b>	350	<b>Contamination Risk:</b>	moderate
<b>Water Purchased From:</b>			WEB Water Development Association (1089)
<b>PWS Owner Type:</b>	Local Government	<b>Service Area:</b>	Municipality
<b>Contract Laboratory:</b>			State Health Lab, Pierre

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 26, 2015</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>1.2</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.53</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.4</u> mg/l
D	Running Annual Average:	<u>1.8</u> mg/l
E	Date of last DBP test:	<u>August 21, 2017</u>
F	THM - Qtr Average:	<u>8.37</u> ug/l
G	Haa5 - Qtr Average:	<u>13.6</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

City of Selby

EPA ID: 0291

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	04/01/2017	Public Notice Requested
	Chlorine		Public Notice Received
DBP Failure To Monitor	Chlorine	01/01/2016	Public Notice Requested
	Chlorine		Public Notice Received
	Chlorine		Compliance Achieved
Lack of Certified Operator	Certified Operator	11/15/2015	Reminder Notice
DBP Failure To Monitor	Haloacetic Acids (HAA5)	08/01/2015	Public Notice Requested
	Haloacetic Acids (HAA5)		Public Notice Received
	Haloacetic Acids (HAA5)		Compliance Achieved
DBP Failure To Monitor	Trihalomethane (THM)	08/01/2015	Public Notice Requested
	Trihalomethane (THM)		Public Notice Received
	Trihalomethane (THM)		Compliance Achieved
Failure To Address Significant Deficiency On	LT2 ESWTR	10/16/2013	Intentional No-Action
	LT2 ESWTR		Compliance Achieved
DBP Failure To Monitor	Chlorine	01/01/2015	Public Notice Requested
	Chlorine		Compliance Achieved
Lack of Certified Operator	Certified Operator	02/01/2015	Reminder Notice
	DBP		Compliance Achieved
DBP Failure To Monitor	Haloacetic Acids (HAA5)	08/01/2014	Public Notice Requested
	Haloacetic Acids (HAA5)		Compliance Achieved
DBP Failure To Monitor	Trihalomethane (THM)	08/01/2014	Public Notice Requested
	Trihalomethane (THM)		Compliance Achieved
DBP Failure To Monitor	Chlorine	10/01/2013	Public Notice Requested
	Chlorine		Compliance Achieved
Routine Sample Monitoring Violation	Total Coliform Bacteria	11/01/2013	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received
Lack of Certified Operator	Certified Operator	06/11/2013	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected