

Town of Trent Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Operator Certification

Population Served:	232	System Population:	232
Certified Operator:	Mr Bob Dickey PO Box 771 - 201 E 3rd Street Trent, SD 57065-0771	Work Phone:	(605)428-5160
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	trenttown@siouxvalley.net
Financial Contact:	Ms Kim Nelson PO Box 754 Trent, SD 57065-0754	Work Phone:	(605)428-5160
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	trenttown@siouxvalley.net
Other Contacts:	President Robert Dickey PO Box 754 Trent, SD 57065-0754	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	trenttown@siouxvalley.net
Last Inspection:	April 20, 2016		
Type of System:	Community	Area Served:	Moody County
Number of Service Connections:	109	Contamination Risk:	moderate
Water Purchased From:			Big Sioux Community Water System (0429)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>15</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>14</u>
E Unsafe samples:	<u>1</u>
F Repeat samples:	<u>3</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>October 17, 2017</u>
B Samples required:	<u>10</u>
C Sampling Frequency	<u>Every Six Months</u>
D Date Due Next	
E Lead - 90% Level	<u>0.9</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>15</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>0.71</u> mg/l
D Running Annual Average:	<u>0.52</u> mg/l
E Date of last DBP test:	<u>August 28, 2017</u>
F THM - Qtr Average:	<u>21.3</u> ug/l
G Haa5 - Qtr Average:	<u>6.37</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Trent

EPA ID: 0333

Violations From

January 1, 2013

To

January 1, 2018

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected