

City of Tyndall Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	1,067	System Population:	1,067
Certified Operator:	Mr Robert Brattmiller PO Box 29 - 110 E 17th Ave Tyndall, SD 57066-0029	Work Phone:	(605)589-3481
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tyndalsd@heartlandpower.org
Financial Contact:	Ms Linda Pesek PO Box 29 Tyndall, SD 57066-0029	Work Phone:	(605)589-3481
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tyndalsd@heartlandpower.org
Other Contacts:	Mayor David Vavruska PO Box 29 Tyndall, SD 57066-0029	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	October 15, 2015		
Type of System:	Community	Area Served:	Bon Homme County
Number of Service Connections:	537	Contamination Risk:	high
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>24</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 14, 2015</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>0.2</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.03</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.81</u> mg/l
D	Running Annual Average:	<u>3.14</u> mg/l
E	Date of last DBP test:	<u>August 28, 2017</u>
F	THM - Qtr Average:	<u>35.9</u> ug/l
G	Haa5 - Qtr Average:	<u>17.1</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Tyndall

EPA ID: 0337

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected