

Town of Volin Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	161	System Population:	161
Certified Operator:	Mr Dan Frank PO Box 143 Volin, SD 57072-0143	Work Phone:	(605)267-2571
		Home Phone:	
		Cell Phone:	
		Fax:	(605)267-2991
		Email:	townofvolin@gmail.com
Financial Contact:	Ms Evelyn Kloucek PO Box 175 Volin, SD 57072-0175	Work Phone:	(605)661-2521
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	townofvolin@gmail.com
Other Contacts:	President Corey Logan PO Box 175 Volin, SD 57072-0175	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	June 5, 2017		
Type of System:	Community	Area Served:	Yankton County
Number of Service Connections:	88	Contamination Risk:	low
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 27, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>3.6</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.5</u> mg/l
D	Running Annual Average:	<u>2.53</u> mg/l
E	Date of last DBP test:	<u>August 28, 2017</u>
F	THM - Qtr Average:	<u>35.5</u> ug/l
G	Haa5 - Qtr Average:	<u>17.2</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Volin

EPA ID: 0347

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	07/01/2013	Public Notice Requested
	Chlorine		Compliance Achieved
Routine Sample Monitoring Violation	Total Coliform Bacteria	09/01/2013	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received

Significant Deficiency	Date Identified	Date Corrected