

City of Wagner Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	1,566	System Population:	1,566
Certified Operator:	Mr Mike Kazena PO Box 40 Wagner, SD 57380-0040	Work Phone:	(605)384-3741
		Home Phone:	
		Cell Phone:	
		Fax:	(605)384-5644
		Email:	cywagner@hcinet.net
Financial Contact:	Ms Rebecca Brunsing PO Box 40 Wagner, SD 57380-0040	Work Phone:	(605)384-3741
		Home Phone:	
		Cell Phone:	
		Fax:	(605)384-5644
		Email:	cywagner@hcinet.net
Other Contacts:	Mayor Don Hosek PO Box 40 Wagner, SD 57380-0040	Work Phone:	(605)384-3741
		Home Phone:	(605)384-5122
		Cell Phone:	
		Fax:	(605)384-5644
		Email:	haarimpl@hcinet.net
Last Inspection:	April 4, 2017		
Type of System:	Community	Area Served:	Charles Mix County
Number of Service Connections:	689	Contamination Risk:	low
Water Purchased From:			Randall Community Water District (0433)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>48</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>48</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 22, 2015</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.04</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>48</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.31</u> mg/l
D	Running Annual Average:	<u>1.31</u> mg/l
E	Date of last DBP test:	<u>November 14, 2017</u>
F	THM - Qtr Average:	<u>29.2</u> ug/l
G	Haa5 - Qtr Average:	<u>17</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Wagner

EPA ID: 0348

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Failure To Address Significant Deficiency On	LT2 ESWTR	01/01/2018	Intentional No-Action
Lack of Certified Operator	Certified Operator	07/16/2014	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected