

Town of Wallace Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation

Population Served:	78	System Population:	78
Certified Operator:	Mr Pat Callan PO Box 65 Wallace, SD 57272-0065	Work Phone: Home Phone: Cell Phone: Fax: Email:	patcallan@hotmail.com
Financial Contact:	Mr Ross Keller PO Box 65 Wallace, SD 57272-0065	Work Phone: (605)758-2596 Home Phone: (605)758-2537 Cell Phone: Fax: Email:	
Other Contacts:	President Al Keller PO Box 65 Wallace, SD 57272-0065	Work Phone: Home Phone: Cell Phone: Fax: Email:	
Last Inspection:	December 17, 2015		
Type of System:	Community	Area Served:	Codington County
Number of Service Connections:	42	Contamination Risk:	low
Water Purchased From:			Clark Rural Water System (0881)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>15</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>14</u>
E	Unsafe samples:	<u>1</u>
F	Repeat samples:	<u>3</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 18, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>0.55</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.06</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>15</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.69</u> mg/l
D	Running Annual Average:	<u>0.75</u> mg/l
E	Date of last DBP test:	<u>August 29, 2017</u>
F	THM - Qtr Average:	<u>55.4</u> ug/l
G	Haa5 - Qtr Average:	<u>7.46</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Wallace

EPA ID: 0350

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/01/2017	Reminder Notice
	DBP		Compliance Achieved
Lack of Certified Operator	Certified Operator	02/01/2014	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected