

City of Lake Preston Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation

Population Served:	565	System Population:	565
Certified Operator:	Mr Jacob Langland 111 NE Third Street Lake Preston, SD 57249	Work Phone:	(605)847-4140
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	lakepreston@mchsi.com
Financial Contact:	Ms Callie Junker 111 NE Third Street Lake Preston, SD 57249	Work Phone:	(605)847-4140
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	lakepreston@mchsi.com
Other Contacts:	Mayor Andy Wienk 111 NE Third Street Lake Preston, SD 57249	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	September 30, 2015		
Type of System:	Community	Area Served:	Kingsbury County
Number of Service Connections:	325	Contamination Risk:	low
Water Purchased From:			Kingbrook II Rural Water System (0511)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 30, 2015</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>12.1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.61</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.72</u> mg/l
D	Running Annual Average:	<u>1.11</u> mg/l
E	Date of last DBP test:	<u>August 21, 2017</u>
F	THM - Qtr Average:	<u>37.1</u> ug/l
G	Haa5 - Qtr Average:	<u>15.2</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Lake Preston

EPA ID: 0398

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	05/30/2017	Reminder Notice
	DBP		Compliance Achieved
Lack of Certified Operator	Certified Operator	10/01/2013	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected