



# Monitoring/Reporting - Entry Point

Lourie Lane Homeowners Assoc

EPA ID: 0416

## SAMPLING

Entry point: Well #2 South

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Triennially	No	Dec-16		
	B. Arsenic	Triennially	No	Dec-16		
	C. Barium	Triennially	No	Dec-16		
	D. Beryllium	Triennially	No	Dec-16		
	E. Cadmium	Triennially	No	Dec-16		
	F. Chromium	Triennially	No	Dec-16		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Triennially	No	Dec-16		
	I. Mercury	Triennially	No	Dec-16		
	J. Nickel	Triennially	No	Dec-16		
	K. Selenium	Triennially	No	Dec-16		
	L. Thallium	Triennially	No	Dec-16		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Quarterly	No	Dec-17	the fourth qu	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Oct-15	2018	
	B. Method 524	Triennially	No	Oct-15	2018	
	C. Method 525	Triennially	No	Oct-15	2018	
	D. Method 531.1	Triennially	No	Oct-15	2018	
	E. Method 547	Triennially	No	Oct-15	2018	
	F. Method 548	Triennially	No	Oct-15	2018	
	G. Method 549	Triennially	No	Oct-15	2018	
5	Nitrate	Annually	N/A	Apr-17		
6	Nitrite	Triennially	N/A	Dec-16		

(These values are calculated from available data. Check correspondence for verification.)

# Monitoring/Reporting - Entry Point

Lourie Lane Homeowners Assoc

EPA ID: 0416

## SAMPLING

Entry point: Well #1 North

Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals				
	A. Antimony	Triennially	No	Dec-16	
	B. Arsenic	Triennially	No	Dec-16	
	C. Barium	Triennially	No	Dec-16	
	D. Beryllium	Triennially	No	Dec-16	
	E. Cadmium	Triennially	No	Dec-16	
	F. Chromium	Triennially	No	Dec-16	
	G. Cyanide		Yes		State-wide waiver
	H. Fluoride	Triennially	No	Dec-16	
	I. Mercury	Triennially	No	Dec-16	
	J. Nickel	Triennially	No	Dec-16	
	K. Selenium	Triennially	No	Dec-16	
	L. Thallium	Triennially	No	Dec-16	
2	Radiological Chemicals	Every six years	N/A		
3	VOC Chemicals	Quarterly	No	Dec-15	2018
4	SOC Chemicals				
	A. Method 515.1	Triennially	No	Oct-15	2018
	B. Method 524	Triennially	No	Oct-15	2018
	C. Method 525	Triennially	No	Oct-15	2018
	D. Method 531.1	Triennially	No	Oct-15	2018
	E. Method 547	Triennially	No	Oct-15	2018
	F. Method 548	Triennially	No	Oct-15	2018
	G. Method 549	Triennially	No	Oct-15	2018
5	Nitrate	Annually	N/A	Apr-17	
6	Nitrite	Triennially	N/A	Dec-16	

(These values are calculated from available data. Check correspondence for verification.)

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 24, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>4</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.235</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis:  to

A	Samples submitted:	<u>No Tests</u>
B	Samples required:	
C	Last Qtr Cl Residual:	<u></u> mg/l
D	Running Annual Average:	<u></u> mg/l
E	Date of last DBP test:	<u>No Tests</u>
F	THM - Qtr Average:	<u></u> ug/l
G	Haa5 - Qtr Average:	<u></u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

Lourie Lane Homeowners Assoc

EPA ID: 0416

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected