

Riverside Mobile Home Court Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	60	System Population:	60
Certified Operator:	Mr Donald Zacher PO Box 516 Spearfish, SD 57783-0516	Work Phone:	(605)642-7304
		Home Phone:	
		Cell Phone:	
		Fax:	(605)642-7304
		Email:	donald@blackhillsescrow.com
Financial Contact:	Mr Donald Zacher PO Box 516 Spearfish, SD 57783-0516	Work Phone:	(605)642-7304
		Home Phone:	
		Cell Phone:	
		Fax:	(605)642-7304
		Email:	donaldz@rushmore.com
Other Contacts:			
Last Inspection:	June 8, 2016		
Type of System:	Community	Area Served:	Butte County
Number of Service Connections:	29	Contamination Risk:	low
Water Purchased From:			Butte-Meade SWD-Bean Well (0223)
PWS Owner Type:	Private Ownership	Service Area:	TC/Mobile Home Park
Contract Laboratory:			Midcontinent Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 22, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2018</u>
E	Lead - 90% Level	<u>0.1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.45</u> mg/l
D	Running Annual Average:	<u>0.44</u> mg/l
E	Date of last DBP test:	<u>September 8, 2015</u>
F	THM - Qtr Average:	<u>4.82</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Riverside Mobile Home Court

EPA ID: 0508

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected