

Kingbrook II Rural Water System Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	5,300	System Population:	2,898
Certified Operator:	Mr Brian Callies PO Box 299 302 E Ash Arlington, SD 57212	Work Phone:	(605)983-5074
		Home Phone:	
		Cell Phone:	
		Fax:	(605)983-5636
		Email:	bcallieskbrw@gmail.com
Financial Contact:	Ms Jolene King PO Box 299 Arlington, SD 57212-0299	Work Phone:	(605)983-5074
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	jolene@kingbrookruralwater.com
Other Contacts:	Mr Randy Jencks PO Box 299 Arlington, SD 57242	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	June 16, 2016		
Type of System:	Community	Area Served:	Kingsbury County
Number of Service Connections:	1,600	Contamination Risk:	moderate
Water Sold To:			Howard, Iroquois, Lake Preston, Oldham, Ramona
PWS Owner Type:	Private Ownership	Service Area:	Rural Water System/Colonies
Contract Laboratory:			State Health Lab, Pierre

Monitoring/Reporting - Entry Point

Kingbrook II Rural Water System

EPA ID: 0511

SAMPLING

Entry point: Desmet Treatment Plant

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Nov-12		
	B. Arsenic	Every nine years	Yes	Nov-12		
	C. Barium	Every nine years	Yes	Nov-12		
	D. Beryllium	Every nine years	Yes	Nov-12		
	E. Cadmium	Every nine years	Yes	Nov-12		
	F. Chromium	Every nine years	Yes	Nov-12		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Every nine years	Yes	Nov-12		
	J. Nickel	Every nine years	Yes	Nov-12		
	K. Selenium	Every nine years	Yes	Nov-12		
	L. Thallium	Every nine years	Yes	Nov-12		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Quarterly	No	Aug-15	2018	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Sep-15	2018	
	B. Method 524	Triennially	No	Sep-15	2018	
	C. Method 525	Triennially	No	Sep-15	2018	
	D. Method 531.1	Triennially	No	Sep-15	2018	
	E. Method 547	Triennially	No	Sep-15	2018	
	F. Method 548	Triennially	No	Sep-15	2018	
	G. Method 549	Triennially	No	Sep-15	2018	
5	Nitrate	Annually	N/A	May-17		
6	Nitrite	Triennially	N/A	May-17		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>36</u>
B Samples required:	<u>Three Samples Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>36</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>June 24, 2015</u>
B Samples required:	<u>10</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2018</u>
E Lead - 90% Level	<u>5</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.23</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>36</u>
B Samples required:	<u>Three Samples Each Month.</u>
C Last Qtr Cl Residual:	<u>0.83</u> mg/l
D Running Annual Average:	<u>0.93</u> mg/l
E Date of last DBP test:	<u>August 15, 2017</u>
F THM - Qtr Average:	<u>30.95</u> ug/l
G Haa5 - Qtr Average:	<u>16.2</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Kingbrook II Rural Water System

EPA ID: 0511

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected