

Town of South Shore Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	180	System Population:	180
Certified Operator:	Mr Chuck Werner PO Box 57 South Shore, SD 57263-0057	Work Phone:	(605)756-4130
		Home Phone:	(605)756-4358
		Cell Phone:	
		Fax:	
		Email:	townsouthshore@sstel.net
Financial Contact:	Ms Kathy Meyer PO Box 57 South Shore, SD 57263-0057	Work Phone:	(605)756-4130
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	townsouthshore@sstel.net
Other Contacts:	President Jon Meyer PO Box 57 South Shore, SD 57263-0057	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 30, 2016		
Type of System:	Community	Area Served:	Codington County
Number of Service Connections:	66	Contamination Risk:	moderate
Water Produced And Used By The Town of South Shore Public Water System			
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Monitoring/Reporting - Entry Point

Town of South Shore

EPA ID: 2068

SAMPLING

Entry point: Treat Site - Well #2

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Nov-11		
	B. Arsenic	Every nine years	Yes	Nov-11		
	C. Barium	Every nine years	Yes	Nov-11		
	D. Beryllium	Every nine years	Yes	Nov-11		
	E. Cadmium	Every nine years	Yes	Nov-11		
	F. Chromium	Every nine years	Yes	Nov-11		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Nov-11		
	I. Mercury	Every nine years	Yes	Nov-11		
	J. Nickel	Every nine years	Yes	Nov-11		
	K. Selenium	Every nine years	Yes	Nov-11		
	L. Thallium	Every nine years	Yes	Nov-11		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Quarterly	No	Aug-16	2019	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jun-16	2019	
	B. Method 524	Not Required	Yes			
	C. Method 525	Triennially	No	Jun-16	2019	
	D. Method 531.1	Not Required	Yes			
	E. Method 547	Triennially	No	Jun-16	2019	
	F. Method 548	Not Required	Yes			
	G. Method 549	Not Required	Yes			
5	Nitrate	Annually-1st Qtr	N/A	May-17		
6	Nitrite	Triennially	N/A	Jul-15		

(These values are calculated from available data. Check correspondence for verification.)

Monitoring/Reporting - Entry Point

Town of South Shore

EPA ID: 2068

SAMPLING

Entry point: Treat Site - Well #3

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Nov-11		
	B. Arsenic	Every nine years	Yes	Nov-11		
	C. Barium	Every nine years	Yes	Nov-11		
	D. Beryllium	Every nine years	Yes	Nov-11		
	E. Cadmium	Every nine years	Yes	Nov-11		
	F. Chromium	Every nine years	Yes	Nov-11		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Nov-11		
	I. Mercury	Every nine years	Yes	Nov-11		
	J. Nickel	Every nine years	Yes	Nov-11		
	K. Selenium	Every nine years	Yes	Nov-11		
	L. Thallium	Every nine years	Yes	Nov-11		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Quarterly	No	Aug-16	2019	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jun-16	2019	
	B. Method 524	Not Required	Yes			
	C. Method 525	Triennially	No	Jun-16	2019	
	D. Method 531.1	Not Required	Yes			
	E. Method 547	Triennially	No	Jun-16	2019	
	F. Method 548	Not Required	Yes			
	G. Method 549	Not Required	Yes			
5	Nitrate	Annually-1st Qtr	N/A	May-17		
6	Nitrite	Triennially	N/A	Jul-15		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 21, 2016</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2019</u>
E	Lead - 90% Level	<u>1.91</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.42</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.1</u> mg/l
D	Running Annual Average:	<u>1.11</u> mg/l
E	Date of last DBP test:	<u>September 6, 2016</u>
F	THM - Qtr Average:	<u>6.12</u> ug/l
G	Haa5 - Qtr Average:	<u>4.02</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of South Shore

EPA ID: 2068

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
Failure To Address Significant Deficiency On	Groundwater Rule	11/15/2013	Reminder Notice
	Groundwater Rule		Compliance Achieved
Lack of Certified Operator	Certified Operator	02/01/2015	Reminder Notice
	DBP		Compliance Achieved
Lack of Certified Operator	Certified Operator	02/01/2014	Reminder Notice
	DBP		Compliance Achieved
Failure to Monitor	Nitrate	04/01/2013	Public Notice Requested
	Nitrate		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected