

# East Winds Court, Inc. Drinking Water Information

## (System Information, Sampling Requirements, and Compliance Report)



**This system is not a candidate for an award:**

Violation

<b>Population Served:</b>	180	<b>System Population:</b>	180
<b>Certified Operator:</b>	Mr Roy Mellegaard PO Box 51 Mission Hill, SD 57046	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	mellegaard3@gmail.com
<b>Financial Contact:</b>	Mr Ron Galvan 300 Pearl Street Yankton, SD 57078	<b>Work Phone:</b>	(605)661-4561
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	rgalvan@midco.net
<b>Other Contacts:</b>			
<b>Last Inspection:</b>	June 23, 2015		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Yankton County
<b>Number of Service Connections:</b>	66	<b>Contamination Risk:</b>	moderate
<b>Water Purchased From:</b>			Bon Homme-Yankton RWS (0865)
<b>PWS Owner Type:</b>	Private Ownership	<b>Service Area:</b>	TC/Mobile Home Park
<b>Contract Laboratory:</b>			Sioux Falls Health Laboratory

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>14</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>13</u>
E	Unsafe samples:	<u>1</u>
F	Repeat samples:	<u>3</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 26, 2013</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2016</u>
E	Lead - 90% Level	<u>0.1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>14</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.5</u> mg/l
D	Running Annual Average:	<u>0.47</u> mg/l
E	Date of last DBP test:	<u>September 28, 2015</u>
F	THM - Qtr Average:	<u>52</u> ug/l
G	Haa5 - Qtr Average:	<u>23.4</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

**East Winds Court, Inc.**

**EPA ID: 2099**

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
Failure to Issue PN for Violation 00106	Public Notice	03/15/2016	
Routine Sample Monitoring Violation	Total Coliform Bacteria	02/01/2015	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		DENR Issued PN

Significant Deficiency	Date Identified	Date Corrected