

Monitoring/Reporting - Entry Point

Quaal Water Association

EPA ID: 2127

SAMPLING

Entry point: Treat Site - Well #1

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Nov-13		
	B. Arsenic	Every nine years	Yes	Nov-13		
	C. Barium	Every nine years	Yes	Nov-13		
	D. Beryllium	Every nine years	Yes	Nov-13		
	E. Cadmium	Every nine years	Yes	Nov-13		
	F. Chromium	Every nine years	Yes	Nov-13		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Nov-13		
	I. Mercury	Every nine years	Yes	Nov-13		
	J. Nickel	Every nine years	Yes	Nov-13		
	K. Selenium	Every nine years	Yes	Nov-13		
	L. Thallium	Every nine years	Yes	Nov-13		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Quarterly	No	May-16	2019	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jul-16	2019	
	B. Method 524	Triennially	No	Jul-16	2019	
	C. Method 525	Triennially	No	Jul-16	2019	
	D. Method 531.1	Triennially	No	Jul-16	2019	
	E. Method 547	Triennially	No	Jul-16	2019	
	F. Method 548	Triennially	No	Jul-16	2019	
	G. Method 549	Triennially	No	Jul-16	2019	
5	Nitrate	Annually	N/A	Feb-17		
6	Nitrite	Triennially	N/A	Feb-15		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 20, 2016</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2019</u>
E Lead - 90% Level	<u>4</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.315</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>1.47</u> mg/l
D Running Annual Average:	<u>1.15</u> mg/l
E Date of last DBP test:	<u>September 20, 2016</u>
F THM - Qtr Average:	<u>4.06</u> ug/l
G Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Quaal Water Association

EPA ID: 2127

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected