

# Hay Creek Water Company Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



## 2015 Certificate of Achievement Award.

<b>Population Served:</b>	300	<b>System Population:</b>	300
<b>Certified Operator:</b>	Mr Jim Emery 19157 Sandstone Road Belle Fourche, SD 57717	<b>Work Phone:</b>	(605)210-0129
		<b>Home Phone:</b>	(605)892-3029
		<b>Cell Phone:</b>	
		<b>Fax:</b>	(605)892-3390
		<b>Email:</b>	emeryreindeer@msn.com
<b>Financial Contact:</b>	Mr Keith Anderson PO Box 85 Belle Fourche, SD 57717	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Other Contacts:</b>			
<b>Last Inspection:</b>	January 12, 2015		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Butte County
<b>Number of Service Connections:</b>	116	<b>Contamination Risk:</b>	low
<b>Water Purchased From:</b>			Black Hills Water Distribution, LLC (2144)
<b>PWS Owner Type:</b>	Private Ownership	<b>Service Area:</b>	Housing Development
<b>Contract Laboratory:</b>			Midcontinent Laboratory

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>11</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>11</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 16, 2013</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2016</u>
E Lead - 90% Level	<u>7.3</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.055</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>11</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>2.63</u> mg/l
D Running Annual Average:	<u>1.06</u> mg/l
E Date of last DBP test:	<u>September 16, 2013</u>
F THM - Qtr Average:	<u>0</u> ug/l
G Haa5 - Qtr Average:	<u>1.03</u> ug/l

### Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

Hay Creek Water Company

EPA ID: 2143

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/01/2013	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected