

Northern Lights Mobile Home Park Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation

Population Served:	57	System Population:	57
Certified Operator:	Mr Steve Drotzmann PO Box 1082 Yankton, SD 57078	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	stevedrotzmann@outlook.com
Financial Contact:	Mr Steve Drotzmann PO Box 1082 Yankton, SD 57078	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:			
Last Inspection:	June 5, 2017		
Type of System:	Community	Area Served:	Yankton County
Number of Service Connections:	29	Contamination Risk:	low
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Private Ownership	Service Area:	TC/Mobile Home Park
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 28, 2017</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2019</u>
E	Lead - 90% Level	<u>1.25</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.16</u> mg/l
D	Running Annual Average:	<u>1.27</u> mg/l
E	Date of last DBP test:	<u>September 28, 2017</u>
F	THM - Qtr Average:	<u>29.2</u> ug/l
G	Haa5 - Qtr Average:	<u>15.2</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Northern Lights Mobile Home Park

EPA ID: 2289

Violations From January 1, 2013 To January 1, 2018

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	04/01/2017	Public Notice Requested
Lack of Certified Operator	Certified Operator	02/01/2017	Reminder Notice
	DBP		Compliance Achieved
Follow-up Tap Sample Monitoring Violation	Lead/Copper	10/01/2016	Public Notice Requested
	Lead/Copper		Public Notice Received
	Lead/Copper		Compliance Achieved
Sanitary Survey		06/20/2014	Intentional No-Action
			Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected