

The City of Armour public water system purchases 100% of their water from Randall Community Water District (0433).

Information on Lead and Copper for Armour (EPA ID 0028)

Terms and abbreviations used in this table:

* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

Units:

*ppb: parts per billion, or micrograms per liter(ug/l)

*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.0	0	08/19/14	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	2	0	08/19/14	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
506 Fourth St	08/19/14	4.40	0.03	Tier I - Lead Service Line
806 Mathews St	08/19/14	1.70	0.02	Tier I - Lead Service Line
1004 First St.	08/19/14	1.20	0.02	Tier I - Lead Service Line
208 Braddock St.	08/19/14	0.60	0.02	Tier I - Lead Service Line
810 Dodson	08/19/14	0.40	0.02	Tier I - Lead Solder
1206 Main St	08/19/14	0.40	0.02	Tier I - Lead Service Line
909 Main St	08/18/14	0.20	0.02	Tier I - Lead Service Line
1014 Main St	08/19/14	0.20	0.02	Tier I - Lead Solder
1008 First St	08/19/14	0.10	0.02	Tier I - Lead Solder
209 Second St.	08/19/14	0.10	0.02	Tier I - Lead Service Line

Please direct questions regarding this information to Mr Dave Majerus with the Armour public water system at (605)724-2277.