

The Amherst Water Company public water system purchases 100% of their water from Brown-Day-Marshall RWS (0882).

Information on Lead and Copper for Amherst Water Company (EPA ID 0030)

Terms and abbreviations used in this table:

* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

Units:

*ppb: parts per billion, or micrograms per liter(ug/l)

*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.1	0	09/25/14	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	1	0	09/25/14	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
501 Center St	09/25/14	2.10	0.15	Tier III
319 Center St	09/25/14	0.80	0.06	Tier III
209 Center St	09/25/14	0.60	0.03	Tier III
301 3rd St	09/25/14	0.60	0.10	Tier III
402 4th St	09/25/14	0.60	0.08	Tier III

Please direct questions regarding this information to Mr Darin Roehr with the Amherst Water Company public water system at (605)448-5417.