

The Town of Batesland public water system purchases 100% of their water from Federal.

Information on Lead and Copper for Batesland (EPA ID 0036)

Terms and abbreviations used in this table:

* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

Units:

*ppb: parts per billion, or micrograms per liter(ug/l)

*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.0	0	09/15/15	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	0	0	09/15/15	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
Ernie Abold	09/15/15	2.10	0.02	Unknown Tier Group
3rd & Ash St	09/15/15	1.90	0.02	Tier III
100 1st St	09/15/15	0.80	0.12	Tier III
Sophia Conroy	09/15/15	0.70	0.08	Unknown Tier Group
Denise Clifford	09/23/15	0.70	0.04	Unknown Tier Group
Linda Rodriguez	09/15/15	0.50	0.07	Unknown Tier Group
2nd & Ash St	09/15/15	0.30	0.14	Tier III
Bill Stover	09/15/15	0.30	0.02	Unknown Tier Group
Rena Conroy	09/15/15	0.10	0.03	Tier III
Nathan Kehn	09/15/15	0.10	0.04	Unknown Tier Group

Please direct questions regarding this information to Mr Willard Clifford with the Batesland public water system at (605)455-1367.