

The Town of Bradley public water system purchases 100% of their water from Clark Rural Water System (0881).

Information on Lead and Copper for Bradley (EPA ID 0047)

Terms and abbreviations used in this table:

* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

Units:

*ppb: parts per billion, or micrograms per liter(ug/l)

*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.1	0	06/30/14	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	3	0	06/30/14	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
342 Bentley	06/30/14	2.60	0.09	Tier III
527 4th St	06/30/14	2.40	0.08	Tier III
324 Hart Ave	07/02/14	2.40	0.02	Tier III
318 Main St	06/30/14	1.70	0.20	Tier III
415 4th St	06/30/14	0.80	0.02	Tier III

Please direct questions regarding this information to Mr Dave Moeller with the Bradley public water system.