

The Town of Bristol public water system purchases 100% of their water from WEB Water Development Association (1089).

Information on Lead and Copper for Bristol (EPA ID 0067)

Terms and abbreviations used in this table:

* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

Units:

*ppb: parts per billion, or micrograms per liter(ug/l)

*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.6	0	09/30/14	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	1	0	09/30/14	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
315 3rd Ave W	09/30/14	1.90	0.30	Tier III
65 1st Ave NW	09/30/14	1.00	0.55	Tier III
304 N 5th St	09/29/14	0.70	0.10	Tier III
210 West 2nd St	09/29/14	0.60	0.31	Tier I - Lead Solder
45 2nd Ave W	09/30/14	0.60	0.58	Tier III

Please direct questions regarding this information to Mr Dave Kroll with the Bristol public water system at (605)492-3225.