

Information on Lead and Copper for B & J Mobile Home Park (EPA ID 2122)

Terms and abbreviations used in this table:

* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

Units:

*ppb: parts per billion, or micrograms per liter(ug/l)

*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.1	0	08/22/13	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	3	0	08/22/13	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
#41	08/22/13	5.00	0.13	Tier III
#19	08/12/13	1.00	0.02	Tier III
#48	08/20/13	1.00	0.01	Tier III
#9	08/22/13	1.00	0.03	Tier III
#36	08/21/13	1.00	0.04	Tier III

Please direct questions regarding this information to Mr Bob Powles with the B & J Mobile Home Park public water system.