

## Information on Lead and Copper for 76 Ranch Estates (EPA ID 2259)

### Terms and abbreviations used in this table:

\* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

### Units:

\*ppb: parts per billion, or micrograms per liter(ug/l)

\*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.1	0	09/16/13	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	1	0	09/16/13	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
tract 16	09/16/13	1.00	0.21	Other
tract 7	09/24/13	0.00	0.06	Other
tract 1	09/12/13	0.00	0.04	Other
tract 2	09/24/13	0.00	0.08	Other
tract 14	09/11/13	0.00	0.02	Other

Please direct questions regarding this information to Mr Rollin Sieveke with the 76 Ranch Estates public water system.