

## Information on Lead and Copper for Cedar Gulch II (EPA ID 2295)

### Terms and abbreviations used in this table:

\* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.

### Units:

\*ppb: parts per billion, or micrograms per liter(ug/l)

\*ppm: parts per million, or milligrams per liter(mg/l)

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.0	0	09/16/15	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	1	0	09/18/15	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Sample Site	Sample Date	Lead(ppb)	Copper(ppm)	Sample Site Type
23479 Brahman Ln	09/16/15	1.00	0.01	Other
23475 Bradsky Rd	09/16/15	1.00	0.01	Other
23471 Brahman Ln	09/16/15	1.00	0.02	Other
23477 Bradsky Ln	09/17/15	1.00	0.01	Other
23473 Bradsky Rd	09/18/15	1.00	0.01	Other

Please direct questions regarding this information to Mr Jay Chittim with the Cedar Gulch II public water system at (605)787-8092.